

深圳妈湾电力有限公司2021年9月#1烟卤烟气数据

浓度单位: (mg/m³)
烟气量单位: 万立方米/天

日期	颗粒物		二氧化硫		氮氧化物		烟气量	氧量%	温度℃	湿度%	机组负荷率 (%)	
	标志	折算	标志	折算	标志	折算					#1机组	#2机组
1	2.92	3.05	6.36	6.56	19.88	20.70	3566	6.60	77.20	6.10	60	65
2	2.90	3.06	4.48	4.71	23.42	24.66	3457	6.80	76.70	6.10	60	59
3	2.82	2.97	8.40	8.74	21.91	23.05	3603	6.70	77.80	6.30	59	65
4	2.72	2.89	8.39	8.81	20.71	22.03	3524	6.90	77.50	6.40	59	62
5	2.70	2.88	5.60	5.91	20.76	22.09	3489	6.90	76.90	6.50	62	58
6	2.68	2.88	6.01	6.38	20.24	21.75	3480	7.00	78.00	6.70	59	61
7	2.90	3.04	5.45	5.64	21.74	22.66	3493	6.60	78.60	6.80	60	62
8	3.08	3.22	5.24	5.41	26.10	27.33	3461	6.60	77.90	6.80	60	61
9	2.94	3.10	5.49	5.76	27.14	28.55	3317	6.70	77.30	6.80	59	54
10	2.77	2.83	6.16	6.29	27.84	28.45	3434	6.30	78.60	7.10	63	60
11	3.05	3.32	19.22	20.39	24.43	26.40	2145	7.10	79.20	7.30	69	1:44机组停运
12	3.67	4.03	19.09	20.82	20.42	22.34	2013	7.30	78.30	7.30	68	机组停运
13	4.62	5.31	20.80	23.59	20.05	22.64	2129	7.70	76.50	7.20	68	机组停运
14	3.66	4.21	22.81	26.03	26.91	30.15	2189	7.80	74.80	7.20	69	机组停运
15	2.91	2.96	19.13	19.43	22.46	22.92	1853	6.30	79.00	7.50	68	机组停运
16	2.86	3.29	12.94	14.22	24.04	27.02	2887	7.50	75.20	7.00	66	12:13并网发电
17	2.63	2.70	12.25	12.57	23.24	23.88	3350	6.40	78.40	7.20	68	48
18	2.60	2.58	18.17	17.64	23.14	22.97	3594	5.90	79.80	7.30	67	67
19	2.43	2.38	21.70	21.25	23.35	22.89	3893	5.70	80.00	7.30	72	75
20	2.92	3.02	11.98	12.36	23.07	23.86	3540	6.50	76.80	7.00	64	60
21	3.11	3.25	9.81	10.14	23.16	24.24	3345	6.70	77.30	7.00	57	56
22	3.14	3.32	8.73	9.18	24.57	25.95	3430	6.80	77.40	7.20	59	58
23	2.98	2.91	14.40	13.71	25.51	24.79	3872	5.60	79.80	7.60	72	76
24	2.89	2.90	11.26	11.10	23.45	23.45	3773	6.00	79.50	7.60	68	72
25	2.80	2.80	12.89	12.79	23.02	22.92	3934	6.00	79.30	7.60	77	72
26	2.81	2.73	17.07	16.32	25.09	24.27	4012	5.50	80.10	7.60	79	78
27	2.86	2.81	17.59	17.16	24.13	23.66	4014	5.70	79.60	7.50	78	77
28	2.82	2.74	15.42	14.85	24.93	24.14	4130	5.50	80.40	7.60	82	80
29	2.86	2.73	16.38	15.60	25.98	24.74	4311	5.20	81.20	7.80	88	87
30	2.87	2.84	15.20	15.06	26.02	25.77	4194	5.90	80.60	7.80	81	82
最大值	4.6	5.3	22.8	26.0	27.8	30.2	4311	7.8	81.2	7.8	88	87
最小值	2.4	2.4	4.5	4.7	19.9	20.7	1853	5.2	74.8	6.1	57	48
平均	3.0	3.1	12.6	12.9	23.6	24.3	3381	6.5	78.3	7.1	67	66

深圳妈湾电力有限公司2021年9月#2烟卤烟气数据

烟卤量单位 万立方米/天

#2烟卤排放口

日期	颗粒物		二氧化硫		氮氧化物		烟气量	氧量%	温度℃	湿度%	#3机组	#4机组
	标志	折算	标志	折算	标志	折算						
1	2.81	2.82	19.62	19.44	26.29	26.32	3860	6.00	77.70	5.50	68	67
2	2.75	2.81	16.70	16.88	27.00	27.56	3710	6.30	76.50	5.50	63	63
3	2.82	2.84	24.23	24.18	27.83	28.05	3816	6.10	77.40	5.60	65	65
4	2.63	2.69	19.02	19.21	24.23	24.66	3637	6.30	77.00	5.70	61	60
5	2.61	2.69	16.41	16.87	23.32	24.02	3705	6.40	76.90	5.80	64	59
6	2.60	2.67	16.49	16.76	25.86	26.53	3671	6.40	77.40	5.90	60	62
7	2.69	2.69	15.13	14.98	25.71	25.76	3668	6.00	77.40	5.90	62	60
8	2.72	2.58	18.12	16.91	24.99	23.64	3883	5.20	77.70	6.10	65	65
9	2.70	2.53	21.42	19.94	24.98	23.46	3965	5.00	78.60	6.30	68	69
10	2.70	2.55	20.80	19.60	24.83	23.41	3896	5.10	78.20	6.40	63	69
11	2.57	2.46	27.06	25.89	25.30	24.22	3839	5.30	78.30	6.40	62	62
12	2.68	2.56	28.05	26.83	25.05	23.96	3805	5.30	78.50	6.40	62	61
13	2.64	2.57	26.17	25.49	24.61	23.97	3673	5.60	77.80	6.40	55	55
14	2.45	2.39	26.62	25.93	25.13	24.50	3622	5.60	77.00	6.50	47	58
15	3.13	3.07	23.51	23.00	27.43	26.86	3610	5.70	77.10	6.50	48	55
16	3.89	3.79	27.69	27.00	23.94	23.37	3706	5.60	76.40	6.00	53	57
17	2.54	2.47	25.67	24.91	25.43	24.70	3729	5.60	76.60	5.80	53	54
18	2.66	2.65	21.56	21.40	21.82	21.73	3760	5.90	76.60	5.90	58	49
19	2.68	2.65	18.72	18.50	20.74	20.52	3673	5.80	75.50	5.90	55	48
20	2.61	2.54	28.25	27.43	23.88	23.19	3690	5.60	77.60	6.10	53	56
21	2.61	2.57	22.29	21.85	23.89	23.47	3641	5.70	77.50	6.00	51	52
22	2.57	2.52	23.28	22.78	24.09	23.63	3719	5.70	77.70	6.20	53	56
23	2.38	2.26	26.10	24.63	24.91	23.59	3921	5.20	78.20	6.50	67	63
24	2.41	2.28	26.33	24.84	26.37	25.00	3910	5.20	78.70	6.50	67	62
25	2.34	2.19	28.36	26.53	26.28	24.58	4019	5.00	79.10	6.60	70	70
26	2.45	2.26	23.83	21.86	27.50	25.35	4068	4.70	79.70	6.70	72	72
27	2.77	2.54	20.93	19.02	28.54	26.15	4149	4.60	78.70	6.80	78	75
28	2.82	2.56	24.14	21.78	28.37	25.74	4189	4.50	80.40	6.90	80	80
29	2.82	2.53	27.82	24.94	28.83	25.83	4314	4.30	80.90	7.00	87	84
30	2.80	2.52	26.75	24.06	29.53	26.55	4258	4.30	80.70	6.80	85	82
最大值	3.9	3.8	28.4	27.4	29.5	28.1	4314	6.4	80.9	7.0	87	84
最小值	2.3	2.2	15.1	15.0	20.7	20.5	3610	4.3	75.5	5.5	47	48
平均	2.7	2.6	23.0	22.1	25.6	24.7	3837	5.5	77.9	6.2	63	63

深圳妈湾电力有限公司2021年9月#3烟卤烟气数据

浓度单位 (mg/m³) 烟气量单位 万立方米/天

日期	颗粒物		二氧化硫		氮氧化物		烟气量	氧量%	温度℃	湿度%	#5机组	#6机组
	标志	折算	标志	折算	标志	折算						
1	2.97	3.03	19.08	19.17	21.44	21.87	4095	6.30	76.30	5.30	73	71
2	2.82	2.91	9.34	9.49	22.39	22.99	4058	6.40	75.90	5.20	70	72
3	2.80	2.84	15.65	15.53	23.07	23.29	4106	6.10	77.60	5.30	74	72
4	2.67	2.72	17.61	17.58	22.76	23.22	4019	6.20	77.00	5.40	71	71
5	2.55	2.56	8.84	8.87	21.20	21.33	4181	6.10	77.20	5.60	70	78
6	2.55	2.66	7.03	7.23	23.82	24.71	3994	6.60	76.70	5.70	69	68
7	2.67	2.75	8.18	8.29	23.74	24.40	3962	6.40	77.40	5.70	67	71
8	3.08	3.12	12.64	12.50	22.33	22.59	3883	6.10	77.30	5.80	67	67
9	2.75	2.62	14.40	13.62	21.90	20.87	4062	5.20	77.40	5.90	72	72
10	2.71	2.56	17.06	16.15	20.82	19.73	4196	5.10	78.00	6.00	72	79
11	2.82	2.68	26.65	25.33	26.26	24.96	4130	5.20	78.70	6.20	77	69
12	2.93	2.81	28.94	27.77	25.78	24.73	3978	5.40	78.60	6.00	69	69
13	2.89	2.76	27.54	26.21	26.61	25.36	4131	5.30	79.30	6.20	74	71
14	2.77	2.63	27.93	26.49	26.41	25.08	4179	5.20	78.00	6.30	77	72
15	2.77	2.63	30.04	28.50	22.35	21.21	4169	5.20	78.40	6.20	75	73
16	2.75	2.62	31.75	30.26	25.42	24.22	4087	5.30	77.10	6.00	72	72
17	2.71	2.58	28.32	26.96	23.34	22.23	4139	5.20	76.90	5.90	73	73
18	2.89	2.87	21.53	21.13	21.37	21.04	3569	5.80	77.20	5.70	21: 16机组停运	67
19	4.74	4.93	23.76	24.66	19.10	19.87	2185	6.60	75.30	5.60	机组停运	67
20	3.79	4.12	25.12	27.29	17.31	18.85	2182	7.20	74.60	5.50	机组停运	63
21	3.42	3.78	22.80	24.79	21.03	22.99	1880	7.30	74.10	5.50	机组停运	52
22	2.88	3.04	25.72	27.06	19.60	20.65	1918	6.70	75.00	5.70	机组停运	57
23	2.74	2.90	26.17	27.53	18.41	19.49	1954	6.80	73.60	5.60	机组停运	58
24	2.77	2.81	24.41	24.66	18.90	19.15	1993	6.20	76.80	5.80	机组停运	63
25	2.87	2.90	23.27	23.45	19.54	19.69	2169	6.10	75.70	5.90	机组停运	68
26	3.33	3.72	19.27	20.58	23.84	25.90	3565	7.10	76.90	6.00	10: 03井网发电	23: 00机组停运
27	3.54	3.92	21.32	23.24	19.01	20.62	2482	7.20	75.70	6.00	74	机组停运
28	3.78	4.50	18.38	21.38	19.47	22.88	2889	8.30	71.00	5.70	82	机组停运
29	3.42	3.90	22.61	25.73	21.00	23.91	3041	7.80	71.90	6.00	90	机组停运
30	3.18	3.43	25.47	26.77	21.92	23.37	2660	6.90	73.90	6.00	84	机组停运
最大值	4.7	4.9	31.8	30.3	26.6	25.9	4196	8.3	79.3	6.3	90	79
最小值	2.6	2.6	7.0	7.2	17.3	18.9	1880	5.1	71.0	5.2	67	52
平均	3.0	3.1	21.0	21.3	22.0	22.4	3395	6.2	76.3	5.8	74	69