

深圳妈湾电力有限公司2021年10月#1烟卤烟气数据

浓度单位 (mg/m³) 烟气量单位 万立方米/天

日期	颗粒物		二氧化硫		氮氧化物		烟气量	氧量%	温度℃	湿度%	机组负荷率 (%)	
	标志	折算	标志	折算	标志	折算					#1机组	#2机组
1	2.9	3.1	14.9	15.2	23.1	24.1	3561	6.6	79.4	7.4	67	63
2	2.8	3.0	8.3	8.6	21.9	23.0	3383	6.7	78.3	7.4	60	59
3	2.8	2.9	4.9	5.1	22.5	23.6	3160	6.7	76.9	7.4	56	55
4	2.9	3.0	7.5	7.7	23.4	24.3	3350	6.6	78.1	7.5	60	60
5	2.8	2.9	11.1	11.2	24.2	24.6	3737	6.2	79.0	7.7	71	71
6	2.8	2.8	12.2	12.0	23.9	23.9	3643	6.1	78.5	7.5	67	71
7	2.9	2.9	13.6	13.6	23.8	24.0	3559	6.2	78.4	7.5	68	66
8	2.7	2.8	8.8	8.8	24.1	24.4	3464	6.2	74.6	7.1	65	62
9	2.7	2.8	7.8	8.1	24.0	25.1	3254	6.6	73.5	6.8	57	55
10	2.6	2.8	9.7	10.2	24.7	25.8	3374	6.6	75.0	6.8	56	61
11	3.0	2.9	17.4	17.0	26.1	25.8	3858	5.9	77.9	7.1	70	75
12	2.8	2.9	6.6	6.7	23.1	23.7	3509	6.4	75.5	6.6	64	64
13	2.9	3.0	8.8	9.0	24.4	25.1	3457	6.4	74.1	6.2	60	61
14	3.0	2.9	18.2	17.7	26.6	25.9	4263	5.6	78.9	6.9	83	83
15	2.8	2.8	7.2	7.3	22.8	23.0	3651	6.2	76.7	6.5	64	70
16	2.9	3.0	8.3	8.6	21.9	22.8	3498	6.6	76.0	6.3	61	61
17	2.8	3.0	11.2	11.3	21.7	22.5	3621	6.5	75.9	6.1	62	66
18	2.9	3.0	8.9	9.1	22.6	23.3	3659	6.5	75.4	5.9	62	66
19	2.9	3.0	7.7	8.1	22.0	23.2	3443	6.7	75.1	5.9	59	58
20	2.9	3.0	13.6	13.7	23.3	23.9	3643	6.4	76.6	6.2	65	66
21	2.8	3.0	5.4	5.7	21.2	22.2	3049	6.7	73.6	5.8	51	51
22	3.0	3.1	4.9	5.1	21.5	22.5	3084	6.7	72.3	5.3	52	51
23	3.1	3.3	8.7	8.8	22.7	23.5	3436	6.6	72.7	5.2	57	58
24	3.1	3.3	7.2	7.8	21.6	23.3	3233	7.1	72.2	5.0	52	53
25	3.0	3.3	4.9	5.3	21.8	23.9	3164	7.3	72.0	5.0	49	50
26	3.0	3.2	9.5	10.1	22.4	24.1	3266	7.0	73.4	5.4	53	53
27	3.1	3.3	15.5	16.0	24.4	25.5	3506	6.7	75.6	5.7	60	60
28	3.2	3.4	12.8	13.3	23.6	25.3	3547	7.0	75.7	5.5	59	59
29	3.2	3.3	13.0	13.5	24.1	25.2	3573	6.7	76.0	5.9	61	60
30	3.0	3.2	10.7	11.1	23.3	24.5	3435	6.8	74.8	5.7	57	58
31	3.0	3.2	6.8	7.3	23.2	24.8	3002	6.9	73.4	5.4	48	49
最大值	3.2	3.4	18.2	17.7	26.6	25.9	4263	7.3	79.4	7.7	83	83
最小值	2.6	2.8	4.9	5.1	21.2	22.2	3002	5.6	72.0	5.0	48	49
平均	2.9	3.0	9.9	10.1	23.2	24.1	3464	6.6	75.7	6.3	60	61

深圳妈湾电力有限公司2021年10月#2烟囱烟气数据

浓度单位: (mg/m³) 烟气量单位: 万立方米/天

日期	颗粒物		二氧化硫		氮氧化物		烟气量	氧量%	温度℃	湿度%	机组负荷率 (%)	
	标志	折算	标志	折算	标志	折算					#3机组	#4机组
1	3.0	2.9	22.2	21.1	25.6	24.6	3853	5.4	78.9	6.5	66	60
2	3.0	2.9	18.6	17.9	25.6	24.8	3784	5.5	78.1	6.5	62	56
3	2.8	2.7	19.2	18.6	26.0	25.2	3784	5.5	76.6	6.5	59	57
4	2.9	2.8	21.4	20.7	26.7	26.0	3711	5.5	77.4	6.5	58	53
5	2.7	2.6	21.4	20.8	26.5	25.7	3816	5.5	76.7	6.6	64	56
6	2.7	2.6	23.8	22.7	25.2	24.1	3792	5.3	76.6	6.6	65	54
7	2.6	2.5	27.3	26.3	25.0	24.1	3656	5.4	75.9	6.3	57	52
8	2.5	2.4	21.7	20.8	26.6	25.5	3804	5.4	72.5	6.4	63	56
9	2.4	2.5	21.8	22.0	25.3	25.4	3634	6.1	71.3	5.9	54	21: 46机组停运
10	3.2	3.4	18.8	20.0	24.1	25.6	3127	6.9	68.2	5.9	54	机组停运
11	3.9	4.1	19.1	20.0	21.4	22.4	2973	6.6	70.4	5.9	69	机组停运
12	4.2	5.2	12.9	15.3	22.8	28.0	2456	8.4	66.7	5.4	57	机组停运
13	3.0	3.4	16.9	18.6	18.4	20.5	2119	7.4	66.7	5.4	49	机组停运
14	2.7	3.0	11.0	11.9	21.5	23.3	2100	7.1	69.2	5.6	49	机组停运
15	2.9	3.2	17.0	18.0	21.1	22.6	2681	6.9	72.7	6.0	82	23: 10并网发电
16	2.8	2.8	21.7	21.1	26.3	25.7	3147	5.6	74.6	5.7	62	56
17	2.6	2.6	23.6	22.8	26.9	26.0	3104	5.5	73.8	5.6	58	59
18	2.8	2.7	17.3	16.4	27.6	26.3	3753	5.3	74.3	5.6	64	65
19	2.8	2.8	15.8	15.6	26.7	26.4	3503	5.8	73.0	5.2	50	53
20	2.9	2.8	20.4	19.9	25.8	25.2	3580	5.7	74.3	5.4	59	55
21	2.8	2.8	16.8	16.9	24.9	25.0	3346	6.1	72.6	5.1	48	48
22	2.7	2.7	13.3	13.4	25.3	25.6	3354	6.2	71.9	5.0	49	49
23	2.8	3.0	18.5	19.6	22.6	24.0	2513	6.9	69.6	5.0	56	0: 04机组停运
24	2.9	3.1	18.1	19.7	23.2	25.2	2457	7.2	68.4	4.7	45	机组停运
25	2.9	3.3	13.1	14.9	22.4	25.8	2955	7.7	68.7	4.4	46	14: 55并网发电
26	2.9	2.9	21.4	21.3	23.8	23.8	3378	6.0	74.1	4.7	48	49
27	2.8	2.7	22.7	22.2	25.2	24.7	3587	5.7	75.0	5.0	54	57
28	2.8	2.8	19.3	18.9	23.4	23.1	3546	5.8	76.2	5.0	55	53
29	2.9	2.8	18.3	17.8	23.7	23.1	3649	5.6	76.7	5.1	55	61
30	2.8	2.8	16.3	16.0	23.3	23.0	3604	5.8	75.3	4.9	55	56
31	2.8	2.9	14.5	14.7	24.4	24.7	3315	6.1	73.6	4.7	46	46
最大值	4.2	5.2	27.3	26.3	27.6	28.0	3853	8.4	78.9	6.6	82	65
最小值	2.4	2.4	11.0	11.9	18.4	20.5	2100	5.3	66.7	4.4	45	46
平均	2.9	2.9	18.8	18.9	24.4	24.7	3293	6.1	73.2	5.6	57	55

深圳妈湾电力有限公司2021年10月#3烟肉烟气数据

浓度单位: mg/m³ 流量单位: 万立方米/天

#3烟肉排放口

日期	颗粒物		二氧化硫		氮氧化物		烟气量	氧量%	温度℃	湿度%	#5机组	#6机组
	标志	折算	标志	折算	标志	折算						
1	3.3	3.3	19.5	19.4	23.6	23.9	1981	6.2	74.9	5.9	63	#6机组
2	3.6	4.0	12.8	14.6	22.0	24.5	2955	7.5	73.1	5.6	63	机组停运
3	3.2	3.2	17.7	17.4	19.1	18.9	3597	5.9	75.6	6.1	61	15: 16并网发电
4	3.3	3.2	18.4	17.8	21.5	21.1	3672	5.7	76.2	6.1	59	53
5	3.3	3.1	25.0	23.8	22.5	21.7	4101	5.4	78.1	6.3	66	59
6	3.3	3.2	23.1	22.0	23.4	22.6	4072	5.5	77.7	6.3	66	73
7	3.1	3.0	21.9	21.1	21.6	21.0	3915	5.5	76.6	6.2	66	69
8	3.1	3.0	19.5	18.7	25.3	24.6	3821	5.6	72.2	6.0	64	65
9	3.0	2.9	20.9	20.0	26.2	25.3	3864	5.5	72.9	6.0	61	62
10	3.0	2.9	20.7	20.0	23.7	23.1	3818	5.6	73.5	5.8	63	68
11	3.0	2.9	23.6	22.5	23.1	22.5	3801	5.5	74.8	5.7	63	63
12	2.9	2.8	22.0	21.1	21.4	20.7	3802	5.5	73.5	5.6	64	63
13	2.7	2.6	25.2	24.1	24.0	23.1	3927	5.4	73.2	5.5	68	64
14	2.8	2.7	31.9	30.0	23.8	22.3	4546	5.1	76.6	5.9	79	79
15	2.6	2.5	25.9	24.6	24.7	23.6	4180	5.3	75.0	5.7	71	74
16	2.8	2.7	24.2	23.6	23.5	23.1	3682	5.7	74.5	5.4	64	22: 46机组停运
17	2.9	2.9	16.6	16.6	21.3	21.7	2123	6.3	71.7	5.2	66	机组停运
18	2.9	3.4	14.7	16.5	20.4	23.6	2487	8.0	67.2	4.8	68	机组停运
19	3.1	3.6	14.4	15.2	21.0	23.5	2292	7.5	67.7	4.8	65	机组停运
20	2.7	2.9	15.1	16.4	21.8	24.2	2143	7.4	67.7	4.8	61	机组停运
21	2.6	3.1	9.3	11.1	20.8	25.0	1999	8.5	63.3	4.4	50	机组停运
22	2.5	3.1	8.3	10.2	22.3	27.4	2044	8.8	58.9	3.9	49	机组停运
23	2.5	3.3	10.4	12.8	21.1	27.1	2380	9.3	57.3	3.6	55	机组停运
24	2.4	3.5	5.3	7.6	17.8	25.8	2437	10.6	54.3	3.2	48	机组停运
25	2.4	3.4	6.1	8.7	17.3	25.1	2440	10.6	54.8	3.2	48	机组停运
26	2.6	3.7	8.6	11.7	15.1	21.1	2420	10.2	58.0	3.4	51	机组停运
27	3.0	3.9	13.6	17.1	16.9	21.9	2606	9.5	61.5	3.9	62	机组停运
28	2.9	3.9	12.2	15.3	18.6	24.5	2566	9.6	60.6	3.8	60	机组停运
29	2.7	3.4	14.9	18.5	18.2	23.2	2679	9.3	61.3	3.9	65	机组停运
30	2.7	3.6	9.8	12.9	16.5	22.1	2563	9.8	59.2	3.7	58	机组停运
31	2.5	3.6	6.4	9.2	16.9	24.2	2308	10.5	58.1	3.4	46	机组停运
最大值	3.6	4.0	31.9	30.0	26.2	27.4	4546	10.6	78.1	6.3	79	79
最小值	2.4	2.5	5.3	7.6	15.1	18.9	1981	5.1	54.3	3.2	46	53
平均	2.9	3.2	16.7	17.4	21.1	23.3	3072	7.3	68.4	5.0	61	66