

深圳妈湾电力有限公司2021年11月#1烟囱烟气数据

浓度单位：mg/m³ 流量单位：万立方米/天

日期	颗粒物		二氧化硫		氮氧化物		氧量%	温度℃	湿度%	#1机组	#2机组	
	标志	折算	标志	折算	标志	折算						
1	3.04	3.42	7.45	8.36	20.99	22.73	1668	7.60	72.30	5.20	49	1: 18机组停运
2	3.21	3.47	13.61	14.49	21.02	22.73	1899	7.10	74.50	5.70	64	机组停运
3	3.28	4.09	7.02	7.81	21.22	25.53	3305	8.40	71.00	5.40	59	7: 14并网发电
4	3.26	3.45	6.36	6.67	21.93	23.15	3067	6.80	72.90	5.60	50	54
5	3.24	3.32	9.86	9.78	23.06	23.42	3633	6.30	76.00	5.90	67	67
6	3.10	3.33	13.49	14.47	21.24	22.84	3383	7.00	75.70	6.20	65	52
7	3.85	4.09	13.28	14.05	21.59	22.75	2067	6.80	77.10	6.40	72	0: 38机组停运
8	3.88	4.43	6.32	7.15	19.66	22.40	1994	7.80	70.00	5.30	64	机组停运
9	3.55	3.90	8.70	9.39	20.21	22.13	2284	7.30	70.60	4.90	76	机组停运
10	3.59	3.81	8.75	9.24	21.82	23.13	2344	6.90	72.60	4.80	81	机组停运
11	3.96	4.07	9.86	9.91	22.64	23.11	2219	6.30	74.50	4.70	81	机组停运
12	4.00	3.96	14.92	14.65	23.95	23.70	2165	5.90	76.50	4.80	81	机组停运
13	4.07	3.96	23.17	22.49	24.98	24.27	2181	5.60	74.70	5.00	83	机组停运
14	4.04	4.17	20.47	21.14	23.25	23.93	2263	6.40	73.40	4.70	80	机组停运
15	3.80	4.09	16.35	17.52	22.27	23.94	2279	7.10	70.00	4.50	77	机组停运
16	3.81	4.22	12.46	13.70	19.99	22.13	2213	7.50	69.60	4.40	72	机组停运
17	3.62	3.90	12.88	13.65	21.35	23.07	2255	7.10	70.00	4.60	76	机组停运
18	3.93	4.18	13.97	14.71	21.00	22.40	2215	7.00	69.80	4.70	75	机组停运
19	4.01	4.23	15.39	15.95	22.95	24.26	2192	6.90	70.70	4.80	75	机组停运
20	3.91	3.94	14.12	14.20	24.14	24.21	2301	6.10	73.30	5.30	86	机组停运
21	3.73	3.81	15.78	16.10	23.63	24.06	2245	6.30	72.90	5.20	83	机组停运
22	3.38	3.48	15.71	16.03	22.63	23.24	2263	6.40	71.20	4.90	80	机组停运
23	3.13	3.30	12.83	13.33	22.35	23.28	2211	6.60	69.40	4.40	76	机组停运
24	3.12	3.11	13.81	13.65	24.54	24.39	2083	5.90	72.40	4.50	77	机组停运
25	3.24	3.35	12.46	12.58	23.01	23.53	2181	6.40	72.80	4.70	78	机组停运
26	3.44	4.35	8.87	11.00	21.62	27.08	3178	8.90	67.20	4.30	75	18: 40并网发电
27	3.17	3.11	6.99	6.87	20.09	19.75	3920	5.70	73.50	4.90	72	78
28	3.30	3.20	7.84	7.60	20.18	19.58	4067	5.50	73.60	5.00	77	81
29	3.13	3.15	7.75	7.82	20.89	21.03	3979	6.10	73.60	4.80	73	74
30	3.11	3.08	8.24	8.16	21.20	20.98	4053	5.80	74.10	5.00	75	78
最大值	4.1	4.4	23.2	22.5	25.0	27.1	4067	8.9	77.1	6.4	86	81
最小值	3.0	3.1	6.3	6.7	19.7	19.6	1668	5.5	67.2	4.3	49	52
平均	3.5	3.7	12.0	12.4	22.0	23.1	2604	6.7	72.5	5.0	73	69

#1烟囱排放口

机组负荷率 (%)

深圳妈湾电力有限公司2021年11月#2烟囱烟气数据

浓度单位 (mg/m³) 流量单位 (万立方米/天)

#2烟囱排放口

日期	颗粒物		二氧化硫		氮氧化物		烟气量	氧含量%	温度℃	湿度%	#3机组	#4机组
	标志	折算	标志	折算	标志	折算						
1	2.90	2.94	17.44	17.70	23.73	24.07	3875	6.20	74.30	4.80	47	48
2	2.82	2.72	17.15	16.35	26.50	25.41	3745	5.40	76.00	5.20	60	63
3	2.70	2.63	12.89	12.47	22.66	22.06	3443	5.60	74.00	5.10	56	59
4	3.06	3.12	13.54	13.73	22.80	23.25	3052	6.30	72.70	4.90	51	49
5	3.45	3.48	19.13	18.84	26.42	26.37	1920	6.00	75.50	5.30	0:19机组停运	71
6	2.57	2.70	21.30	22.34	23.92	25.16	1751	6.70	72.60	4.90	机组停运	63
7	4.05	4.02	18.20	18.03	28.21	27.98	1885	5.90	75.30	5.30	机组停运	72
8	2.78	3.09	13.56	14.06	23.51	26.42	3284	7.10	67.30	5.00	5:53并网发电	62
9	2.98	2.82	19.25	18.15	23.64	22.35	4079	5.20	73.50	5.40	74	76
10	3.00	2.93	15.53	15.00	24.96	24.21	3790	5.50	73.70	5.00	22:38机组停运	81
11	3.44	3.60	14.39	14.97	23.54	24.54	2207	6.60	70.20	4.80	机组停运	78
12	3.01	3.21	21.41	22.81	22.71	24.19	2238	6.90	69.10	4.70	78	机组停运
13	3.32	3.47	25.02	25.88	22.55	23.66	3433	6.50	71.10	4.80	81	7:05并网发电
14	3.34	3.07	29.21	26.85	24.84	22.84	4179	4.70	76.10	5.00	80	79
15	3.23	3.01	30.59	28.51	26.44	24.65	4127	4.90	75.40	4.90	78	78
16	3.10	2.92	25.27	23.76	27.66	26.04	3927	5.10	74.40	4.70	75	74
17	3.15	2.94	22.63	21.07	28.59	26.70	4123	5.00	73.90	4.80	80	79
18	2.99	2.78	26.60	24.70	27.83	25.96	4090	4.90	73.60	4.80	78	78
19	3.07	2.87	25.88	24.06	27.69	25.88	4043	5.00	75.00	4.90	78	78
20	3.14	2.89	20.28	18.65	29.20	26.86	4427	4.70	75.00	5.20	86	87
21	2.97	2.77	23.44	21.86	29.47	27.49	4364	4.90	74.60	5.10	85	85
22	2.88	2.70	27.23	25.51	28.59	26.84	4224	5.00	73.10	4.90	80	81
23	2.77	2.62	22.33	21.11	29.00	27.47	3994	5.20	71.10	4.50	75	75
24	2.80	2.62	24.06	22.49	29.06	27.26	4097	5.00	72.80	4.50	78	78
25	2.79	2.60	15.56	14.41	24.73	23.01	4187	4.90	74.60	4.60	79	79
26	2.84	2.70	20.91	19.84	24.31	23.08	3971	5.20	73.30	4.30	74	73
27	2.82	2.68	15.62	14.85	21.12	20.10	4006	5.20	73.70	4.40	74	74
28	2.90	2.71	17.66	16.53	22.38	20.94	4107	5.00	73.30	4.40	78	78
29	2.84	2.73	22.11	21.13	20.36	19.52	4161	5.40	73.70	4.40	73	74
30	2.78	2.66	20.68	19.74	19.30	18.43	4327	5.30	73.20	4.40	74	75
最大值	4.1	4.0	30.6	28.5	29.5	28.0	4427	7.1	76.1	5.4	86	87
最小值	2.6	2.6	12.9	12.5	19.3	18.4	1751	4.7	67.3	4.3	47	48
平均	3.0	2.9	20.6	19.8	25.2	24.4	3619	5.5	73.4	4.8	74	73

深圳妈湾电力有限公司2021年11月#3烟囱烟气数据

浓度单位 (mg/m³) 流量单位 (万立方米/天)

#3烟囱排放口

日期	颗粒物		二氧化硫		氮氧化物		烟气量	氨量%	温度℃	湿度%	机组负荷率 (%)	
	标志	折算	标志	折算	标志	折算					#5机组	#6机组
1	2.67	3.52	8.10	10.53	19.25	25.24	2123	9.60	61.30	3.70	49	机组停运
2	2.95	3.31	21.05	23.27	22.00	24.64	2204	7.70	68.00	4.30	63	机组停运
3	2.68	2.97	14.51	15.73	22.75	25.25	2038	7.50	67.10	4.30	61	机组停运
4	2.60	2.92	10.62	11.81	21.74	24.43	1867	7.60	67.10	4.10	51	机组停运
5	2.53	2.62	20.03	20.53	21.55	22.36	2386	6.50	70.80	4.80	75	机组停运
6	2.47	2.58	18.84	19.61	20.97	21.92	2153	6.60	68.90	4.60	66	机组停运
7	2.61	2.60	22.77	22.63	22.59	22.44	2258	5.90	71.80	4.90	74	机组停运
8	3.24	3.35	17.47	17.34	22.69	22.62	2087	6.00	68.10	4.70	65	机组停运
9	2.57	2.88	13.06	13.87	21.24	23.16	1970	7.30	64.40	4.10	53	机组停运
10	2.87	3.29	14.54	16.30	30.37	33.58	3671	7.80	66.50	4.30	75	14: 45并网发电
11	2.61	2.43	16.28	15.08	26.82	24.92	4486	4.90	71.70	4.80	78	81
12	2.68	2.50	23.68	21.86	26.23	24.35	4539	4.80	73.10	4.80	78	84
13	2.65	2.48	20.53	19.23	25.66	24.05	4307	5.00	71.90	4.60	65	84
14	2.72	2.55	18.18	17.04	25.87	24.23	4252	5.00	72.30	4.60	64	83
15	2.71	2.53	21.08	19.68	23.56	22.03	4372	5.00	72.00	4.60	78	78
16	2.74	2.58	19.03	17.81	22.87	21.50	4206	5.00	71.90	4.40	75	73
17	2.78	2.59	20.05	18.54	24.70	22.97	4470	4.90	73.00	4.70	81	80
18	2.66	2.48	20.47	19.03	24.56	22.94	4431	4.90	72.40	4.60	79	79
19	2.75	2.55	22.83	21.03	23.82	22.04	4416	4.80	73.90	4.60	79	80
20	2.79	2.57	24.52	22.56	26.76	24.65	4861	4.70	74.90	4.80	88	89
21	2.76	2.55	25.32	23.34	25.47	23.50	4728	4.70	74.30	4.70	86	87
22	2.63	2.45	21.62	20.05	25.29	23.50	4591	4.90	72.20	4.70	82	83
23	2.62	2.47	16.81	15.76	24.85	23.36	4115	5.00	69.20	4.20	77	67
24	2.81	2.64	14.63	13.65	23.31	21.84	4088	5.00	70.30	3.90	79	64
25	2.71	2.52	20.85	19.24	24.84	23.02	4553	4.80	72.80	4.10	81	82
26	2.73	2.54	16.54	15.40	21.39	19.92	4252	4.90	71.60	3.90	75	76
27	2.73	2.55	12.77	11.90	19.44	18.12	4251	4.90	72.10	4.00	74	76
28	2.81	2.60	21.23	19.65	21.19	19.61	4460	4.80	72.10	4.10	79	80
29	2.77	2.57	20.16	18.63	16.84	15.65	4231	4.80	71.70	4.00	74	76
30	2.64	2.46	22.54	20.98	18.50	17.20	4355	4.90	71.40	4.10	77	78
最大值	3.2	3.5	25.3	23.3	30.4	33.6	4861	9.6	74.9	4.9	88	89
最小值	2.5	2.4	8.1	10.5	16.8	15.7	1867	4.7	61.3	3.7	49	64
平均	2.7	2.7	18.7	18.1	23.2	22.8	3691	5.7	70.6	4.4	73	79