

深圳妈湾电力有限公司2022年2月#1烟囱烟气数据

浓度单位: (mg/m³)

烟气量单位: 万立方米/天

日期	颗粒物		二氧化硫		氮氧化物		烟气量	氧量%	温度℃	湿度%	#1机组	#2机组
	标志	折算	标志	折算	标志	折算						
1	3.2	3.4	3.9	4.3	22.7	24.8	3368	7.3	68.2	3.2	机组停运	60
2	3.5	3.9	5.6	6.1	20.2	22.3	2065	7.4	68.5	3.6	机组停运	48
3	3.9	4.0	9.1	9.2	21.0	21.2	2425	6.2	71.5	4.0	机组停运	52
4	4.3	4.6	6.6	6.8	18.5	19.2	2402	6.6	70.2	3.8	机组停运	48
5	4.5	4.8	6.9	7.2	21.9	23.2	4334	6.7	70.0	3.9	机组停运	53
6	4.1	4.2	4.7	4.8	19.4	20.0	3970	6.4	70.7	3.9	机组停运	51
7	3.8	3.8	4.5	4.6	19.8	20.2	4063	6.3	70.6	4.0	机组停运	51
8	3.2	3.3	4.2	4.3	20.5	21.1	3814	6.5	70.2	3.9	机组停运	49
9	3.1	3.2	4.0	4.2	20.5	21.1	3807	6.4	70.5	3.9	机组停运	52
10	3.3	3.3	4.9	4.9	20.4	20.6	4111	6.2	70.9	3.7	机组停运	51
11	3.4	3.4	3.7	3.7	20.8	20.9	4081	6.1	71.4	4.0	机组停运	53
12	3.6	3.5	5.4	5.3	21.8	21.5	4385	5.9	72.1	3.9	机组停运	50
13	4.0	4.0	4.8	4.7	21.3	21.1	4423	5.8	73.0	4.0	机组停运	62
14	4.6	4.5	3.9	3.8	24.2	23.7	4584	5.7	73.8	4.3	机组停运	57
15	4.3	4.2	4.6	4.6	24.7	24.3	4480	5.7	74.8	4.3	机组停运	54
16	4.2	4.2	6.4	6.3	23.3	23.1	4334	5.9	72.9	4.1	机组停运	66
17	4.1	4.1	6.0	6.0	23.1	23.1	4202	6.0	72.1	4.1	机组停运	65
18	3.8	3.8	4.8	4.8	22.5	23.0	4003	6.2	70.2	3.9	17:44机组并网	63
19	3.6	3.8	4.3	4.4	22.5	23.4	3798	6.5	69.0	3.6	56	56
20	3.9	4.1	3.6	3.8	24.4	25.7	3651	6.7	68.4	3.5	53	54
21	4.3	4.3	4.5	4.5	25.5	25.6	3922	6.1	70.0	3.6	67	67
22	3.9	4.0	4.9	5.0	25.1	25.5	3848	6.3	68.7	3.8	73	73
23	3.9	3.8	5.4	5.3	26.2	26.2	4245	6.0	69.1	4.2	67	66
24	3.9	3.9	5.8	5.7	27.4	26.9	3443	5.8	71.7	4.4	69	71
25	4.1	4.1	3.7	3.7	24.1	24.3	2142	6.2	69.5	3.7	55	56
26	4.0	4.2	3.4	3.6	22.8	24.0	2063	6.8	68.4	3.5	61	55
27	3.5	3.7	3.4	3.6	21.8	23.5	1916	7.0	67.5	3.5	53	51
28	3.5	3.7	3.0	3.1	22.2	23.3	1811	6.7	68.5	3.6	62	53
最大值	4.6	4.8	9.1	9.2	27.4	26.9	4584	7.4	74.8	4.4	73	73
最小值	3.1	3.2	3.0	3.1	18.5	19.2	1811	5.7	67.5	3.2	53	48
平均	3.8	3.9	4.9	4.9	22.4	23.0	3560	6.3	70.4	3.9	61	57

深圳妈湾电力有限公司2022年2月#2烟卤烟气数据

浓度单位: (mg/m³)

烟量单位: 万立方米/天

日期	颗粒物		二氧化硫		氮氧化物		烟气量	氧量%	温度℃	湿度%	机组负荷率 (%)	
	标志	折算	标志	折算	标志	折算					#3机组	#4机组
1	2.8	2.9	9.5	9.8	18.9	19.5	3058	6.4	66.6	3.0	机组停运	机组停运
2	2.7	2.7	12.6	12.5	21.3	21.2	3410	5.9	67.5	3.2	机组停运	机组停运
3	2.7	2.5	21.7	19.8	24.3	22.2	4538	4.7	71.4	3.6	机组停运	机组停运
4	2.7	2.5	16.4	15.1	24.0	22.2	4574	4.8	72.1	3.6	14:37机组并网	5日0:53机组并网
5	2.9	2.7	23.3	21.5	24.6	22.7	4588	4.8	72.9	3.7	46	44
6	2.6	2.6	15.0	14.4	19.6	19.2	3827	5.5	69.8	3.4	46	46
7	2.7	2.5	20.5	19.1	22.1	20.8	4022	5.0	71.0	3.6	50	46
8	2.6	2.5	20.1	19.1	20.8	20.0	3857	5.4	70.8	3.6	50	1:28机组停运
9	3.7	3.8	15.6	15.6	20.4	20.5	1935	6.0	72.0	3.4	55	机组停运
10	3.5	3.8	14.8	15.5	19.6	20.5	2276	6.8	66.5	3.4	55	机组停运
11	3.5	3.6	13.4	13.3	19.2	19.4	2047	6.2	65.1	3.2	55	机组停运
12	3.1	3.2	17.8	18.1	26.3	26.9	2330	6.5	63.5	3.1	61	机组停运
13	3.6	3.7	16.2	16.8	26.7	27.7	2309	6.6	65.7	3.1	69	机组停运
14	3.9	4.0	9.8	10.0	23.5	24.1	2405	6.3	66.1	3.1	67	机组停运
15	3.2	3.2	15.9	15.6	25.4	25.0	2309	5.8	67.3	3.0	61	机组停运
16	2.8	2.8	15.0	14.8	23.4	23.2	2132	5.9	68.0	3.1	71	机组停运
17	2.8	2.8	14.0	14.0	24.7	24.8	2118	6.1	67.3	3.1	71	机组停运
18	2.8	2.9	13.4	13.7	25.7	26.5	1970	6.5	65.8	3.1	69	机组停运
19	3.0	3.1	10.8	11.2	22.7	23.7	1794	6.7	64.5	3.0	72	机组停运
20	2.9	3.1	8.3	8.7	26.5	28.1	1672	6.9	63.9	2.8	68	机组停运
21											73	机组停运
22											78	机组停运
23											78	机组停运
24											78	机组停运
25											68	机组停运
26											70	机组停运
27											56	机组停运
28											67	机组停运
最大值	3.9	4.0	23.3	21.5	26.7	28.1	4588	6.9	72.9	3.7	78	46
最小值	2.6	2.5	8.3	8.7	18.9	19.2	1672	4.7	63.5	2.8	46	44
平均	3.0	3.0	15.2	14.9	23.0	22.9	2859	5.9	67.9	3.3	64	45

#3、#4机组停运

深圳妈湾电力有限公司2022年2月#3烟卤烟气数据

烟卤量单位 万立方米/天

#3烟卤排放口

日期	颗粒物		二氧化硫		氮氧化物		烟气量	氧量%	温度℃	湿度%	#5机组	#6机组
	标志	折算	标志	折算	标志	折算						
1	2.7	2.6	6.1	6.1	28.0	22.9	3257	5.9	65.5	2.7	62	62
2	2.5	2.5	5.9	5.8	21.2	21.2	2033	5.9	66.5	2.7	51	50
3	2.2	2.1	15.7	14.8	23.6	22.4	2467	5.2	67.6	3.0	54	53
4	2.4	2.4	11.7	11.4	24.5	24.5	4267	5.9	67.0	3.1	48	49
5	2.3	2.1	13.3	12.3	24.2	22.4	4622	4.8	70.4	3.4	54	53
6	2.3	2.2	7.6	7.2	22.4	21.3	3947	5.2	68.1	3.2	51	50
7	2.3	2.2	9.9	9.2	21.8	20.4	4197	4.9	68.5	3.1	51	50
8	2.2	2.0	8.7	8.1	21.9	20.5	4248	4.9	68.5	3.2	53	48
9	2.1	2.0	9.4	8.8	21.2	20.0	4091	5.1	68.6	3.2	59	53
10	2.1	1.9	11.8	11.0	22.4	21.0	4331	5.0	69.9	3.3	58	54
11	2.0	1.9	11.1	10.4	22.4	21.0	4314	5.0	68.4	3.2	58	52
12	2.1	1.9	13.1	12.0	23.2	21.3	4540	4.7	69.7	3.3	64	53
13	2.1	2.0	9.5	8.7	23.0	21.3	4394	4.8	68.4	3.2	72	67
14	2.6	2.4	7.3	6.7	23.4	21.5	4584	4.7	67.4	3.2	69	60
15	2.5	2.3	7.4	6.9	23.4	21.7	4538	4.8	69.1	3.2	63	55
16	2.4	2.3	9.1	8.4	23.3	21.6	4401	4.8	69.1	3.2	73	69
17	2.4	2.3	7.5	7.0	22.8	21.3	4207	5.0	68.2	3.1	74	68
18	2.3	2.2	7.9	7.4	21.9	20.7	3998	5.1	67.0	2.9	71	66
19	2.3	2.2	6.9	6.6	21.1	20.2	3848	5.3	66.7	2.8	74	61
20	2.4	2.3	6.6	6.3	21.1	20.1	3809	5.3	66.7	2.8	69	57
21	2.4	2.3	8.4	7.8	24.4	23.0	4054	5.1	68.6	3.0	76	69
22	#5、#6机组停运											
23												
24												
25												
26	2.4	2.3	9.1	8.4	23.3	21.7	4390	4.9	68.9	3.2	69	57
27	2.6	2.5	7.2	6.8	21.8	21.0	3827	5.4	68.0	3.0	73	61
28	2.4	2.3	6.8	6.4	25.9	24.6	3975	5.2	68.3	3.1	60	51
最大值	2.5	2.3	5.6	5.3	25.3	24.2	3979	5.3	69.1	3.1	68	64
最小值	2.7	2.6	15.7	14.8	25.9	24.6	4622	5.9	70.4	3.4	81	74
平均	2.0	1.9	5.6	5.3	21.1	20.0	2033	4.7	65.5	2.7	48	48
	2.3	2.2	8.9	8.4	22.9	21.7	4013	5.1	68.2	3.1	65	59