

深圳妈湾电力有限公司2022年3月#1烟卤烟气数据

烟量单位: 万立方米/天

#1烟卤排放口

日期	颗粒物		二氧化硫		氮氧化物		烟气量	氧量%	温度℃	湿度%	#1机组	#2机组
	标志	折算	标志	折算	标志	折算						
1	3.4	3.7	3.5	3.8	23.5	25.9	3312	7.4	69.1	3.1	52	50
2	2.9	3.1	3.7	3.9	24.4	26.3	3545	7.1	69.9	3.4	55	55
3	2.7	2.9	3.5	3.7	20.6	21.9	3503	6.9	69.0	3.5	56	57
4	2.7	2.8	4.2	4.3	23.1	24.1	3705	6.6	69.3	3.4	60	61
5	2.6	2.7	3.4	3.6	22.8	24.1	3587	6.8	69.1	3.5	56	58
6	3.0	3.3	3.2	3.5	24.1	26.2	3311	7.2	69.4	3.5	51	51
7	2.7	2.9	4.1	4.4	26.9	28.8	3635	7.0	70.0	3.6	57	57
8	3.0	3.2	4.8	5.0	25.1	26.6	3453	6.8	69.2	3.3	56	54
9	3.1	3.2	4.9	5.2	22.9	24.1	3341	6.7	68.8	3.3	54	52
10	3.2	3.3	6.8	6.9	22.4	23.0	3688	6.4	70.5	3.6	62	60
11	3.3	3.4	7.6	7.8	23.4	24.1	3856	6.5	71.2	3.7	65	63
12	3.0	3.2	5.3	5.5	22.6	23.6	3623	6.6	70.7	3.7	59	58
13	3.1	3.3	5.6	5.8	23.0	24.5	3534	6.9	71.5	3.7	56	56
14	2.9	3.0	4.8	4.9	23.0	24.0	3445	6.7	71.0	3.8	56	56
15	2.8	2.9	2.8	3.0	23.7	25.1	3246	6.8	70.3	3.8	51	52
16	2.8	2.9	3.1	3.3	23.1	24.2	3528	6.6	71.2	4.1	56	57
17	2.7	2.8	3.5	3.5	22.2	23.0	3499	6.5	72.3	4.3	58	58
18	2.8	2.8	3.1	3.2	21.6	22.2	3573	6.4	72.8	4.4	59	60
19	3.0	3.2	3.8	4.0	19.9	21.0	3216	6.8	73.2	4.4	52	51
20	3.0	3.2	3.6	3.9	21.5	23.2	3215	7.1	72.7	4.4	51	50
21	3.0	2.9	5.4	5.3	24.6	24.4	4135	6.0	74.6	4.9	72	72
22	2.9	2.9	5.9	5.7	25.0	24.5	4325	5.8	75.4	5.4	76	77
23	2.8	2.8	5.3	5.4	23.3	23.8	3731	6.3	69.2	4.5	63	64
24	2.7	2.8	5.7	5.8	23.7	24.2	3754	6.3	69.3	4.2	61	61
25	3.0	2.9	10.1	9.7	26.9	26.1	4441	5.6	74.6	5.1	80	80
26	2.9	2.9	6.6	6.6	24.9	25.3	3978	6.3	73.7	4.8	69	68
27	2.8	3.0	3.3	3.5	22.8	24.4	3472	7.0	70.8	4.4	54	54
28	2.8	2.9	3.9	4.1	22.2	23.4	3593	6.8	68.8	4.0	57	57
29	2.7	2.8	5.2	5.3	22.1	22.8	3660	6.5	70.5	4.1	59	60
30	2.8	3.0	5.1	5.4	22.1	23.7	3423	7.0	71.2	4.2	56	56
31	3.0	3.2	10.2	10.2	24.2	24.9	3941	6.5	75.2	4.9	69	69
最大值	3.4	3.7	10.2	10.2	26.9	28.8	4441	7.4	75.4	5.4	80	80
最小值	2.6	2.7	2.8	3.0	19.9	21.0	3215	5.6	68.8	3.1	51	50
平均	2.9	3.0	4.9	5.0	23.3	24.3	3622	6.6	71.1	4.0	59	59

23:51机组停运

深圳妈湾电力有限公司2022年3月#2烟肉烟气数据

浓度单位 (mg/m³)

烟肉量单位 万立方米/天

日期	颗粒物		二氧化硫		氮氧化物		烟肉量	氧重%	温度℃	湿度%	机组负荷率 (%)	
	标志	折算	标志	折算	标志	折算					#3机组	#4机组
1	3.4	4.0	4.8	5.6	19.9	23.5	2045	8.3	61.0	2.6	62	机组停运
2	3.1	3.6	4.7	5.4	21.3	25.0	2107	8.2	61.9	2.7	64	机组停运
3	3.0	3.4	5.3	6.0	20.7	24.4	2026	7.9	63.1	2.8	65	机组停运
4	3.0	3.3	6.6	7.2	21.8	24.1	2142	7.5	64.4	2.9	70	机组停运
5	3.0	3.3	8.8	9.7	19.5	21.6	2197	7.5	64.8	3.0	72	机组停运
6	3.2	3.7	3.7	4.3	20.3	23.7	1789	8.2	61.2	2.7	57	机组停运
7	4.1	4.5	7.6	8.4	20.6	23.3	2005	7.7	64.0	2.8	65	机组停运
8	4.0	4.7	8.2	9.5	20.5	24.1	1939	8.2	61.4	2.5	60	机组停运
9	3.5	4.1	7.2	8.5	20.8	24.5	1856	8.3	61.4	2.5	57	机组停运
10	4.4	4.9	12.0	13.1	23.9	26.5	2154	7.4	64.8	2.8	70	机组停运
11	3.6	3.9	14.1	15.2	23.7	26.0	2162	7.3	65.5	2.9	71	机组停运
12	3.7	4.1	12.5	13.6	22.9	25.2	2103	7.4	65.4	2.9	69	机组停运
13	4.3	4.8	10.6	11.6	22.5	25.1	2048	7.6	64.9	2.9	66	机组停运
14	3.7	4.2	7.1	8.0	25.4	29.1	1872	7.9	65.2	3.0	60	机组停运
15	3.1	3.6	6.4	7.5	24.4	29.1	1737	8.4	63.3	3.0	54	机组停运
16	3.6	4.0	11.2	12.4	27.5	30.8	2202	7.6	66.5	3.3	69	机组停运
17	3.3	3.7	9.6	10.6	25.5	29.1	1881	7.8	67.3	3.4	62	机组停运
18	3.6	3.9	9.2	9.8	22.6	24.3	1842	7.0	69.3	3.6	65	机组停运
19	3.5	3.7	11.5	12.2	23.2	24.9	1716	7.1	69.3	3.5	61	机组停运
20	3.2	3.4	9.7	10.5	23.3	25.4	1513	7.2	68.6	3.6	54	机组停运
21	3.7	3.7	12.9	12.8	24.7	24.9	1987	6.1	72.0	4.1	73	机组停运
22	3.9	3.8	15.3	14.8	25.3	24.8	2179	5.7	73.9	4.3	82	机组停运
23	3.5	4.2	13.6	14.8	23.0	25.1	2202	7.3	64.9	3.7	71	机组停运
24	3.0	3.7	13.7	15.1	21.3	24.8	1617	8.4	66.9	3.4	54	机组停运
25	3.2	4.2	10.9	13.7	19.6	25.6	2321	9.3	63.7	3.6	59	机组停运
26	3.8	4.3	15.6	17.1	20.6	23.6	2461	7.7	69.8	3.8	73	机组停运
27	3.0	3.9	7.5	9.5	22.3	29.6	2339	9.3	65.8	3.3	60	机组停运
28	3.0	3.1	13.4	13.8	20.0	20.9	1694	6.6	65.9	3.6	64	机组停运
29	2.8	2.9	13.9	14.4	22.7	23.9	1661	6.7	68.1	3.4	63	机组停运
30	2.8	3.0	19.7	20.4	17.9	18.9	1815	6.7	69.7	3.6	64	机组停运
31	2.9	3.0	20.2	20.5	19.6	20.0	2108	6.3	72.3	3.9	72	机组停运
最大值	4.4	4.9	20.2	20.5	27.5	30.8	2461	9.3	73.9	4.3	82	0
最小值	2.8	2.9	3.7	4.3	17.9	18.9	1513	5.7	61.0	2.5	54	0
平均	3.4	3.8	10.6	11.5	22.2	24.9	1991	7.6	66.0	3.2	65	#DIV/0!

深圳妈湾电力有限公司2022年3月#3烟卤烟气数据

烟气量单位: 万立方米/天

#3烟卤排放口

日期	颗粒物		二氧化硫		氮氧化物		烟气量	氧量%	温度℃	湿度%	机组负荷率(%)	
	标志	折算	标志	折算	标志	折算					#5机组	#6机组
1	2.1	2.1	6.4	6.3	34.2	33.7	3583	5.8	65.3	2.5	63	52
2	2.1	2.0	6.9	6.7	32.8	31.9	3758	5.6	66.8	2.6	66	57
3	2.2	2.2	5.3	5.3	33.5	34.0	3490	6.2	66.6	2.6	52	57
4	2.1	2.1	6.1	6.0	32.7	32.6	3719	5.9	66.3	2.8	53	65
5	2.1	2.1	6.4	6.4	33.4	33.6	3525	6.1	65.8	2.8	47	62
6	2.3	2.4	5.4	5.5	33.3	34.0	3326	6.3	64.0	2.7	46	53
7	2.4	2.3	6.7	6.5	29.1	28.3	3842	5.6	66.2	2.9	63	62
8	2.4	2.4	6.7	6.6	32.1	31.9	3606	5.9	64.7	2.7	59	54
9	2.5	2.5	5.5	5.5	31.5	31.4	3510	5.9	63.0	2.6	57	52
10	2.5	2.4	6.4	6.1	30.5	29.4	3939	5.4	66.1	2.9	68	62
11	2.5	2.4	9.8	9.3	30.1	29.1	4097	5.4	67.0	3.0	71	66
12	2.5	2.4	10.9	10.6	29.2	28.3	3818	5.6	66.0	2.9	67	58
13	2.6	2.6	11.7	11.3	30.0	29.2	3799	5.6	66.7	3.0	64	61
14	2.6	2.6	11.7	11.2	31.7	31.0	3799	5.7	67.3	3.1	62	62
15	2.5	2.5	8.7	8.6	33.5	33.3	3398	5.9	66.9	3.0	55	52
16	2.9	2.7	20.0	19.0	31.5	30.3	3947	5.4	68.5	3.3	69	62
17	3.8	3.7	13.7	13.2	26.8	26.4	3708	5.7	68.4	3.3	62	59
18	3.4	3.3	15.2	14.6	25.7	25.3	3851	5.7	68.8	3.5	64	61
19	3.0	3.0	9.5	9.3	25.0	24.7	3507	5.8	68.5	3.4	61	52
20	2.8	2.8	6.8	6.8	27.0	27.1	3350	6.0	67.5	3.4	54	51
21	3.0	2.9	14.3	13.6	27.0	26.1	4288	5.5	70.1	4.0	70	74
22	2.8	2.6	10.9	10.3	24.9	23.6	4533	5.2	71.1	4.2	79	78
23	2.5	2.4	6.9	6.7	25.0	24.0	4046	5.4	65.1	3.7	69	65
24	2.5	2.4	8.7	8.3	26.8	25.7	4007	5.3	65.3	3.6	70	63
25	2.5	2.4	11.8	11.1	30.1	28.9	4045	5.3	68.8	3.8	78	60
26	2.5	2.4	15.9	15.0	27.9	26.7	4142	5.3	69.2	3.9	74	68
27	2.5	2.5	10.0	9.8	30.4	30.0	3525	5.8	66.3	3.4	59	53
28	2.5	2.4	13.1	12.6	26.8	26.2	3814	5.6	63.8	3.4	65	59
29	2.5	2.5	18.2	17.9	26.1	26.0	3796	5.8	65.5	3.4	62	60
30	2.6	2.6	26.3	25.6	23.8	23.3	3721	5.6	67.6	3.5	62	59
31	2.4	2.3	27.4	26.1	25.1	24.1	4054	5.3	69.4	3.8	68	69
最大值	3.8	3.7	27.4	26.1	34.2	34.0	4533	6.3	71.1	4.2	79	78
最小值	2.1	2.0	5.3	5.3	23.8	23.3	3326	5.2	63.0	2.5	46	51
平均	2.6	2.5	11.1	10.7	29.3	28.7	3792	5.7	66.9	3.2	63	60