

深圳妈湾电力有限公司2022年4月#1烟囱烟气数据

浓度单位 (mg/Nm³) 烟气量单位 万立方米/天

日期	#1烟囱排放口						机组负荷率 (%)					
	颗粒物		二氧化硫		氮氧化物		烟气量	氧量%	温度℃	湿度%	#1机组	#2机组
	标态	折算	标态	折算	标态	折算						
1	2.92	2.96	7.90	7.92	21.90	22.14	2119	6.20	72.90	4.60	73	机组停运
2	3.57	3.75	7.91	8.16	20.25	21.07	2292	6.60	69.80	4.10	76	机组停运
3	3.05	3.35	6.46	7.04	19.66	21.60	1963	7.30	68.10	3.50	61	机组停运
4	2.94	3.18	9.49	9.98	19.37	20.71	2133	7.00	70.20	3.80	68	机组停运
5	2.79	2.93	7.44	7.65	20.14	21.17	1935	6.70	70.60	3.80	64	机组停运
6	3.87	4.16	4.93	5.23	20.30	21.59	1839	6.90	70.40	3.90	59	机组停运
7	2.64	2.78	4.62	4.82	20.15	21.18	1769	6.70	70.80	4.00	57	机组停运
8	2.62	2.69	4.30	4.41	19.84	20.34	1903	6.40	71.70	4.20	64	机组停运
9	2.75	2.84	3.98	4.08	21.42	22.12	1879	6.50	71.10	4.20	63	机组停运
10	2.68	2.87	3.30	3.52	23.73	25.46	1685	7.00	70.00	4.00	53	机组停运
11	2.96	2.95	5.38	5.27	23.47	23.38	2055	6.00	73.90	4.60	72	机组停运
12	3.23	3.73	4.19	4.66	22.90	26.19	2894	7.80	69.90	4.50	71	19:15并网发电
13	2.58	2.61	4.53	4.56	22.76	22.96	3901	6.20	73.30	4.90	68	65
14	2.87	2.98	3.03	3.14	23.09	23.99	3653	6.60	70.80	4.80	60	58
15	2.87	2.96	3.31	3.38	22.66	23.28	3715	6.40	72.00	4.80	63	62
16	2.81	3.03	4.72	5.06	23.89	25.69	3364	7.00	70.70	4.50	52	51
17	2.90	3.03	5.00	5.14	23.96	24.93	3660	6.60	70.80	4.50	59	60
18	2.89	3.05	4.94	5.16	23.71	24.96	3452	6.70	69.70	4.20	54	54
19	2.73	2.89	4.38	4.64	22.61	23.99	3263	6.90	68.40	3.80	50	50
20	2.74	2.91	4.38	4.65	23.16	24.58	3192	6.90	69.10	4.00	49	49
21	2.87	3.01	5.12	5.36	25.80	27.09	3263	6.70	70.60	4.30	51	51
22	2.94	3.07	6.70	6.81	24.05	25.10	3611	6.60	72.20	4.80	59	58
23	2.94	2.98	5.38	5.33	24.90	25.15	3928	6.20	74.70	5.00	67	67
24	2.92	3.03	4.91	5.02	24.07	24.94	3664	6.50	73.50	5.10	61	60
25	2.84	2.86	10.18	10.00	25.25	25.33	4044	6.10	75.70	5.40	71	71
26	2.77	2.73	17.17	16.61	26.15	25.64	4411	5.70	76.70	5.80	80	79
27	2.73	2.79	13.52	13.51	24.61	25.07	3966	6.30	74.90	5.70	70	67
28	2.70	2.77	13.42	13.56	24.02	24.54	3359	6.40	76.10	6.20	15: 41机组停运	69
29	2.69	2.93	13.70	14.72	24.80	26.79	3004	7.00	74.50	5.90	17: 07并网发电	75
30	2.78	2.94	7.56	7.80	22.76	23.98	3609	6.80	74.90	5.70	60	59
最大值	3.9	4.2	17.2	16.6	26.2	27.1	4411	7.8	76.7	6.2	80	79
最小值	2.6	2.6	3.0	3.1	19.4	20.3	1685	5.7	68.1	3.5	49	49
平均	2.9	3.0	6.7	6.9	22.8	23.8	2984	6.6	71.9	4.6	63	61

深圳妈湾电力有限公司2022年4月#2烟囱烟气数据

浓度单位: mg/Nm³

烟气量单位: 万立方米/天

日期	#2烟囱排放口						机组负荷率(%)					
	颗粒物		二氧化硫		氮氧化物		烟气量	氧量%	温度℃	湿度%	#3机组	#4机组
	标态	折算	标态	折算	标态	折算						
1	3.04	2.99	14.16	13.89	20.06	19.81	2321	5.80	72.00	4.00	78	机组停运
2	3.32	3.67	10.99	11.99	19.90	21.62	3968	7.10	67.70	3.80	78	11:46并网发电
3	2.94	2.90	10.72	10.51	20.73	20.55	4009	5.80	70.50	3.70	61	62
4	3.34	3.23	12.09	11.52	23.73	22.94	4349	5.50	72.80	3.80	69	67
5	3.29	3.25	10.99	10.53	23.30	22.98	4075	5.90	72.00	3.70	63	63
6	3.04	3.04	8.74	8.55	22.94	22.98	3861	6.00	72.60	3.60	58	58
7	3.22	3.16	9.65	9.26	23.60	23.08	4145	5.70	73.90	3.80	64	64
8	3.30	3.14	6.85	6.53	23.05	21.97	4513	5.30	75.00	4.00	76	76
9	3.68	3.53	8.23	7.80	24.04	23.09	4102	5.40	73.20	3.90	72	71
10	3.51	3.48	7.86	7.65	24.88	24.76	3641	5.90	73.10	3.90	62	61
11	3.78	3.57	10.03	9.27	26.55	25.02	4239	5.20	75.00	4.30	74	75
12	3.84	3.57	14.90	13.63	24.29	22.63	4376	4.90	75.30	4.30	78	78
13	3.58	3.41	10.24	9.65	22.11	21.05	4154	5.30	74.80	4.30	73	73
14	3.40	3.30	5.33	5.16	21.52	20.90	3806	5.60	74.10	4.30	66	65
15	3.51	3.40	6.01	5.80	21.98	21.32	3876	5.50	74.30	4.40	68	67
16	3.14	3.20	11.26	11.42	22.20	22.58	3308	6.30	72.10	4.00	54	53
17	3.35	3.33	10.72	10.53	22.73	22.66	3445	6.00	72.50	4.10	56	59
18	3.25	3.29	11.37	11.41	21.17	21.48	3276	6.20	72.20	4.00	52	55
19	3.16	3.11	12.12	11.81	26.13	25.60	3429	5.80	71.60	4.00	47	68
20	3.23	3.17	12.08	11.75	24.88	24.43	3411	5.70	72.60	4.00	46	71
21	3.23	3.25	10.86	10.89	23.08	23.24	3259	6.10	73.00	4.00	47	60
22	3.51	3.48	15.41	15.11	22.44	22.36	3657	5.90	74.30	4.30	62	61
23	3.51	3.39	11.23	10.69	22.24	21.51	3930	5.50	76.30	4.60	68	68
24	3.36	3.34	10.04	9.80	23.75	23.61	3602	5.90	75.90	4.50	61	61
25	3.26	3.14	15.14	14.32	24.39	23.54	3951	5.50	76.70	4.70	70	70
26	3.41	3.20	22.22	20.66	25.38	23.77	4411	5.00	78.20	5.20	81	80
27	2.96	2.82	18.67	17.69	24.50	23.33	4044	5.30	76.90	5.00	72	71
28	3.04	2.89	18.64	17.64	24.86	23.68	4103	5.30	77.60	5.30	73	72
29	3.19	2.99	18.59	17.33	24.98	23.47	4269	5.00	78.00	5.50	76	77
30	3.12	3.14	10.30	10.22	23.02	23.13	2565	6.10	75.00	5.10	10:51机组停运	61
最大值	3.8	3.7	22.2	20.7	26.6	25.6	4513	7.1	78.2	5.5	81	80
最小值	2.9	2.8	5.3	5.2	19.9	19.8	2321	4.9	67.7	3.6	46	53
平均	3.3	3.2	11.8	11.4	23.3	22.8	3803	5.7	74.0	4.3	66	67

深圳妈湾电力有限公司2022年4月#3烟囱烟气数据

浓度单位 Cmg/Nm³ 烟气量单位 万立方米/天

日期	#3烟囱排放口						机组负荷率 (%)					
	颗粒物		二氧化硫		氮氧化物		烟气量	氧量%	温度℃	湿度%	#5机组	#6机组
	标态	折算	标态	折算	标态	折算						
1	2.47	2.33	26.09	24.55	23.43	22.05	4463	5.10	68.60	4.10	80	78
2	2.66	2.60	23.12	22.48	26.71	26.13	3978	5.70	65.30	3.60	53	76
3	3.29	3.53	7.03	7.45	24.51	26.19	2161	6.90	61.50	2.90	1: 31机组停运	60
4	3.34	3.45	11.06	11.16	24.97	25.86	2208	6.50	62.30	3.10	机组停运	67
5	3.33	3.38	13.38	13.17	21.06	21.24	2052	6.20	64.00	3.20	机组停运	64
6	3.11	3.51	6.42	6.69	20.60	22.63	3347	7.10	64.00	3.30	9: 22并网发电	59
7	2.57	2.52	8.36	8.05	23.71	23.24	3822	5.70	68.30	3.60	68	60
8	2.48	2.36	12.29	11.63	23.72	22.62	4153	5.20	69.50	3.90	81	65
9	2.70	2.59	14.07	13.38	25.80	24.73	4130	5.40	69.20	3.90	80	63
10	2.56	2.49	10.57	10.23	24.82	24.22	3765	5.60	68.20	3.70	72	55
11	2.77	2.67	13.68	12.86	25.88	24.83	4260	5.40	70.30	4.10	77	71
12	2.60	2.48	9.62	9.05	25.45	24.21	4346	5.20	70.60	4.20	81	73
13	2.59	2.49	6.74	6.43	23.37	22.46	4058	5.40	69.80	4.20	76	68
14	2.57	2.51	7.27	7.03	24.81	24.18	3825	5.60	68.90	4.10	69	61
15	2.63	2.55	6.63	6.40	25.77	25.01	3879	5.50	69.20	4.20	70	63
16	2.68	2.69	11.09	11.08	27.58	27.70	3401	6.00	67.40	3.90	56	52
17	2.62	2.60	16.34	15.96	28.04	27.85	3659	5.90	68.30	4.00	60	59
18	2.62	2.64	14.26	14.15	26.89	27.13	3503	6.10	67.10	3.80	57	54
19	2.54	2.48	19.97	19.38	25.81	25.17	3902	5.60	66.80	4.00	57	72
20	2.64	2.59	15.64	15.26	26.56	26.03	3859	5.70	67.40	4.00	55	72
21	2.71	2.69	9.15	8.99	25.50	25.26	3691	5.80	68.00	3.90	58	63
22	2.73	2.70	11.06	10.64	26.81	26.51	3621	5.80	69.90	4.00	59	61
23	2.66	2.62	19.70	19.05	24.37	24.00	3930	5.70	71.20	4.30	67	65
24	2.73	2.71	11.17	10.83	28.34	28.08	3697	5.80	71.00	4.30	61	61
25	2.65	2.57	8.98	8.63	26.43	25.68	4082	5.50	72.40	4.60	69	72
26	2.65	2.51	12.14	11.40	24.85	23.53	4424	5.20	73.40	5.10	76	82
27	2.49	2.40	6.45	6.18	25.72	24.84	4034	5.50	72.30	4.90	70	69
28	2.49	2.41	12.26	11.76	24.44	23.72	4089	5.50	72.70	5.10	72	69
29	2.49	2.39	15.42	14.67	25.79	24.78	4371	5.40	72.70	5.00	78	76
30	2.47	2.43	7.39	7.22	27.79	27.38	3594	5.80	70.40	4.60	62	58
最大值	3.3	3.5	26.1	24.6	28.3	28.1	4463	7.1	73.4	5.1	81	82
最小值	2.5	2.3	6.4	6.2	20.6	21.2	2052	5.1	61.5	2.9	53	52
平均	2.7	2.7	12.2	11.9	25.3	24.9	3743	5.7	68.7	4.1	68	66