

# 深圳妈湾电力有限公司2022年7月#1烟囱烟气数据



浓度单位: (mg/m<sup>3</sup>) 烟气量单位: 万立方米/天

日期	颗粒物		二氧化硫		氮氧化物		烟气量	氧量%	温度℃	湿度%	机组负荷率 (%)	
	标志	折算	标志	折算	标志	折算					#1机组	#2机组
1	2.7	3.1	7.9	8.7	22.7	25.2	3414	7.4	71.6	6.5	50	52
2	1:30#1烟囱停运											
3	1日23:58机组停运											
4	机组停运											
5	机组停运											
6	机组停运											
7	机组停运											
8	机组停运											
9	机组停运											
10	机组停运											
11	机组停运											
12	12:20#1烟囱恢复											
13	3.3	3.5	16.7	17.4	29.3	30.7	2263	6.7	75.1	7.7	79	79
14	3.0	3.2	20.3	21.7	26.5	28.4	2233	7.1	74.8	7.5	77	77
15	2.9	3.1	18.6	19.9	27.2	29.2	2199	7.0	74.7	7.4	76	76
16	3.0	3.3	19.8	21.2	28.3	30.9	2173	7.2	74.8	7.6	79	79
17	3.3	3.6	20.4	22.0	27.7	30.0	2247	7.2	75.7	7.7	80	80
18	3.6	5.3	16.4	22.4	25.4	36.2	3655	10.2	72.7	7.3	77	85
19	4.3	4.7	22.5	24.5	28.2	30.8	4453	7.3	79.6	7.7	77	84
20	3.9	4.3	14.2	15.6	27.6	30.6	4277	7.5	78.7	7.5	67	84
21	3.6	4.1	19.3	21.7	26.2	29.7	4266	7.8	77.7	7.2	73	77
22	3.7	4.1	21.8	24.0	27.0	30.0	4457	7.5	77.9	7.2	78	81
23	3.5	3.9	20.0	22.3	26.7	29.8	4445	7.6	78.0	7.1	80	81
24	3.1	3.6	16.4	18.9	25.3	29.1	4262	8.0	77.0	6.9	76	76
25	3.2	3.4	22.3	23.8	27.9	30.1	4450	7.0	78.0	7.1	79	80
26	3.3	3.1	16.1	15.1	27.3	25.6	4528	5.0	78.2	7.2	83	84
27	3.3	3.1	17.4	16.3	29.0	27.3	4553	5.1	78.3	7.3	84	84
28	3.5	3.2	23.9	22.0	31.6	29.1	4875	4.7	79.9	7.6	92	92
29	3.3	3.1	24.5	22.7	30.9	28.6	4843	4.8	79.8	7.5	94	94
30	3.5	3.2	24.2	22.6	29.8	27.7	4725	4.9	78.9	7.3	89	89
31	3.6	3.4	20.2	19.2	28.6	27.3	4700	5.2	79.3	7.1	88	86
最大值	4.3	5.3	24.5	24.5	31.6	36.2	4875	10.2	79.9	7.7	94	94
最小值	2.7	3.1	7.9	8.7	22.7	25.2	2173	4.7	71.6	6.5	50	52
平均	3.4	3.6	19.1	20.1	27.7	29.3	3851	6.8	77.0	7.3	79	81

烟囱停运

# 深圳妈湾电力有限公司2022年7月#2烟卤烟气数据

浓度单位: mg/m<sup>3</sup> 烟气量单位: 万立方米/天

日期	颗粒物		二氧化硫		氮氧化物		烟气量	氧量%	温度℃	湿度%	#3机组	#4机组
	标志	折算	标志	折算	标志	折算						
1	3.1	3.2	15.1	15.8	18.6	19.5	3201	6.8	72.9	5.1	50	50
2	3.4	3.4	24.2	23.6	22.1	21.8	3964	5.8	75.1	5.6	67	66
3	2.7	2.6	24.4	23.2	21.5	20.9	3900	5.6	76.4	5.7	67	65
4	2.7	2.7	19.2	18.7	21.3	21.3	3879	6.0	76.5	5.8	65	65
5	3.0	2.9	23.9	22.6	21.8	20.8	4199	5.4	76.9	5.9	72	73
6	3.4	3.2	22.9	21.8	21.2	20.2	4135	5.3	76.8	5.9	71	71
7	4.1	3.7	20.7	18.3	23.0	20.9	4226	4.5	77.6	6.0	74	73
8	4.5	4.0	20.7	18.6	23.1	20.8	4488	4.4	79.1	6.3	79	80
9	4.6	4.3	24.7	22.8	25.6	23.8	4240	4.8	77.8	6.2	74	73
10	4.0	3.6	23.2	20.4	26.9	23.9	4387	4.1	79.3	6.3	78	77
11	3.2	3.0	23.3	21.5	23.4	21.8	3938	4.9	76.8	6.0	72	61
12	3.3	3.0	27.5	25.2	24.6	22.4	4131	4.5	77.9	6.3	76	65
13	3.4	3.2	26.6	25.2	23.2	22.0	4280	5.2	78.4	6.4	79	66
14	3.2	3.0	29.0	27.9	22.6	21.8	4174	5.4	77.6	6.3	75	65
15	3.5	3.4	27.6	26.7	22.6	21.9	4370	5.5	78.1	6.5	75	72
16	3.2	3.1	28.8	27.6	24.2	23.3	4244	5.4	78.1	6.5	74	71
17	3.6	3.4	33.0	31.3	24.5	23.2	4370	5.2	79.0	6.6	78	73
18	3.7	3.5	33.8	32.0	25.5	24.1	4474	5.2	79.2	6.7	80	74
19	3.9	3.7	31.4	29.7	26.1	24.7	4504	5.1	79.6	6.6	80	75
20	4.1	3.9	23.8	22.6	25.5	24.2	4518	5.2	80.1	6.5	80	76
21	3.6	3.4	26.2	25.0	24.9	23.7	4435	5.3	78.8	6.4	78	78
22	3.6	3.4	29.6	27.9	21.3	20.2	4479	5.1	79.3	6.4	79	78
23	3.6	3.5	30.4	29.3	21.0	20.2	4443	5.5	78.8	6.0	78	76
24	3.6	3.5	31.2	30.1	20.6	19.8	4480	5.4	78.5	5.9	78	78
25	3.6	3.5	31.2	29.8	21.4	20.4	4525	5.3	79.1	6.0	82	78
26	3.6	3.4	28.2	26.8	22.4	21.3	4713	5.2	79.1	6.2	84	83
27	3.7	3.5	28.3	26.6	24.2	22.8	4813	5.1	79.4	6.3	86	86
28	3.8	3.5	30.6	28.2	26.3	24.3	4947	4.7	80.2	6.4	91	91
29	3.6	3.3	32.4	30.0	26.6	24.6	4930	4.8	80.5	6.4	90	91
30	3.3	3.1	31.4	29.3	26.2	24.5	4805	4.9	79.5	6.3	87	87
31	3.4	3.2	28.8	27.1	26.3	24.8	4738	5.1	79.3	6.2	84	84
最大值	4.6	4.3	33.8	32.0	26.9	24.8	4947	6.8	80.5	6.7	91	91
最小值	2.7	2.6	15.1	15.8	18.6	19.5	3201	4.1	72.9	5.1	50	50
平均	3.5	3.4	26.8	25.3	23.5	22.2	4353	5.2	78.2	6.2	77	74

# 深圳妈湾电力有限公司2022年7月#3烟卤烟气数据

浓度单位: (mg/m<sup>3</sup>)

烟量单位: 万立方米/天

日期	颗粒物		二氧化硫		氮氧化物		烟气量	氧量%	温度℃	湿度%	#5机组	#6机组
	标志	折算	标志	折算	标志	折算						
1	2.3	2.3	9.3	9.2	24.1	24.2	3252	6.1	69.8	4.9	51	50
2	2.2	2.2	24.8	23.5	23.7	23.0	4116	5.5	71.3	5.2	69	69
3	2.0	1.9	19.7	18.9	24.7	24.1	4072	5.6	72.4	5.4	68	68
4	1.9	1.9	22.1	21.4	24.8	24.4	3812	5.7	71.8	5.3	63	62
5	2.0	2.0	27.6	26.5	25.4	24.6	4079	5.5	71.8	5.4	70	67
6	2.2	2.1	19.5	18.7	23.8	23.0	4195	5.5	72.9	5.5	75	68
7	2.5	2.4	20.5	19.2	25.2	24.3	4361	5.4	72.6	5.5	75	74
8	2.6	2.4	25.6	24.1	25.0	23.7	4517	5.2	73.8	5.7	79	78
9	2.6	2.5	22.7	21.5	25.0	24.0	4344	5.3	73.4	5.6	76	74
10	2.5	2.4	23.4	22.0	22.3	21.2	4512	5.2	73.8	5.7	78	78
11	2.4	2.3	21.1	20.2	21.9	21.1	4250	5.4	72.7	5.7	73	71
12	2.4	2.3	27.8	26.3	23.1	21.8	4610	5.1	73.7	5.8	80	81
13	2.4	2.3	33.2	31.8	23.1	22.1	4318	5.3	72.8	5.8	71	78
14	2.4	2.3	37.9	35.9	23.2	22.0	4225	5.2	72.7	5.8	68	78
15	2.4	2.3	35.8	34.1	23.1	22.0	4465	5.3	73.3	5.9	76	78
16	2.4	2.3	35.0	33.3	25.0	23.9	4400	5.3	73.7	5.9	74	77
17	2.5	2.3	42.1	40.0	24.0	22.9	4336	5.2	73.5	5.8	73	77
18	2.4	2.3	39.4	37.4	25.4	24.1	4408	5.2	73.4	6.0	73	79
19	2.5	2.3	24.6	23.1	26.5	24.9	4616	5.1	74.4	6.0	82	81
20	2.7	2.5	27.1	25.6	26.3	24.9	4666	5.1	74.4	5.9	82	82
21	2.6	2.5	24.1	23.0	26.9	25.6	4391	5.3	73.3	5.7	72	78
22	2.7	2.5	28.0	26.3	26.6	25.0	4642	5.1	73.7	5.7	81	82
23	2.7	2.6	24.3	22.9	25.7	24.4	4645	5.2	73.8	5.7	82	80
24	2.8	2.7	22.9	21.8	25.9	24.7	4443	5.3	73.3	5.5	76	77
25	2.7	2.5	30.6	28.7	26.4	24.9	4705	5.1	74.2	5.6	82	83
26	2.5	2.4	31.8	30.1	27.2	25.8	4721	5.2	73.9	5.6	82	82
27	2.5	2.4	29.7	27.8	27.6	26.0	4815	5.0	73.9	5.6	85	85
28	2.6	2.4	33.9	31.4	28.7	26.6	5039	4.8	75.1	5.9	90	91
29	2.5	2.3	31.7	29.4	27.8	25.8	4987	4.8	75.3	5.9	89	91
30	2.5	2.3	31.2	29.1	30.0	28.0	4866	4.9	74.5	5.8	87	87
31	2.5	2.4	31.0	29.1	28.5	26.7	4809	5.0	74.4	5.8	85	85
最大值	2.8	2.7	42.1	40.0	30.0	28.0	5039	6.1	75.3	6.0	90	91
最小值	1.9	1.9	9.3	9.2	21.9	21.1	3252	4.8	69.8	4.9	51	50
平均	2.4	2.3	27.7	26.2	25.4	24.2	4439	5.3	73.3	5.7	76	77