

# 深圳妈湾电力有限公司2022年9月#1烟囱烟气数据

浓度单位: (mg/Nm<sup>3</sup>)

烟气量单位: 万立方米/天

日期	颗粒物		二氧化硫		氮氧化物		烟气量	氧量%	温度℃	湿度%	机组负荷率 (%)	
	标态	折算	标态	折算	标态	折算					#1机组	#2机组
1	4.15	3.91	16.04	15.12	30.77	28.99	4892	5.10	79.60	8.10	92	92
2	3.44	3.27	11.23	10.67	30.89	29.32	4696	5.20	78.50	7.80	87	87
3	3.37	3.33	10.94	10.77	29.25	28.90	4543	5.80	76.50	7.30	79	82
4	3.81	3.86	9.32	9.30	27.57	27.94	4122	6.20	74.40	6.90	71	72
5	3.83	3.78	11.20	10.99	28.02	27.56	4384	5.80	76.30	7.10	78	78
6	3.88	3.75	12.92	12.43	30.15	29.11	4525	5.50	77.60	7.50	83	83
7	3.98	3.86	10.71	10.36	29.33	28.39	4496	5.50	76.90	7.70	83	83
8	3.73	3.67	8.26	8.05	29.66	29.14	4399	5.80	75.50	7.50	76	78
9	3.70	3.60	11.31	10.90	30.63	29.77	4374	5.60	75.10	7.50	76	78
10	3.83	3.76	7.19	6.99	30.07	29.45	4403	5.70	75.60	7.90	76	79
11	3.63	3.49	5.30	5.05	31.23	29.95	4555	5.40	80.70	8.00	83	83
12	3.89	3.72	8.86	8.43	33.38	31.89	4654	5.30	80.70	8.20	87	87
13	3.87	3.67	8.90	8.44	30.03	28.42	4667	5.20	81.30	8.10	83	90
14	3.51	3.37	6.84	6.54	28.63	27.44	4607	5.30	80.00	8.00	86	86
15	3.62	3.40	6.14	5.75	26.64	24.99	4688	5.00	80.10	8.00	87	87
16	3.76	3.48	11.02	10.20	26.62	24.60	4838	4.80	80.60	8.10	94	94
17	4.55	4.25	14.81	13.85	31.79	29.76	4907	5.00	80.60	7.90	93	95
18	4.79	4.58	14.21	13.60	30.88	29.57	4840	5.30	79.40	7.60	87	91
19	4.58	4.32	17.47	16.48	32.92	31.08	4917	5.10	79.20	5.60	87	89
20	4.76	4.46	18.38	17.24	29.13	27.29	4931	5.00	79.00	3.20	87	88
21	4.01	3.83	6.35	6.08	27.56	26.37	4811	5.30	79.40	5.70	85	86
22	4.63	4.47	5.60	5.40	29.71	28.66	4632	5.40	79.40	7.80	84	85
23	5.26	5.07	9.53	9.17	31.41	30.21	4690	5.40	79.70	7.80	85	85
24	4.93	4.84	11.82	11.56	30.44	29.85	4533	5.70	78.70	7.70	81	80
25	5.10	5.03	8.08	7.95	29.81	29.41	4481	5.80	78.30	7.60	78	79
26	4.94	4.82	14.73	14.31	30.17	29.44	4426	5.60	78.70	7.80	79	78
27	3.59	3.45	15.79	15.19	29.86	28.68	4569	5.40	79.40	7.80	84	83
28	3.46	3.29	16.22	15.51	30.22	28.71	4566	5.20	79.70	7.80	83	84
29	3.47	3.36	11.36	10.90	30.05	29.00	4519	5.50	78.90	7.90	80	82
30	3.25	3.17	8.94	8.68	29.35	28.70	4500	5.70	77.30	7.50	78	81
最大值	5.3	5.1	18.4	17.2	33.4	31.9	4931	6.2	81.3	8.2	94	95
最小值	3.3	3.2	5.3	5.1	26.6	24.6	4122	4.8	74.4	3.2	71	72
平均	4.0	3.9	11.0	10.5	29.9	28.8	4606	5.4	78.6	7.4	83	84

# 深圳妈湾电力有限公司2022年9月#2烟卤烟气数据

浓度单位: Cmg/Nm<sup>3</sup> 烟气量单位: 万立方米/天

日期	颗粒物		二氧化硫		氮氧化物		烟气量	氧量%	温度℃	湿度%	机组负荷率(%)	
	标志	折算	标志	折算	标志	折算					#3机组	#4机组
	0.5	0.5	0.5	0.5	0.5	0.5						
1	3.85	3.65	25.87	24.50	22.87	21.65	5056	5.20	79.40	6.70	88	89
2	3.50	3.39	21.69	20.99	22.80	22.09	4888	5.50	78.00	6.30	84	84
3	3.70	3.60	19.81	19.18	22.49	21.86	4659	5.60	76.50	6.20	77	79
4	4.08	4.09	18.73	18.57	19.94	20.00	4267	6.10	75.10	5.60	69	71
5	4.48	4.44	16.69	16.47	21.65	21.42	4402	5.90	75.50	5.70	73	73
6	4.38	4.27	21.05	20.41	22.35	21.78	4724	5.60	77.20	6.10	81	81
7	3.93	3.84	22.70	22.16	22.34	21.84	4734	5.70	76.40	6.30	78	79
8	3.96	3.89	19.48	18.94	22.21	21.82	4612	5.70	76.70	6.40	76	76
9	3.99	3.93	19.38	18.78	22.52	22.12	4562	5.80	76.70	6.40	74	76
10	3.85	3.78	15.50	15.11	21.38	20.95	4628	5.70	77.30	6.60	77	77
11	3.76	3.59	10.66	10.15	23.34	22.28	4740	5.30	80.30	6.70	82	83
12	3.73	3.54	20.70	19.57	25.11	23.84	3812	5.20	80.10	6.80	86	88
13	3.71	3.47	23.19	21.67	25.09	23.45	3941	5.00	80.80	6.90	90	90
14	3.45	3.29	17.87	17.05	25.43	24.28	3860	5.30	80.00	6.80	86	87
15	3.66	3.46	16.29	15.38	25.70	24.28	3977	5.10	80.10	6.90	88	89
16	3.52	3.29	23.69	22.13	26.76	25.02	4053	5.00	80.40	6.90	92	93
17	3.58	3.32	27.67	25.69	26.02	24.17	4443	4.90	80.80	6.90	92	92
18	3.77	3.53	26.09	24.43	26.09	24.44	4742	5.00	79.90	6.80	89	88
19	3.87	3.68	25.40	24.17	25.97	24.71	4826	5.20	79.10	6.80	88	88
20	3.97	3.76	26.14	24.73	26.43	25.02	4777	5.20	79.30	6.60	86	87
21	3.33	3.21	16.00	15.43	24.74	23.84	4780	5.40	78.70	6.50	83	83
22	3.31	3.21	14.03	13.58	25.60	24.81	4765	5.50	78.40	6.40	82	83
23	3.38	3.26	20.99	20.18	25.54	24.57	4815	5.40	78.90	6.50	85	84
24	3.21	3.17	22.29	21.98	23.99	23.66	4619	5.80	77.50	6.30	77	78
25	3.20	3.15	18.66	18.34	23.47	23.08	4501	5.80	77.50	6.30	75	76
26	3.41	3.33	21.58	21.07	23.01	22.47	4633	5.60	78.20	6.40	78	79
27	4.07	4.31	19.94	20.13	20.63	21.40	4420	6.50	78.50	6.40	82	9:30-13:43停运
28	3.81	3.70	23.28	22.52	21.51	20.81	4758	5.50	78.90	6.50	81	83
29	3.22	3.13	21.69	21.09	22.84	22.22	4773	5.60	78.00	6.40	81	83
30	3.10	3.06	14.83	14.55	22.22	21.90	4535	5.80	75.00	6.50	73	78
最大值	4.5	4.4	27.7	25.7	26.8	25.0	5056	6.5	80.8	6.9	92	93
最小值	3.1	3.1	10.7	10.2	19.9	20.0	3812	4.9	75.0	5.6	69	71
平均	3.7	3.6	20.4	19.6	23.7	22.9	4543	5.5	78.3	6.5	82	83

# 深圳妈湾电力有限公司2022年9月#3烟囱烟气数据

浓度单位: (mg/m<sup>3</sup>) 烟气量单位: 万立方米/天

日期	颗粒物		二氧化硫		氮氧化物		烟气量	氧量%	温度℃	湿度%	机组负荷率 (%)	
	标志	折算	标志	折算	标志	折算					#5机组	#6机组
1	2.74	2.57	32.55	30.53	24.52	22.99	4947	5.00	76.00	6.10	91	89
2	2.50	2.37	31.60	29.85	22.70	21.45	4668	5.10	74.40	5.80	84	84
3	2.37	2.25	20.07	19.03	23.57	22.35	4432	5.20	73.40	5.50	80	78
4	2.43	2.36	19.38	18.60	21.00	20.42	4069	5.50	73.20	5.10	73	69
5	2.46	2.34	20.66	19.62	20.14	19.18	4263	5.20	73.90	5.30	76	74
6	2.44	2.29	25.54	23.95	22.58	21.22	4372	5.00	74.20	5.40	81	78
7	2.61	2.47	24.65	23.32	23.30	22.07	4463	5.20	73.70	5.60	82	79
8	2.87	2.73	26.71	25.34	22.45	21.39	4362	5.30	73.80	5.60	79	76
9	2.82	2.78	19.22	18.84	22.71	22.31	3387	5.70	73.30	5.60	76	18: 57机组停运
10	3.51	3.49	23.04	22.68	23.93	23.71	2299	5.90	71.90	5.70	80	机组停运
11	2.98	2.88	21.31	20.52	27.57	26.60	2385	5.50	73.30	6.00	87	机组停运
12	3.30	3.41	21.12	21.16	28.76	29.78	3711	6.30	72.30	5.90	89	9: 44机组并网
13	3.75	3.48	28.32	26.26	24.30	22.51	4980	4.80	75.50	6.50	93	92
14	3.39	3.17	28.10	26.28	23.60	22.10	4814	5.00	75.50	6.40	89	90
15	3.75	3.49	27.06	25.19	22.62	21.08	5001	4.90	75.80	6.30	92	92
16	4.13	3.82	27.05	25.00	23.94	22.14	5158	4.80	76.00	6.30	96	97
17	4.12	3.79	30.78	28.34	25.87	23.82	5192	4.70	76.10	6.40	98	98
18	4.85	4.56	26.41	24.78	27.65	25.99	4860	5.00	73.90	6.10	80	93
19	5.40	5.06	21.66	20.28	28.21	26.41	4805	5.00	73.80	6.20	84	90
20	5.20	4.91	23.68	22.38	27.58	26.06	4806	5.10	73.70	6.10	86	87
21	4.75	4.49	24.49	23.11	27.31	25.79	4801	5.10	73.30	6.10	85	86
22	4.49	4.25	27.65	26.18	24.68	23.38	4701	5.20	72.80	6.00	83	84
23	3.93	3.75	26.13	24.90	24.84	23.69	4658	5.30	72.50	5.90	81	83
24	3.51	3.34	21.79	20.72	25.99	24.74	4537	5.20	72.20	5.90	80	80
25	3.33	3.19	20.20	19.33	26.12	25.00	4473	5.30	72.50	5.90	79	78
26	3.17	3.02	24.10	22.94	26.16	24.92	4559	5.30	72.90	6.00	82	80
27	3.12	2.93	22.17	20.72	26.15	24.57	4741	5.00	73.20	6.10	87	85
28	3.14	2.96	24.01	22.56	26.60	25.08	4731	5.10	73.30	6.10	86	85
29	3.73	3.54	21.32	20.18	27.09	25.69	4681	5.20	72.70	6.00	86	82
30	3.37	3.22	20.61	19.66	26.57	25.41	4513	5.30	70.80	5.90	81	77
最大值	5.4	5.1	32.6	30.5	28.8	29.8	5192	6.3	76.1	6.5	98	98
最小值	2.4	2.3	19.2	18.6	20.1	19.2	2299	4.7	70.8	5.1	73	69
平均	3.5	3.3	24.4	23.1	25.0	23.7	4446	5.2	73.7	5.9	84	84