

# 深圳妈湾电力有限公司2022年11月#1烟囱烟气数据

浓度单位 (mg/m<sup>3</sup>) 烟气量单位 万立方米/天

日期	颗粒物		二氧化硫		氮氧化物		烟气量	氧量%	温度℃	湿度%	机组负荷率 (%)		
	标志	折算	标志	折算	标志	折算					#1机组	#2机组	
1	3.28	3.84	8.03	9.15	20.59	24.01	2006	8.18	70.02	5.37	60	机组停运	
2	3.45	3.78	11.93	12.85	22.81	25.01	2205	7.30	71.79	5.54	72	机组停运	
3	3.35	3.61	14.36	15.04	24.45	26.25	2166	7.03	72.90	5.66	73	机组停运	
4	3.52	3.85	14.60	15.69	25.06	27.50	2208	7.31	73.55	5.55	74	机组停运	
5	3.19	3.50	12.41	13.24	24.56	26.94	2072	7.32	71.91	5.09	68	机组停运	
6	3.16	3.51	9.16	9.88	25.26	28.07	1893	7.49	70.59	4.76	62	机组停运	
7	2.98	3.12	15.52	15.53	26.79	27.96	2087	6.60	70.88	5.22	73	机组停运	
8	2.86	3.25	8.21	9.03	24.43	27.65	1899	7.75	68.86	4.79	61	机组停运	
9	2.91	3.26	11.23	12.34	22.31	25.03	1915	7.61	71.11	4.93	62	机组停运	
10	2.91	3.23	14.38	15.63	22.25	24.68	2076	7.47	71.86	5.33	69	机组停运	
11	2.89	3.25	16.02	17.58	22.09	24.82	1968	7.64	71.74	5.36	65	机组停运	
12	2.97	3.26	9.97	10.71	21.19	23.24	2021	7.30	71.85	5.31	68	机组停运	
13	3.12	3.38	13.28	13.87	21.84	23.49	2000	7.06	72.24	5.43	68	机组停运	
14	2.89	3.24	11.41	12.35	20.83	23.28	1918	7.58	70.54	5.45	64	机组停运	
15	3.10	3.47	15.31	16.74	19.60	21.94	2011	7.61	71.36	5.49	67	机组停运	
16	3.00	3.66	11.26	13.53	19.93	24.31	1773	8.69	69.86	5.20	52	机组停运	
17	3.12	3.48	20.05	21.67	19.45	21.86	2080	7.55	71.82	5.58	69	机组停运	
18	3.17	4.37	11.95	15.80	19.25	25.70	3230	9.67	68.05	5.27	70	14: 23机组并网	
19	3.11	3.57	8.95	10.17	22.02	25.30	3706	7.91	71.61	5.57	58		
20	3.35	4.18	4.53	5.59	20.73	25.61	1821	8.87	68.29	5.19	1: 38机组停运	48	
21	3.31	3.78	10.94	11.89	25.63	28.97	2005	7.77	69.90	5.55	机组停运	63	
22											机组停运		
23											11: 12机组并网		
24	3.35	3.77	13.78	15.29	18.77	21.15	1898	7.69	70.68	5.86	60	机组停运	
25	3.05	4.00	10.32	12.78	19.88	25.33	3380	9.05	68.55	5.22	64	8: 48机组并网	
26	3.59	4.03	8.00	8.95	20.02	22.65	3582	7.70	71.62	5.29	57	55	
27	2.81	3.24	8.92	10.25	21.28	24.51	3520	7.98	71.96	5.48	51	55	
28	2.79	3.18	7.60	8.60	22.55	25.62	3527	7.79	72.58	5.55	48	61	
29	2.88	3.23	6.68	7.45	23.01	25.76	3510	7.60	73.19	5.78	48	64	
30	2.75	3.05	10.24	11.14	22.82	25.28	3921	7.42	72.23	5.67	63	64	
最大值	3.6	4.4	20.1	21.7	26.8	29.0	3921	9.7	73.6	5.9	74	64	
最小值	2.8	3.1	4.5	5.6	18.8	21.2	1773	6.6	68.1	4.8	48	48	
平均	3.1	3.5	11.4	12.6	22.1	25.1	2443	7.7	71.1	5.4	63	59	



# 深圳妈湾电力有限公司2022年11月#2烟窗烟气数据

浓度单位: (mg/Nm<sup>3</sup>)

烟气量单位: 万立方米/天

日期	颗粒物		二氧化硫		氮氧化物		烟气量	氧量%	温度℃	湿度%	#3机组 机组停运	#4机组 机组负荷率 (%)
	标志	折算	标志	折算	标志	折算						
1	4.62	4.58	14.61	14.25	21.11	20.97	1680	5.91	72.18	4.24	15:17机组并网	58
2	4.58	5.05	15.00	15.90	19.91	21.46	3491	6.99	71.45	4.37		72
3	3.91	3.74	19.45	18.39	23.44	22.37	4407	5.31	75.06	4.60	70	70
4	3.77	3.61	16.74	15.88	25.25	24.11	4334	5.32	75.59	4.68	71	70
5	3.62	3.51	15.01	14.37	24.91	24.18	4183	5.57	74.68	4.54	67	66
6	3.24	3.21	11.71	11.36	24.28	23.98	3778	5.84	71.88	4.29	59	59
7	3.53	3.37	16.34	15.40	25.20	24.11	4363	5.34	72.50	4.52	72	70
8	3.36	3.31	13.72	13.30	21.95	21.63	3968	5.78	71.33	4.23	63	63
9	3.26	3.22	16.87	16.41	19.84	19.57	3949	5.81	72.68	4.31	62	62
10	3.44	3.33	17.08	16.40	20.41	19.76	4232	5.53	73.50	4.48	68	68
11	3.46	3.39	15.48	14.89	20.26	19.81	4053	5.67	74.42	4.67	65	66
12	3.67	3.55	18.32	17.48	20.42	19.76	4338	5.51	74.65	4.72	69	72
13	3.43	3.33	18.00	17.17	20.60	19.97	4308	5.55	74.42	4.77	69	70
14	3.54	3.47	17.13	16.48	20.57	20.18	4125	5.71	73.55	4.69	65	66
15	3.86	3.77	18.89	18.17	22.11	21.64	4218	5.67	73.54	4.73	66	68
16	4.03	4.11	12.98	13.09	19.69	20.06	3542	6.29	73.66	4.50	52	53
17	4.67	4.47	20.90	19.72	21.03	20.22	4356	5.41	74.94	4.91	70	70
18	4.45	4.26	22.55	21.41	20.96	20.06	4548	5.33	75.53	4.99	72	74
19	3.77	3.80	20.06	20.13	19.92	20.11	3770	6.14	73.51	4.61	55	56
20	3.74	3.86	13.38	13.79	20.28	20.90	3345	6.45	73.35	4.46	47	47
21	4.32	4.21	19.73	19.04	21.58	21.04	4184	5.62	74.95	4.87	64	65
22	4.30	4.12	21.45	20.35	21.85	21.01	4357	5.40	74.84	4.96	68	69
23	4.17	4.05	23.39	22.61	21.57	20.97	4356	5.58	74.45	4.87	66	68
24	3.94	3.84	26.71	25.94	21.82	21.30	4239	5.65	73.78	4.76	65	65
25	4.01	3.90	21.01	20.19	21.83	21.28	4309	5.63	73.98	4.77	66	66
26	3.59	3.62	14.48	14.48	21.06	21.24	3773	6.13	72.94	4.58	55	55
27	3.61	3.66	13.88	14.03	20.86	21.19	3641	6.24	73.23	4.50	53	53
28	3.84	3.78	15.98	15.58	22.79	22.39	4047	5.76	75.20	4.76	62	62
29	3.79	3.73	14.51	14.14	21.91	21.55	4065	5.76	75.40	4.88	63	62
30	3.66	3.58	17.00	16.38	22.08	21.58	4114	5.68	74.83	4.80	62	64
最大值	4.7	5.1	26.7	25.9	25.3	24.2	4548	7.0	75.6	5.0	72	74
最小值	3.2	3.2	11.7	11.4	19.7	19.6	1680	5.3	71.3	4.2	47	47
平均	3.8	3.8	17.4	16.9	21.6	21.3	4002	5.8	73.9	4.6	64	64



# 深圳妈湾电力有限公司2022年11月#3烟卤烟气数据

浓度单位: (mg/m<sup>3</sup>) 烟量单位: 万立方米/天

日期	颗粒物		二氧化硫		氮氧化物		烟气量	氧含量%	温度℃	湿度%	机组负荷率 (%)	
	标志	折算	标志	折算	标志	折算					#5机组	#6机组
	#3烟卤停运											
1											机组停运	机组停运
2											机组停运	机组停运
3											机组停运	机组停运
4											机组停运	机组停运
5											机组停运	机组停运
6											机组停运	机组停运
7											机组停运	12: 10机组并网
8	2.49	3.00	9.65	11.27	18.69	22.60	2593	8.55	55.66	3.26	机组停运	62
9	2.64	3.23	14.10	16.77	19.80	24.19	2385	8.74	56.14	3.28	机组停运	62
10	3.23	3.85	14.37	16.92	19.29	23.27	2109	8.46	58.43	3.51	机组停运	68
11	3.13	3.72	13.29	15.52	19.36	23.44	2035	8.41	58.88	3.52	机组停运	66
12	3.43	4.00	16.35	18.61	18.02	21.05	2183	8.17	59.97	3.73	机组停运	73
13	3.40	3.96	16.22	18.56	19.63	23.04	2163	8.16	59.66	3.78	机组停运	73
14	3.08	3.63	18.03	20.92	19.91	23.43	2031	8.31	58.61	3.62	机组停运	67
15	3.48	4.09	18.06	20.91	17.98	21.18	2108	8.32	59.24	3.73	机组停运	70
16	2.87	3.54	9.82	11.91	16.85	20.91	1836	8.89	57.09	3.44	机组停运	56
17	3.27	3.72	16.39	18.19	20.81	23.72	2063	7.92	60.03	3.91	机组停运	72
18	4.03	4.46	15.93	17.46	23.79	26.35	1999	7.47	61.66	4.01	机组停运	81
19	3.07	3.43	10.79	11.88	21.23	23.63	1608	7.54	61.88	3.77	机组停运	50
20	3.00	3.44	6.85	7.87	19.14	22.03	1441	7.91	61.41	3.62	机组停运	48
21	3.48	3.76	18.53	19.87	22.37	24.22	1779	7.16	63.01	3.99	机组停运	67
22	3.72	3.93	21.23	22.36	21.14	22.47	1819	6.88	63.57	4.05	机组停运	70
23	3.62	3.79	21.36	22.33	24.15	25.32	1769	6.69	64.47	4.16	机组停运	70
24	3.42	3.89	17.86	19.67	21.11	23.47	2068	7.49	62.70	4.01	机组停运	68
25	3.59	4.70	15.61	20.07	17.26	22.69	2583	9.49	57.51	3.83	机组停运	69
26	3.06	3.95	12.70	15.37	22.84	28.59	2026	8.89	62.09	3.59	机组停运	57
27	2.54	2.81	16.32	18.02	22.31	24.69	1437	7.40	64.56	3.77	机组停运	51
28	3.12	3.61	14.00	15.82	22.96	26.24	2691	7.82	65.58	3.89	11: 43机组并网	63
29	3.25	3.26	16.76	16.59	19.71	19.87	3548	6.06	70.31	4.20	64	63
30	3.12	3.12	19.15	18.89	23.45	23.67	3716	6.02	69.96	4.56	66	67
最大值	4.0	4.7	21.4	22.4	24.2	28.6	3716	9.5	70.3	4.6	66	81
最小值	2.5	2.8	6.9	7.9	16.9	19.9	1437	6.0	55.7	3.3	64	48
平均	3.2	3.7	15.4	17.2	20.5	23.5	2173	7.9	61.4	3.8	65	65