

深圳妈湾电力有限公司2022年12月#1烟囱烟气数据

浓度单位: mg/m³ 烟气量单位: 万立方米/天

#1烟囱排放口

机组负荷率 (%)

日期	颗粒物		二氧化硫		氮氧化物		烟气量	氧量%	温度℃	湿度%	#1机组	#2机组
	标志	折算	标志	折算	标志	折算						
1	3.0	3.2	10.3	10.8	19.7	20.9	3957	6.9	69.2	5.0	59	65
2	4.4	4.9	4.8	5.2	21.0	23.0	3290	7.3	68.1	4.4	18: 36机组停运	56
3	5.3	5.7	4.9	5.2	25.2	27.3	1975	7.1	67.9	4.6	机组停运	59
4											机组停运	1: 28机组停运
5											机组停运	机组停运
6											机组停运	机组停运
7											机组停运	机组停运
8											机组停运	机组停运
9											机组停运	机组停运
10											机组停运	机组停运
11											机组停运	机组停运
12											机组停运	机组停运
13											机组停运	机组停运
14											机组停运	机组停运
15											12: 27并网发电	18: 22并网发电
16	3.2	3.3	6.4	6.5	23.9	24.6	4191	6.4	69.0	3.7	70	70
17	3.8	4.1	3.0	3.2	22.0	23.9	3940	7.2	67.1	3.3	62	60
18	3.7	4.1	3.1	3.3	21.0	23.0	3844	7.3	66.2	2.9	58	58
19	4.6	5.6	2.9	3.4	18.1	21.9	3194	8.6	67.9	2.7	70	9: 45机组停运
20	2.3	3.4	4.7	5.7	19.7	27.4	2855	10.2	61.2	2.7	71	机组停运
21	2.2	2.9	4.1	5.3	19.3	25.8	2433	9.8	62.1	2.6	63	机组停运
22	2.0	2.8	2.8	3.8	17.5	24.0	2362	10.1	61.1	2.1	60	机组停运
23	2.1	2.8	2.9	3.6	18.9	24.8	2233	9.5	62.1	2.2	60	机组停运
24	2.1	2.6	3.6	4.3	20.6	24.9	1958	8.6	64.6	2.3	57	机组停运
25	2.1	2.5	3.4	4.0	22.0	26.5	1884	8.5	64.1	2.3	56	机组停运
26	2.1	2.3	5.7	6.2	23.8	26.5	2005	7.6	66.8	2.6	64	机组停运
27	2.2	2.4	5.3	5.7	21.8	24.4	1952	7.6	66.7	2.7	63	机组停运
28	2.2	2.4	4.3	4.7	21.3	23.4	1860	7.4	67.1	2.8	61	机组停运
29	2.1	2.3	5.4	5.8	22.1	24.7	1883	7.6	66.3	2.6	61	机组停运
30	2.0	2.2	8.1	8.5	23.0	25.3	2026	7.4	66.2	2.6	67	机组停运
31	2.0	2.3	5.2	5.8	22.3	25.6	1966	8.0	65.3	2.5	63	机组停运
最大值	5.3	5.7	10.3	10.8	25.2	27.4	4191	10.2	69.2	5.0	71	70
最小值	2.0	2.2	2.8	3.2	17.5	20.9	1860	6.4	61.1	2.1	56	56
平均	2.8	3.3	4.8	5.3	21.2	24.6	2621	8.0	65.7	3.0	63	61

#1烟囱停运

深圳妈湾电力有限公司2022年12月#2烟囱烟气数据

浓度单位: (mg/m³)

烟气量单位: 万立方米/天

日期	颗粒物		二氧化硫		氮氧化物		烟气量	氧量%	温度℃	湿度%	#3机组	#4机组
	标志	折算	标志	折算	标志	折算						
1	3.4	3.4	19.9	19.4	22.4	22.1	3987	5.8	71.6	4.7	63	56
2	3.3	3.2	17.1	16.7	26.4	25.8	4027	5.7	71.5	4.4	62	61
3	3.3	3.3	13.5	13.2	27.2	26.9	3857	5.9	71.9	4.2	59	58
4	3.3	3.3	9.6	9.8	26.0	26.5	3470	6.3	71.4	4.0	51	51
5	3.5	3.4	16.5	15.9	26.9	26.3	4098	5.7	72.1	4.2	65	61
6	3.3	3.2	17.4	16.8	26.4	25.7	4187	5.6	71.6	4.2	66	63
7	3.5	3.4	12.8	12.3	24.3	23.7	4072	5.6	71.6	3.9	64	63
8	3.5	3.4	9.2	8.9	21.5	21.1	3939	5.7	71.3	3.8	61	61
9	3.5	3.4	10.2	9.8	24.6	23.9	4120	5.6	71.5	3.8	65	64
10	3.4	3.4	7.6	7.5	25.0	24.9	3666	6.0	69.6	3.6	55	56
11	3.3	3.2	7.8	7.6	24.9	24.6	3759	5.8	70.1	3.6	57	57
12	3.2	3.2	8.3	8.0	26.0	25.5	3941	5.7	70.5	3.6	60	60
13	3.3	3.2	17.7	16.7	28.1	27.0	4291	5.4	69.8	3.6	65	70
14	3.2	3.1	12.9	12.3	27.4	26.2	4404	5.4	69.2	3.6	68	69
15	3.2	3.1	15.4	14.4	27.6	25.9	4523	5.3	70.0	3.6	68	70
16	2.9	2.9	13.0	12.8	22.5	22.5	3843	6.0	69.7	3.4	67	47
17	2.9	2.9	9.0	9.1	24.5	24.9	3678	6.2	67.9	3.2	60	47
18	2.9	3.0	8.7	8.8	24.0	24.3	3627	6.2	68.1	3.1	57	48
19	3.3	3.3	6.8	6.8	24.8	25.0	3823	6.1	68.9	3.1	64	49
20	3.8	3.8	9.9	9.6	29.7	29.4	3922	5.9	70.6	3.1	66	52
21	3.0	3.1	9.2	9.3	27.2	27.6	3674	6.2	69.1	3.0	60	47
22	3.2	3.3	6.8	6.9	24.3	24.7	3630	6.3	69.6	2.9	58	48
23	3.3	3.4	6.6	6.6	22.2	22.4	3582	6.2	69.6	2.9	57	47
24	3.5	4.0	6.7	7.7	24.1	27.7	1970	8.0	67.1	2.6	55	1: 40机组停运
25	3.2	3.8	6.1	7.1	23.2	27.6	2048	8.4	64.1	2.3	56	机组停运
26	3.6	4.1	11.8	13.0	24.4	27.7	2356	7.8	65.0	2.7	66	机组停运
27	3.7	4.2	8.5	9.5	24.4	28.0	2195	7.9	63.4	2.6	62	机组停运
28	2.7	3.1	7.1	8.1	23.2	26.9	2188	8.0	63.4	2.6	62	机组停运
29	3.0	3.5	9.1	10.2	22.2	25.9	2179	8.2	62.6	2.3	61	机组停运
30	3.1	3.6	11.3	12.6	19.7	22.8	2328	7.9	61.5	2.4	66	机组停运
31	3.0	3.4	7.1	8.1	15.9	18.4	2192	8.1	60.7	2.3	62	机组停运
最大值	3.8	4.2	19.9	19.4	29.7	29.4	4523	8.4	72.1	4.7	68	70
最小值	2.7	2.9	6.1	6.6	15.9	18.4	1970	5.3	60.7	2.3	51	47
平均	3.3	3.4	10.8	10.8	24.5	25.2	3470	6.4	68.5	3.3	62	57

深圳妈湾电力有限公司2022年12月#3烟囱烟气数据

浓度单位: (mg/m³)

烟气量单位: 万立方米/天

日期	颗粒物		二氧化硫		氮氧化物		烟气量	氧量%	温度℃	湿度%	#5机组	#6机组
	标志	折算	标志	折算	标志	折算						
1	2.9	3.0	19.5	19.2	24.6	24.7	3720	6.0	66.6	4.1	60	63
2	3.0	3.0	20.0	19.7	25.4	25.5	3938	6.0	66.0	3.9	62	62
3	3.0	3.0	17.4	17.2	23.5	23.6	3837	6.0	67.1	3.8	63	60
4	3.0	3.1	11.7	12.2	25.3	26.5	3429	6.7	66.2	3.5	50	51
5	3.0	3.0	19.5	19.0	23.6	23.5	4015	5.9	67.1	3.8	65	65
6	2.9	2.9	14.5	14.0	26.0	25.7	4041	5.7	66.4	3.6	66	67
7	3.0	3.0	18.8	18.5	25.2	25.3	4015	6.1	66.7	3.5	64	65
8	3.0	3.0	13.2	13.1	25.6	25.9	3777	6.1	67.0	3.4	59	62
9	3.0	3.0	17.5	17.0	24.6	24.6	3879	5.9	67.2	3.5	64	63
10	2.9	3.0	11.7	11.8	26.4	27.0	3683	6.3	66.3	3.3	57	58
11	2.9	3.0	7.9	7.9	24.7	25.2	3651	6.2	65.4	3.2	58	58
12	3.0	3.1	7.5	7.5	24.2	24.8	3779	6.3	65.8	3.2	58	60
13	2.9	2.9	14.1	13.6	24.0	23.6	4100	5.7	65.6	3.4	67	69
14	2.8	2.7	12.5	12.0	23.4	23.1	4099	5.8	64.0	3.3	68	68
15	2.8	2.7	11.4	11.0	24.6	24.0	4228	5.7	64.8	3.2	71	71
16	2.8	2.8	9.7	9.4	22.3	22.0	4079	5.8	65.7	3.2	68	68
17	2.8	2.8	5.2	5.2	24.7	24.9	3812	6.1	64.3	2.9	60	60
18	3.0	3.0	8.5	8.4	23.4	23.6	3721	6.1	64.1	2.7	58	58
19	2.9	2.9	10.4	10.1	23.3	23.4	4015	5.9	65.2	2.8	65	65
20	2.9	2.9	11.1	10.8	24.0	24.1	4094	6.0	66.0	2.8	64	70
21	3.1	3.1	3.8	3.8	23.5	23.7	3708	6.0	65.5	2.7	60	60
22	3.0	3.0	4.2	4.1	23.0	23.2	3603	6.1	64.6	2.6	58	58
23	2.8	2.8	5.4	5.3	24.7	24.9	3620	6.1	64.0	2.6	58	58
24	3.0	3.1	5.0	5.1	20.6	21.3	3687	6.4	65.0	2.5	58	56
25	2.9	2.9	5.6	5.6	24.1	24.6	3634	6.2	65.0	2.4	56	56
26	2.5	2.5	7.6	7.5	22.8	22.8	3961	5.9	65.2	2.6	64	65
27	2.6	2.5	9.7	9.5	22.5	22.3	3904	5.9	65.4	2.5	63	64
28	2.5	2.5	8.9	8.9	24.7	25.0	3829	6.1	65.3	2.5	59	62
29	2.5	2.5	8.0	7.9	21.6	21.7	3837	6.0	65.0	2.5	61	62
30	2.5	2.5	12.5	12.1	24.2	23.8	4134	5.7	65.1	2.6	68	68
31	2.5	2.5	11.4	11.1	24.3	24.1	4022	5.8	64.5	2.5	66	66
最大值	3.1	3.1	20.0	19.7	26.4	27.0	4228	6.7	67.2	4.1	71	71
最小值	2.5	2.5	3.8	3.8	20.6	21.3	3429	5.7	64.0	2.4	50	51
平均	2.9	2.9	11.1	10.9	24.0	24.1	3866	6.0	65.5	3.1	62	63

机组负荷率 (%)