

HJ/T76-2017

烟气连续监测日平均值月报表

排放源名称：深能洪湾电厂
排放源编号：3#锅炉

监测月份：2023 年 1 月

日期	颗粒物			SO2			NOx			CO2	流量	O2	温度	水分	负荷	备注
	mg/Nm3	折算 mg/Nm3	t/d	mg/Nm3	折算 mg/Nm3	t/d	mg/Nm3	折算 mg/Nm3	t/d	%	X1000 Nm3/d	%	℃	含量%	MW	
1 日	0	0	0	1	1	0	1	1	0	0	0	21	47	1		停机备用
2 日	0	0	0	1	1	0	1	1	0	0	0	21	46	1		停机备用
3 日	0	0	0	1	1	0	1	1	0	0	0	21	38	1		停机备用
4 日	0.103	0.113	0.001	0.19	0.21	0.00	15.570	17.804	0.3973	0	1196.504	18	73	2		
5 日	0.121	0.124	0.001	0.31	0.32	0.00	10.968	11.819	0.2699	0	753.7316	19	76	3		
6 日	0.123	0.127	0.000	0.56	0.56	0.00	9.0344	10.414	0.2102	0	624.2994	20	74	3		
7 日	0	0	0	1	1	0	0	0	0	0	0	21	61	1		停机备用
8 日	0	0	0	0	0	0	0	0	0	0	0	21	57	1		停机备用
9 日	0	0	0	1	1	0	0	0	0	0	0	21	52	1		停机备用
10 日	0	0	0	1	1	0	1	1	0	0	0	21	43	2		停机备用
11 日	0	0	0	1	1	0	1	1	0	0	0	21	41	2		停机备用
12 日	0	0	0	0	0	0	1	1	0	0	0	21	37	2		停机备用
13 日	0	0	0	0	0	0	0	0	0	0	0	21	34	2		停机备用
14 日	0	0	0	0	0	0	0	0	0	0	0	21	34	2		停机备用
15 日	0	0	0	1	1	0	0	0	0	0	0	21	29	1		停机备用
16 日	0	0	0	1	1	0	0	0	0	0	0	21	20	1		停机备用
17 日	0	0	0	1	1	0	1	1	0	0	0	21	19	1		停机备用
18 日	0	0	0	2	2	0	1	1	0	0	0	21	19	1		停机备用
19 日	0	0	0	1	1	0	1	1	0	0	0	21	21	1		停机备用
20 日	0	0	0	1	1	0	1	1	0	0	0	21	21	1		停机备用
21 日	0	0	0	0	1	0	1	1	0	0	0	21	21	1		停机备用
22 日	0	0	0	0	0	0	0	0	0	0	0	21	22	1		停机备用
23 日	0	0	0	1	1	0	1	1	0	0	0	21	22	1		停机备用
24 日	0	0	0	1	1	0	1	1	0	0	0	21	19	1		停机备用
25 日	0	0	0	1	1	0	2	2	0	0	0	21	16	1		停机备用
26 日	0	0	0	1	1	0	2	2	0	0	0	21	18	1		停机备用
27 日	0	0	0	1	1	0	1	1	0	0	0	21	17	1		停机备用
28 日	0	0	0	2	2	0	2	2	0	0	0	21	16	1		停机备用
29 日	0	0	0	2	2	0	2	2	0	0	0	21	15	1		停机备用
30 日	0	0	0	2	2	0	3	3	0	0	0	21	16	1		停机备用
31 日	0	0	0	0	0	0	1	1	0	0	0	21	16	1		停机备用
平均值	0.175	0.176	0.000	0.90	0.90	0.00	1.9815	2.1256	0.0283	0	83.0495	21	34	1		
最大值	0.331	0.331	0.001	2.45	2.45	0.00	15.570	17.804	0.3973	0	1196.504	21	76	3		
最小值	0.061	0.061	0.000	0.19	0.21	0.00	0.2211	0.2207	0.0000	0	0.0000	18	15	1		
样本数	31	31	31	31	31	31	31	31	31	31	31	31	31	31		
月排放 总量(t)			0.003			0.004			0.8775		2574.5356					

烟气月排放总量单位：x1000m3/m

HJ/T76-2017

烟气连续监测日平均值月报表

排放源名称：深能洪湾电厂

排放源编号：4#锅炉

监测月份：2023 年 1 月

日期	颗粒物			SO2			NOx			CO2	流量	O2	温度	水分	负荷	备注
	mg/Nm3	折算 mg/Nm3	t/d	mg/Nm3	折算 mg/Nm3	t/d	mg/Nm3	折算 mg/Nm3	t/d	%	X1000 Nm3/d	%	℃	含量%	MW	
1 日	0	0	0	1	1	0	1	1	0	0	0	21	59	1		停机备用
2 日	0	0	0	1	1	0	1	1	0	0	0	21	51	1		停机备用
3 日	0.046	0.050	0.0003	0.73	0.786	0.001	5.2607	7.150	0.1047	0	629.6716	19	62	1		
4 日	0	0	0	1	1	0	1	1	0	0	0	21	63	1		停机备用
5 日	0	0	0	1	1	0	1	1	0	0	0	21	56	1		停机备用
6 日	0	0	0	2	2	0	1	1	0	0	0	21	50	1		停机备用
7 日	0	0	0	1	1	0	1	1	0	0	0	21	45	1		停机备用
8 日	0	0	0	1	1	0	1	1	0	0	0	21	40	1		停机备用
9 日	0	0	0	1	1	0	1	1	0	0	0	21	34	1		停机备用
10 日	0	0	0	1	1	0	1	1	0	0	0	21	28	1		停机备用
11 日	0.059	0.065	0.0004	1.59	1.690	0.002	4.3744	5.980	0.0809	0	637.1960	20	50	1		
12 日	0	0	0	1	1	0	1	1	0	0	0	21	61	1		停机备用
13 日	0	0	0	2	2	0	1	1	0	0	0	21	55	1		停机备用
14 日	0	0	0	1	1	0	1	1	0	0	0	21	50	1		停机备用
15 日	0	0	0	1	1	0	1	1	0	0	0	21	44	1		停机备用
16 日	0	0	0	3	3	0	1	1	0	0	0	21	32	1		停机备用
17 日	0	0	0	2	2	0	1	1	0	0	0	21	28	1		停机备用
18 日	0	0	0	1	1	0	1	1	0	0	0	21	26	1		停机备用
19 日	0	0	0	1	1	0	1	1	0	0	0	21	26	1		停机备用
20 日	0	0	0	1	1	0	1	1	0	0	0	21	26	1		停机备用
21 日	0	0	0	1	1	0	1	1	0	0	0	21	25	1		停机备用
22 日	0	0	0	1	1	0	1	1	0	0	0	21	25	1		停机备用
23 日	0	0	0	1	1	0	1	1	0	0	0	21	25	1		停机备用
24 日	0	0	0	3	3	0	1	1	0	0	0	21	21	1		停机备用
25 日	0	0	0	2	2	0	1	1	0	0	0	21	19	1		停机备用
26 日	0	0	0	1	1	0	1	1	0	0	0	21	20	1		停机备用
27 日	0	0	0	2	2	0	1	1	0	0	0	21	19	1		停机备用
28 日	0	0	0	1	1	0	1	1	0	0	0	21	17	0		停机备用
29 日	0	0	0	1	1	0	1	1	0	0	0	21	17	0		停机备用
30 日	0	0	0	1	1	0	1	1	0	0	0	21	18	1		停机备用
31 日	0	0	0	1	1	0	1	1	0	0	0	21	18	1		停机备用
平均值	0.055	0.055	0.0000	1.28	1.289	0.000	1.2575	1.370	0.0060	0	40.8669	21	36	1		
最大值	0.080	0.080	0.0004	2.90	2.908	0.002	5.2607	7.150	0.1047	0	637.1960	21	63	1		
最小值	0.039	0.039	0.0000	0.53	0.531	0.000	0.6139	0.614	0.0000	0	0.0000	19	17	0		
样本数	31	31	31	31	31	31	31	31	31	31	31	31	31	31		
月排放 总量(t			0.0007			0.0041			0.1856		1266.8735					

烟气月排放总量单位：x1000m3/m