

深圳妈湾电力有限公司2022年4月#1烟卤烟气数据

浓度单位: (mg/Nm³) 烟量单位: 万立方米/天

日期	颗粒物		二氧化硫		氮氧化物		烟气量	氧量%	温度℃	湿度%	机组负荷率 (%)	
	标志	折算	标志	折算	标志	折算					#1机组	#2机组
1	2.47	2.69	8.31	8.73	25.48	27.53	3939	7.16	70.45	4.62	63	63
2	2.48	2.58	11.30	11.37	25.54	26.34	4269	6.53	72.08	5.03	73	72
3	2.46	2.66	7.72	7.90	23.89	25.55	3895	7.08	70.77	4.64	65	63
4	2.40	2.49	9.05	9.10	25.50	26.27	4243	6.51	73.01	5.10	73	73
5	2.34	2.58	6.06	6.54	27.97	30.70	3805	7.34	72.46	5.03	61	61
6	2.32	2.53	3.84	4.07	28.32	30.61	3811	7.15	72.40	5.11	62	62
7	2.33	2.52	2.51	2.65	27.09	29.09	3949	7.08	71.39	4.87	64	65
8	2.40	2.59	3.23	3.41	27.60	29.65	3906	7.05	71.52	4.80	62	64
9	2.44	2.73	4.10	4.52	24.15	26.96	3666	7.57	68.81	4.36	55	55
10	2.45	2.71	4.72	5.14	25.09	27.69	3756	7.42	70.02	4.60	58	58
11	2.50	2.61	10.26	10.30	27.84	28.70	4228	6.55	72.27	4.96	71	72
12	2.39	2.59	10.80	11.41	25.21	27.15	3773	7.11	71.20	4.76	62	23: 47机组停运
13	2.52	2.71	10.78	11.05	24.99	26.37	2177	6.84	73.65	5.31	73	机组停运
14	2.26	2.64	6.23	7.11	22.29	25.85	2008	8.10	69.55	4.60	59	机组停运
15	2.45	2.57	7.85	8.14	23.29	24.46	2166	6.72	75.42	5.27	73	机组停运
16	2.71	2.83	12.89	13.04	24.99	25.91	2002	6.55	75.01	5.11	68	机组停运
17	2.60	2.55	15.00	14.46	27.27	26.65	2326	5.68	78.09	5.76	84	机组停运
18	3.19	3.35	10.11	10.73	23.53	24.72	2789	6.73	76.91	5.94	95	机组停运
19	2.49	2.64	9.06	9.55	24.52	25.63	2527	6.68	75.29	5.54	85	机组停运
20	2.85	3.10	8.31	8.81	23.06	24.83	2416	7.09	73.73	5.34	80	机组停运
21	2.34	2.75	3.16	3.59	20.40	23.98	2269	8.24	70.71	5.05	68	机组停运
22	2.15	2.61	2.53	3.02	19.98	24.02	2121	8.56	68.30	4.75	61	机组停运
23	2.13	2.66	3.46	4.27	17.83	22.19	2030	8.98	68.51	4.66	55	机组停运
24	2.16	2.64	6.46	7.29	19.54	23.46	2253	8.54	69.36	4.86	63	机组停运
25	2.30	2.77	4.16	4.78	21.15	25.24	2250	8.16	70.52	4.78	61	机组停运
26	2.25	2.44	3.55	3.81	21.31	23.03	1824	7.14	73.23	4.53	57	机组停运
27	2.43	3.05	2.06	2.31	21.15	26.32	3067	8.55	72.32	4.58	56	14: 14机组并网
28	2.30	2.34	2.12	2.11	24.66	25.03	4088	6.22	77.43	5.14	69	69
29	2.49	2.64	2.11	2.22	23.49	24.76	3834	6.78	75.12	5.13	63	63
30	2.80	3.11	4.54	5.04	25.05	27.82	3332	7.49	72.56	4.92	50	51
最大值	3.2	3.4	15.0	14.5	28.3	30.7	4269	9.0	78.1	5.9	95	73
最小值	2.1	2.3	2.1	2.1	17.8	22.2	1824	5.7	68.3	4.4	50	51
平均	2.4	2.7	6.5	6.9	24.1	26.2	3091	7.3	72.4	5.0	66	64

深圳妈湾电力有限公司2022年4月#2烟卤烟气数据

浓度单位: mg/m³ 烟卤量单位: 万立方米/天

日期	颗粒物		二氧化硫		氮氧化物		烟气量	氧量%	温度℃	湿度%	#3机组	#4机组
	标志	折算	标志	折算	标志	折算						
1	2.60	2.61	8.53	8.51	21.33	21.37	3985	6.04	71.76	3.92	72	47
2	2.65	2.61	9.69	9.46	22.20	21.90	4159	5.81	72.79	4.06	75	51
3	2.65	2.55	8.19	7.71	23.95	22.97	4427	5.40	73.83	4.21	72	68
4	2.64	2.52	6.82	6.43	25.10	23.96	4670	5.34	75.44	4.34	75	73
5	2.50	2.47	5.06	4.95	24.11	23.71	4166	5.77	74.92	4.18	65	64
6	2.45	2.42	3.83	3.74	24.99	24.55	4111	5.79	74.84	4.28	65	63
7	2.48	2.50	2.86	2.87	23.06	23.21	3889	6.12	72.69	4.07	66	50
8	2.47	2.50	3.20	3.23	22.89	23.13	3861	6.17	72.73	4.17	65	49
9	2.40	2.55	6.61	7.39	21.49	22.75	3032	6.83	72.00	4.00	58	15: 23机组停运
10	2.11	2.49	2.89	3.39	19.33	22.82	2181	8.29	70.97	3.68	60	机组停运
11	2.18	2.38	8.04	8.38	22.01	23.78	2428	7.16	73.32	4.18	74	机组停运
12	2.67	2.93	8.03	8.50	23.09	25.29	2229	7.30	68.27	4.08	67	机组停运
13	2.59	2.80	11.45	11.90	24.95	26.91	2429	7.10	70.64	4.40	74	机组停运
14	3.05	3.57	6.42	6.96	27.46	30.66	3551	7.47	69.01	4.06	62	10: 00机组并网
15	2.75	2.62	11.13	10.42	29.07	27.63	4731	5.24	77.06	4.62	77	75
16	3.07	2.97	17.56	16.79	27.56	26.58	4361	5.47	77.53	4.57	69	70
17	2.81	2.61	15.56	14.44	30.49	28.29	5044	4.84	79.26	5.05	85	85
18	2.68	2.45	11.99	10.95	30.27	27.62	5224	4.56	79.44	5.29	89	87
19	2.56	2.38	11.99	11.13	30.77	28.59	5126	4.85	76.98	5.29	84	87
20	2.59	2.42	14.76	13.80	30.61	28.65	5197	4.98	78.18	5.33	86	86
21	2.49	2.34	5.45	5.11	30.15	28.36	5062	5.06	78.65	5.27	83	84
22	2.36	2.24	5.76	5.47	29.57	28.11	4832	5.23	78.05	5.18	78	79
23	2.40	2.31	9.69	9.22	28.97	27.87	4568	5.42	78.61	5.16	73	72
24	2.51	2.39	12.16	11.46	29.39	27.93	4732	5.23	79.12	5.22	76	77
25	2.37	2.29	6.50	6.21	27.37	26.37	4585	5.46	76.53	4.97	72	74
26	2.44	2.37	4.76	4.58	25.91	25.06	4289	5.51	76.52	4.72	67	68
27	2.46	2.40	3.01	2.93	26.58	25.92	4390	5.63	77.04	4.81	67	70
28	2.55	2.49	1.93	1.88	27.43	26.83	4053	5.68	77.58	4.79	23: 56机组停运	77
29	2.91	2.93	3.62	3.68	21.96	21.97	2413	6.04	76.67	5.07	机组停运	80
30	3.57	3.91	6.19	6.71	16.85	18.36	1600	7.24	70.32	4.09	机组停运	52
最大值	3.6	3.9	17.6	16.8	30.8	30.7	5224	8.3	79.4	5.3	89	87
最小值	2.1	2.2	1.9	1.9	16.9	18.4	1600	4.6	68.3	3.7	58	47
平均	2.6	2.6	7.8	7.6	25.6	25.4	3978	5.9	75.0	4.6	72	70

机组负荷率 (%)

深圳妈湾电力有限公司2022年4月#3烟卤烟气数据

浓度单位: mg/m³ 烟量单位: 万立方米/天

#3烟卤排放口

机组负荷率 (%)

日期	颗粒物		二氧化硫		氮氧化物		烟气量	氧量%	温度℃	湿度%	#5机组	#6机组
	标志	折算	标志	折算	标志	折算						
1	3.02	2.87	18.84	17.84	24.68	23.55	4008	5.24	71.34	3.67	72	72
2	3.10	2.92	17.04	15.94	24.65	23.25	4290	5.08	72.57	3.86	78	79
3	3.05	2.89	17.20	16.11	23.74	22.54	4097	5.21	73.01	3.78	74	75
4	3.04	2.88	12.36	11.58	21.84	20.79	4273	5.18	74.32	3.94	78	78
5	2.86	2.77	7.25	6.95	24.68	23.87	3697	5.46	73.49	3.77	66	65
6	2.78	2.72	9.15	8.78	24.65	24.17	3770	5.64	73.51	3.92	66	67
7	2.73	2.64	7.63	7.24	22.19	21.46	3936	5.49	72.40	4.00	68	70
8	2.68	2.61	7.68	7.34	22.19	21.70	3867	5.58	72.60	3.91	67	68
9	2.67	2.67	6.58	6.46	21.23	21.22	3613	5.93	71.09	3.69	60	60
10	2.65	2.60	5.39	5.20	20.31	19.88	3645	5.62	72.20	3.76	62	63
11	2.79	2.68	11.66	10.96	23.43	22.43	4212	5.36	74.80	4.13	76	77
12	2.86	2.77	11.55	10.96	24.13	23.34	3889	5.50	73.21	3.96	69	69
13	2.76	2.64	8.32	7.88	23.22	22.18	4019	5.29	74.04	3.98	76	70
14	2.71	2.64	4.79	4.62	22.54	21.94	3696	5.58	72.74	3.90	65	65
15	2.71	2.54	8.60	8.00	23.61	22.12	4296	5.02	75.53	4.28	80	81
16	3.07	2.93	6.32	5.98	22.74	21.66	3949	5.28	76.42	4.22	71	73
17	3.16	2.92	18.35	16.85	22.54	20.85	4562	4.79	77.41	4.63	85	88
18	2.98	2.74	29.09	26.71	24.75	22.73	4973	4.67	77.50	4.93	96	97
19	2.94	2.72	21.53	19.89	23.76	21.99	4670	4.79	75.95	4.91	89	89
20	2.83	2.63	22.34	20.73	25.95	24.14	4390	4.88	75.47	4.83	87	79
21	3.00	2.83	11.16	10.45	23.46	22.08	4119	5.07	72.37	4.64	85	69
22	3.52	3.35	8.72	8.25	23.27	22.14	3857	5.24	72.61	4.47	80	61
23	3.07	2.94	5.29	5.06	24.89	23.87	3637	5.37	75.29	4.38	74	55
24	3.04	2.91	13.75	13.00	22.88	21.85	3963	5.33	75.03	4.58	80	63
25	3.00	2.90	10.60	10.06	21.05	20.33	3783	5.49	73.20	4.37	75	60
26	3.00	2.97	7.18	7.01	21.89	21.59	3500	5.80	71.99	4.17	69	50
27	3.23	3.17	10.94	10.41	25.75	25.02	1989	5.58	73.42	4.30	71	1: 14机组停运
28	2.73	2.64	20.23	19.31	26.35	25.34	2178	5.45	74.10	4.38	82	机组停运
29	2.68	2.59	18.59	17.87	22.76	21.97	2219	5.47	74.47	4.44	83	机组停运
30	2.65	2.77	5.24	5.43	21.35	22.33	1562	6.65	70.46	3.74	53	机组停运
最大值	3.5	3.4	29.1	26.7	26.4	25.3	4973	6.7	77.5	4.9	96	97
最小值	2.7	2.5	4.8	4.6	20.3	19.9	1562	4.7	70.5	3.7	53	50
平均	2.9	2.8	12.1	11.4	23.3	22.4	3755	5.4	73.8	4.2	75	71