

深圳妈湾电力有限公司2023年5月#1烟囱烟气数据

浓度单位 (mg/Nm³) 烟量单位 万立方米/天

#1烟囱排放口

日期	颗粒物		二氧化硫		氮氧化物		烟气量	氧量%	温度℃	湿度%	机组负荷率 (%)	
	标志	折算	标志	折算	标志	折算						
1	3.1	3.4	4.8	5.4	24.5	27.3	3368	7.6	73.3	5.1	50	50
2	2.9	3.2	4.4	5.0	22.2	24.9	3391	7.7	73.5	5.2	50	50
3	3.0	3.2	6.1	6.5	23.0	24.9	3593	7.2	75.5	5.4	56	56
4	2.9	3.1	4.6	4.9	23.1	24.8	3501	7.1	75.2	5.6	57	54
5	2.8	3.0	3.0	3.2	22.0	24.0	3529	7.2	74.8	5.9	55	55
6	2.8	2.9	9.5	9.6	23.9	25.0	3999	6.7	75.3	6.2	66	66
7	2.8	2.9	7.6	7.8	21.8	23.1	3817	6.8	73.1	5.8	63	63
8	2.6	2.9	6.2	7.0	24.6	27.7	3287	7.7	70.2	5.3	48	48
9	3.3	4.0	3.4	4.1	22.1	26.6	1914	8.6	67.0	5.0	1: 21机组停运	48
10	3.5	4.2	3.3	4.0	21.2	25.8	1913	8.6	66.5	4.9	机组停运	51
11	2.2	2.6	4.1	4.9	22.2	26.3	1846	8.3	66.6	4.8	机组停运	50
12	3.1	3.5	3.1	3.6	22.6	25.9	1703	7.9	67.4	4.6	机组停运	48
13	2.9	3.3	4.5	5.1	24.7	27.8	1721	7.6	69.5	4.8	机组停运	50
14	2.7	3.0	4.7	5.2	26.2	29.3	1721	7.6	68.9	4.9	机组停运	50
15	2.6	2.9	4.3	4.7	25.5	27.9	1769	7.3	70.4	5.1	机组停运	53
16	2.5	2.8	4.0	4.4	26.2	29.2	1719	7.5	70.8	5.2	机组停运	50
17	2.6	2.7	8.4	8.6	29.1	30.7	2022	6.9	73.8	6.1	机组停运	65
18	2.6	2.6	15.3	14.6	30.9	30.5	2201	6.0	76.5	6.5	机组停运	77
19	2.6	2.6	21.4	21.1	31.1	30.6	2428	5.8	78.2	7.0	机组停运	86
20	2.5	2.6	19.0	19.1	28.6	28.8	2346	6.1	77.8	7.1	机组停运	81
21	2.6	3.3	9.7	11.2	23.4	28.4	3496	8.7	73.0	6.3	15:39并网发电	77
22	2.7	2.8	13.0	13.0	26.8	26.9	4322	6.1	78.7	6.8	75	78
23	2.7	3.0	9.7	10.1	24.3	26.1	3693	7.1	76.1	6.3	61	60
24	2.6	2.9	10.7	11.7	23.9	26.2	3521	7.3	72.7	6.1	55	55
25	2.7	2.8	11.0	11.5	25.1	26.6	3911	6.9	74.3	6.4	64	65
26	2.6	2.7	14.5	14.8	25.5	26.2	4086	6.5	75.2	6.5	70	69
27	2.6	2.8	10.5	11.0	25.1	27.0	3871	7.1	74.2	6.3	64	63
28	2.7	3.0	10.3	11.0	24.2	26.5	3568	7.3	73.9	6.0	57	57
29	2.7	2.9	17.5	17.9	27.0	28.2	4032	6.7	76.3	6.2	70	65
30	2.6	2.7	21.8	21.8	30.7	30.8	4519	6.1	78.9	6.8	84	79
31	2.7	2.8	21.8	22.4	30.2	31.1	4309	6.5	79.4	6.7	78	72
最大值	3.5	4.2	21.8	22.4	31.1	31.1	4519	8.7	79.4	7.1	84	86
最小值	2.2	2.6	3.0	3.2	21.2	23.1	1703	5.8	66.5	4.6	48	48
平均	2.7	3.0	9.4	9.8	25.2	27.3	3068	7.2	73.5	5.8	62	61

深圳妈湾电力有限公司2023年5月#2烟囱烟气数据

浓度单位: (mg/m³) 烟气量单位: 万立方米/天

日期	#2烟囱排放口				机组负荷率(%)							
	颗粒物		二氧化硫									
	标志	折算	标志	折算								
1	3.0	3.2	7.8	8.3	16.2	17.2	1535	6.9	71.6	4.2	机组停运	51
2	3.2	3.3	6.0	6.2	17.0	17.5	1441	6.4	72.9	4.3		
3	3.9	4.2	11.1	11.4	21.8	22.8	3024	6.7	74.3	4.6	13: 38并网发电	67
4	3.0	2.9	15.4	14.6	24.8	23.6	4606	5.3	80.3	5.2	73	76
5	2.4	2.3	4.9	4.6	23.6	22.6	4717	5.4	80.4	5.4	75	77
6	2.4	2.3	11.0	10.4	25.5	24.1	4979	5.2	79.3	5.6	81	80
7	2.6	2.6	9.9	9.6	22.6	22.4	4236	5.9	73.8	5.2	66	65
8	2.6	2.7	4.6	4.8	21.7	22.6	3373	6.6	71.7	4.8	47	48
9	2.8	2.8	5.0	5.1	23.1	23.6	3658	6.3	72.9	4.9	54	52
10	2.8	2.9	6.6	6.7	21.5	21.9	3658	6.3	73.9	4.9	53	53
11	2.9	3.0	6.1	6.1	21.9	22.2	3564	6.3	73.4	4.8	52	52
12	3.1	4.3	4.0	5.6	13.7	18.7	2394	10.1	69.8	4.4	49	1: 31机组停运
13	3.7	5.3	4.5	6.5	12.6	18.1	2453	10.6	63.1	4.1	48	机组停运
14	3.3	3.9	6.6	7.7	16.1	18.9	1824	8.3	68.8	4.4	51	机组停运
15	2.9	3.1	11.6	12.1	19.9	21.0	1876	6.8	74.1	4.8	60	机组停运
16	2.9	3.0	9.8	10.4	19.7	20.9	1707	6.9	74.4	4.7	55	机组停运
17	2.9	2.9	14.4	14.6	21.9	22.4	2038	6.4	76.3	5.2	67	机组停运
18	2.8	3.1	14.3	15.2	22.6	24.4	3736	6.9	74.9	5.3	76	10: 45并网发电
19	3.0	2.9	18.0	16.9	26.5	24.9	4994	5.1	81.0	5.9	81	82
20	2.9	2.8	20.5	19.2	25.4	23.9	4910	5.1	81.4	6.0	84	79
21	3.0	2.8	19.2	18.2	25.5	24.3	4876	5.3	80.2	6.1	81	82
22	2.9	2.8	15.7	15.0	23.0	22.1	4792	5.4	79.5	6.1	75	78
23	2.8	2.7	18.4	17.6	24.0	23.1	4719	5.4	77.6	6.1	75	77
24	2.6	2.6	15.8	15.4	22.7	22.2	4332	5.7	75.0	5.8	68	68
25	2.7	2.6	13.4	12.9	22.6	21.9	4663	5.5	76.8	6.0	73	75
26	2.8	2.6	19.3	18.3	24.0	22.9	4858	5.3	77.7	6.1	77	79
27	2.6	2.7	14.8	15.0	21.0	21.5	3175	6.4	75.8	5.9	74	7: 39机组停运
28	2.6	2.9	16.0	17.2	19.6	21.4	2116	7.3	75.4	5.6	64	机组停运
29	3.0	3.1	21.4	21.9	25.6	26.9	4386	6.4	76.8	6.0	82	8: 32并网发电
30	3.0	2.7	26.6	24.2	29.0	26.4	5260	4.6	80.6	6.3	90	90
31	3.1	3.0	24.8	23.8	27.6	26.6	4304	5.4	78.7	6.1	55	85
最大值	3.9	5.3	26.6	24.2	29.0	26.9	5260	10.6	81.4	6.3	90	90
最小值	2.4	2.3	4.0	4.6	12.6	17.2	1441	4.6	63.1	4.1	47	48
平均	2.9	3.0	12.8	12.8	22.0	22.4	3619	6.3	75.5	5.3	67	70

深圳妈湾电力有限公司2023年5月#3烟卤烟气数据

浓度单位 (mg/Nm³) 烟流量单位 万立方米/天

日期	颗粒物		二氧化硫		#3烟卤排放口		烟气量	氧量%	温度℃	湿度%	机组负荷率 (%)	
	标志	折算	标志	折算	标志	折算					#5机组	#6机组
1	3.0	3.1	4.1	4.3	20.5	21.5	1588	6.6	70.3	3.8	52	机组停运
2	2.8	2.9	4.4	4.6	22.8	23.9	1561	6.7	70.3	3.8	51	机组停运
3	2.7	2.7	6.5	6.4	23.5	23.3	1941	5.9	73.4	4.3	68	机组停运
4	2.6	2.5	7.4	7.2	23.6	23.1	2008	5.7	74.6	4.6	72	机组停运
5	2.0	1.9	10.4	9.9	24.9	24.0	2071	5.4	75.8	4.9	76	机组停运
6	2.8	2.6	13.2	12.5	22.6	21.5	2203	5.3	76.7	5.1	83	机组停运
7	2.7	2.6	12.4	11.9	22.3	21.8	1916	5.7	73.8	4.8	70	机组停运
8	2.5	2.6	4.8	5.0	19.4	20.3	1488	6.7	69.1	4.2	48	机组停运
9	2.5	2.6	5.3	5.5	20.0	20.7	1589	6.5	70.3	4.2	52	机组停运
10	2.4	2.5	7.8	8.1	21.1	22.1	1681	6.7	70.0	4.1	54	机组停运
11	2.4	2.5	10.2	10.4	22.1	22.9	1722	6.5	68.1	4.1	55	机组停运
12	2.7	2.9	7.4	7.9	24.3	26.2	1591	7.0	68.1	3.9	48	机组停运
13	2.6	2.8	7.5	8.0	21.5	23.0	1568	7.0	67.5	3.9	48	机组停运
14	2.7	2.8	9.7	10.3	25.4	27.1	1667	6.9	67.7	3.9	51	机组停运
15	2.6	2.6	16.0	16.0	21.2	21.5	1850	6.2	70.7	4.2	61	机组停运
16	2.6	2.6	9.9	10.1	22.0	22.6	1677	6.4	70.8	4.2	55	机组停运
17	2.5	2.5	18.3	17.6	23.6	23.1	1952	5.7	73.3	4.6	68	机组停运
18	2.8	2.7	23.3	22.1	25.2	24.0	2234	5.3	75.9	4.9	82	机组停运
19	3.3	3.3	22.6	22.7	24.4	24.6	3575	6.0	74.7	5.3	90	13: 11并网发电
20	2.9	2.7	22.7	20.9	21.2	19.5	4606	4.7	79.1	5.6	87	87
21	2.8	2.6	17.6	16.3	24.0	22.4	4411	4.9	78.2	5.7	82	82
22	2.8	2.6	22.6	21.2	26.1	24.4	4256	5.0	77.5	5.7	78	78
23	2.9	2.8	12.8	12.3	24.1	23.5	3526	5.6	74.9	5.1	59	62
24	2.7	2.7	11.5	11.3	25.5	25.1	3364	5.8	73.6	5.1	52	58
25	2.8	2.6	21.2	19.7	23.0	21.6	3932	5.0	76.4	5.4	74	67
26	2.7	2.6	23.1	21.6	23.2	21.8	4210	5.1	76.6	5.4	80	73
27	2.8	2.6	18.9	17.8	24.0	22.7	3976	5.2	76.1	5.3	74	66
28	2.8	2.8	13.8	13.2	24.3	23.9	3633	5.7	75.2	5.1	65	58
29	2.8	2.6	22.9	21.3	23.9	22.3	4466	4.9	78.2	5.6	82	81
30	3.1	2.8	22.3	20.4	26.2	23.9	4711	4.6	79.2	5.8	90	88
31	3.3	3.0	24.4	22.4	26.1	24.2	4440	4.8	80.1	5.6	82	83
最大值	3.3	3.3	24.4	22.7	26.2	27.1	4711	7.0	80.1	5.8	90	88
最小值	2.0	1.9	4.1	4.3	19.4	19.5	1488	4.6	67.5	3.8	48	58
平均	2.7	2.7	14.0	13.5	23.3	23.0	2755	5.8	73.7	4.8	67	74