

HJ/T76-2017

烟气连续监测日平均值月报表

排放源名称：深能洪湾电厂
排放源编号：3#锅炉

监测月份：2024 年 12 月

日期	颗粒物			SO2			NOx			CO2	流量	O2	温度	水分	负荷	备注
	mg/Nm3	折算 mg/Nm3	t/d	mg/Nm3	折算 mg/Nm3	t/d	mg/Nm3	折算 mg/Nm3	t/d	%	X1000 Nm3/d	%	℃	含量%	MW	
1 日	0	0	0	0	0	0	0	0	0	0	0	21	31	1	0	停机备用
2 日	0	0	0	0	0	0	0	0	0	0	0	21	31	1	0	停机备用
3 日	0	0	0	0	0	0	0	0	0	0	0	21	29	1	0	停机备用
4 日	0	0	0	0	0	0	0	0	0	0	0	21	27	2	0	停机备用
5 日	0	0	0	0	0	0	0	0	0	0	0	21	27	2	0	停机备用
6 日	0	0	0	0	0	0	0	0	0	0	0	21	26	1	0	停机备用
7 日	0	0	0	0	0	0	0	0	0	0	0	21	25	1	0	停机备用
8 日	0	0	0	0	0	0	0	0	0	0	0	21	22	1	0	停机备用
9 日	0	0	0	0	0	0	0	0	0	0	0	21	22	1	0	停机备用
10 日	0	0	0	0	0	0	0	0	0	0	0	21	23	1	0	停机备用
11 日	0	0	0	0	0	0	0	0	0	0	0	21	24	1	0	停机备用
12 日	0	0	0	0	0	0	0	0	0	0	0	21	22	1	0	停机备用
13 日	0	0	0	0	0	0	0	0	0	0	0	21	21	1	0	停机备用
14 日	0	0	0	0	0	0	0	0	0	0	0	21	18	1	0	停机备用
15 日	0	0	0	0	0	0	0	0	0	0	0	21	17	1	0	停机备用
16 日	0.3280	0.357	0.0015	0.3543	0.3684	0.0009	11.9786	15.9120	0.2314	0	602.03	20	40	1	0	机组运行
17 日	0	0	0	0	0	0	0	0	0	0	0	21	60	1	0	停机备用
18 日	0	0	0	0	0	0	0	0	0	0	0	21	62	1	0	停机备用
19 日	0	0	0	0	0	0	0	0	0	0	0	21	52	1	0	停机备用
20 日	0	0	0	0	0	0	0	0	0	0	0	21	37	1	0	停机备用
21 日	0	0	0	0	0	0	0	0	0	0	0	21	28	1	0	停机备用
22 日	0	0	0	0	0	0	0	0	0	0	0	21	23	1	0	停机备用
23 日	0	0	0	0	0	0	0	0	0	0	0	21	20	1	0	停机备用
24 日	0	0	0	0	0	0	0	0	0	0	0	21	20	1	0	停机备用
25 日	0	0	0	0	0	0	0	0	0	0	0	21	19	1	0	停机备用
26 日	0	0	0	0	0	0	0	0	0	0	0	21	20	1	0	停机备用
27 日	0	0	0	0	0	0	0	0	0	0	0	21	21	1	0	停机备用
28 日	0	0	0	0	0	0	0	0	0	0	0	21	19	1	0	停机备用
29 日	0	0	0	0	0	0	0	0	0	0	0	21	17	1	0	停机备用
30 日	0	0	0	0	0	0	0	0	0	0	0	21	19	1	0	停机备用
31 日	0	0	0	0	0	0	0	0	0	0	0	21	20	1	0	停机备用
平均值	0.3572	0.358	0.0000	0.5942	0.5945	0.0000	1.6651	1.7920	0.0075	0	19.420	21	27	1	0	
最大值	0.4615	0.461	0.0015	1.2775	1.2778	0.0009	11.9786	15.9120	0.2314	0	602.03	21	62	2	0	
最小值	0.2487	0.248	0.0000	0.2229	0.2228	0.0000	0.3002	0.3003	0.0000	0	0.0000	20	17	1	0	
样本数	31	31	31	31	31	31	31	31	31	31	31	31	31	31	3	
月排放 总量(t)			0.0015			0.0009			0.2314		602.03					
			5			9			4		359					

烟气连续监测日平均值月报表

排放源名称：深能洪湾电厂
排放源编号：4#锅炉

监测月份：2024 年 12 月

日期	颗粒物			SO2			NOx			CO2	流量	O2	温度	水分	负荷	备注
	mg/Nm3	折算 mg/Nm3	t/d	mg/Nm3	折算 mg/Nm3	t/d	mg/Nm3	折算 mg/Nm3	t/d	%	X1000 Nm3/d	%	℃	含量 %	MW	
1 日	0	0	0	0	0	0	0	0	0	0	0	21	30	0	0	停机备用
2 日	0	0	0	0	0	0	0	0	0	0	0	21	29	0	0	停机备用
3 日	0	0	0	0	0	0	0	0	0	0	0	21	28	1	0	停机备用
4 日	0	0	0	0	0	0	0	0	0	0	0	21	27	1	0	停机备用
5 日	0.0720	0.0772	0.0004	0.92	0.9347	0.0009	8.5745	11.397	0.1832	0	598.799	20	64	1	0	机组运行
6 日	0	0	0	0	0	0	0	0	0	0	0	21	59	1	0	停机备用
7 日	0	0	0	0	0	0	0	0	0	0	0	21	53	1	0	停机备用
8 日	0	0	0	0	0	0	0	0	0	0	0	21	46	1	0	停机备用
9 日	0	0	0	0	0	0	0	0	0	0	0	21	43	1	0	停机备用
10 日	0	0	0	0	0	0	0	0	0	0	0	21	40	1	0	停机备用
11 日	0	0	0	0	0	0	0	0	0	0	0	21	37	1	0	停机备用
12 日	0.0744	0.0864	0.0006	1.05	1.0740	0.0012	10.113	14.195	0.2134	0	737.326	19	55	1	0	机组运行
13 日	0	0	0	0	0	0	0	0	0	0	0	21	57	1	0	停机备用
14 日	0	0	0	0	0	0	0	0	0	0	0	21	47	0	0	停机备用
15 日	0	0	0	0	0	0	0	0	0	0	0	21	43	1	0	停机备用
16 日	0	0	0	0	0	0	0	0	0	0	0	21	41	1	0	停机备用
17 日	0	0	0	0	0	0	0	0	0	0	0	21	39	0	0	停机备用
18 日	0	0	0	0	0	0	0	0	0	0	0	21	36	1	0	停机备用
19 日	0	0	0	0	0	0	0	0	0	0	0	21	31	1	0	停机备用
20 日	0	0	0	0	0	0	0	0	0	0	0	21	29	1	0	停机备用
21 日	0	0	0	2	0	0	0	0	0	0	0	21	27	1	0	停机备用
22 日	0	0	0	0	0	0	0	0	0	0	0	21	25	1	0	停机备用
23 日	0	0	0	0	0	0	0	0	0	0	0	21	24	1	0	停机备用
24 日	0	0	0	0	0	0	0	0	0	0	0	21	23	1	0	停机备用
25 日	0	0	0	0	0	0	0	0	0	0	0	21	22	0	0	停机备用
26 日	0	0	0	0	0	0	0	0	0	0	0	21	22	0	0	停机备用
27 日	0	0	0	0	0	0	0	0	0	0	0	21	23	0	0	停机备用
28 日	0	0	0	0	0	0	0	0	0	0	0	21	20	1	0	停机备用
29 日	0	0	0	0	0	0	0	0	0	0	0	21	19	0	0	停机备用
30 日	0	0	0	0	0	0	0	0	0	0	0	21	20	0	0	停机备用
31 日	0	0	0	0	0	0	0	0	0	0	0	21	22	0	0	停机备用
平均值	0.0607	0.0613	0.0000	1.65	1.6542	0.0001	1.1319	1.3547	0.0128	0	43.1008	21	35	1	0	
最大值	0.0749	0.0864	0.0006	2.67	2.6702	0.0012	10.113	14.195	0.2134	0	737.326	21	64	1	0	
最小值	0.0470	0.0470	0.0000	0.92	0.9347	0.0000	0.2541	0.2537	0.0000	0	0.0000	19	19	0	0	
样本数	31	31	31	31	31	31	31	31	31	31	31	31	31	3	3	
月排放 总量(t)			0.0010			0.0021			0.3966		1336.1 259					

烟气月排放总量单位：x1000m3/m

上报单位（盖章） 填报人：罗文挺 审核：黄劲松 批准： 范汉林

报告日期： 2025 年 01 月 06 日