

深圳妈湾电力有限公司2025年1月#2烟囱烟气数据

浓度单位 (mg/Nm³)

烟气量单位 万立方米/天

日期	#2烟囱排放口										机组负荷率 (%)	
	氮氧化物		二氧化硫		颗粒物		烟气量	温度℃	湿度%	氧量%	#3机组	#4机组
	干基	折算	干基	折算	干基	折算						
1	21.7	23.5	8.1	8.8	1.8	2.0	1558	69.2	3.1	7.2	00: 00机组停运	50
2	20.2	24.4	9.6	10.5	2.7	3.7	2298	62.0	2.9	9.0	机组停运	58
3	20.0	23.3	8.4	9.1	2.0	2.5	2032	63.1	2.8	8.3	机组停运	53
4	28.7	27.9	16.3	15.8	2.1	2.0	2263	72.2	3.9	5.6	机组停运	81
5	26.3	26.8	16.8	17.1	2.0	2.0	2494	70.4	3.8	6.3	机组停运	84
6	26.5	27.8	13.7	14.3	2.0	2.1	2498	65.9	3.6	6.7	机组停运	81
7	27.2	28.2	12.6	13.0	2.2	2.3	2367	67.8	3.6	6.5	机组停运	79
8	26.3	27.2	14.6	15.1	2.4	2.5	2330	68.4	3.6	6.5	机组停运	78
9	28.7	28.9	21.4	21.6	2.5	2.5	2370	69.6	3.8	6.1	机组停运	80
10	28.1	28.3	25.1	25.2	2.3	2.4	2470	68.1	3.7	6.1	机组停运	85
11	28.3	28.7	19.7	19.9	2.1	2.1	2546	67.0	3.4	6.2	机组停运	87
12	22.2	23.9	13.2	14.0	1.8	2.0	2129	64.8	3.0	7.0	机组停运	69
13	27.2	27.6	21.5	21.6	2.1	2.1	2412	67.3	3.3	6.2	机组停运	80
14	26.1	27.0	17.5	18.0	2.1	2.2	2287	67.2	3.3	6.5	机组停运	77
15	26.3	27.5	15.1	15.6	1.8	1.8	2163	66.8	3.2	6.7	机组停运	71
16	23.4	24.9	11.6	12.2	1.9	2.0	2158	65.7	3.1	6.9	机组停运	70
17	18.3	22.1	5.1	6.1	1.6	1.9	1783	61.2	2.5	8.6	机组停运	50
18	19.6	23.6	4.8	5.8	1.6	1.9	1711	61.2	2.7	8.6	机组停运	48
19	18.2	21.7	4.8	5.7	1.4	1.7	1683	62.1	2.7	8.4	机组停运	47
20	19.0	22.0	4.6	5.3	1.5	1.7	1685	64.0	2.9	8.0	机组停运	49
21	22.5	24.3	6.5	7.0	1.8	2.0	1973	66.8	3.1	7.2	机组停运	62
22	22.2	24.6	6.6	7.3	1.7	1.8	1774	65.9	3.2	7.5	机组停运	56
23	22.3	25.1	7.0	7.9	1.5	1.6	1636	65.0	3.2	7.7	机组停运	49
24	#3、#4机停运										机组停运	1: 23机组停运
25											机组停运	机组停运
26											机组停运	机组停运
27											机组停运	机组停运
28											机组停运	16: 00并网发电
29	15.5	18.8	4.4	5.4	1.7	2.0	1698	62.7	2.6	8.7	机组停运	52
30	16.7	20.9	5.1	6.3	1.1	1.4	1652	62.8	2.9	9.0	机组停运	48
31	17.6	22.1	5.5	6.9	1.1	1.4	1634	63.9	3.0	9.1	机组停运	47
最大值	28.7	28.9	25.1	25.2	2.7	3.7	2546	72.2	3.9	9.1	0	87
最小值	15.5	18.8	4.4	5.3	1.1	1.4	1558	61.2	2.5	5.6	0	47
平均	23.0	25.0	11.5	12.1	1.9	2.1	2062	65.8	3.2	7.3	#DIV/0!	65

深圳妈湾电力有限公司2025年1月#3烟囱烟气数据



浓度单位 (mg/Nm³) 烟气量单位 万立方米/天

日期	#3烟囱排放口										机组负荷率 (%)	
	氮氧化物		二氧化硫		颗粒物		烟气量	温度℃	湿度%	氧量%	#5机组	#6机组
	干基	折算	干基	折算	干基	折算						
1	19.7	21.2	9.5	10.1	2.3	2.5	3559	67.4	2.6	7.1	61	52
2	24.2	24.4	18.2	17.9	2.3	2.4	4150	70.0	3.0	6.1	80	65
3	25.5	25.3	16.1	15.8	2.6	2.5	4175	71.3	3.0	5.9	84	64
4	24.7	24.7	12.7	12.5	2.8	2.8	4025	69.2	2.9	6.0	82	62
5	24.3	23.9	9.7	9.5	2.7	2.7	4030	70.2	2.9	5.7	84	62
6	24.6	24.3	8.8	8.7	2.6	2.5	3928	70.1	2.9	5.8	80	60
7	22.7	22.9	7.9	7.9	2.6	2.7	3854	70.0	2.8	6.1	79	55
8	24.6	25.4	8.8	9.1	2.9	3.0	3797	68.5	2.7	6.5	77	51
9	24.6	24.9	16.0	16.1	2.8	2.8	3986	70.2	2.9	6.2	81	57
10	24.1	23.7	20.8	20.2	2.6	2.6	4234	72.0	3.0	5.7	85	68
11	24.5	23.9	18.9	18.4	2.4	2.4	4328	72.4	2.9	5.7	86	72
12	22.4	23.1	10.3	10.5	2.3	2.4	3597	69.9	2.5	6.4	69	53
13	24.2	24.1	17.6	17.3	2.1	2.1	4021	70.1	2.6	5.9	81	63
14	24.6	24.9	13.5	13.6	2.3	2.4	3596	67.5	2.5	6.2	74	53
15	23.9	24.4	10.9	11.0	2.6	2.7	3543	68.2	2.5	6.3	70	51
16	23.7	24.5	7.8	8.0	2.8	2.8	3584	68.2	2.4	6.5	70	51
17	25.7	26.0	7.8	7.7	3.3	3.3	4021	69.7	2.5	6.1	77	65
18	23.8	24.5	5.9	6.0	2.9	3.0	3782	68.7	2.4	6.4	70	60
19	22.7	23.1	6.1	6.2	3.1	3.1	3818	68.8	2.5	6.3	73	60
20	21.0	21.9	5.6	5.8	3.3	3.4	3653	68.2	2.5	6.6	68	56
21	23.5	26.7	4.1	4.5	3.1	3.5	1969	65.8	2.2	7.6	59	1: 03机组停运
22	22.6	24.2	4.9	5.2	2.9	3.1	1782	66.1	2.2	7.0	57	机组停运
23	23.3	25.8	4.7	5.2	2.7	3.0	1616	64.5	2.1	7.4	50	机组停运
24	20.8	23.8	4.3	4.9	3.8	4.3	1648	64.1	2.1	7.8	48	机组停运
25	23.3	26.5	3.8	4.3	4.3	4.9	1711	65.2	2.1	7.7	52	机组停运
26	23.3	26.1	3.9	4.4	2.6	2.9	1697	67.0	2.0	7.6	52	机组停运
27	24.1	26.3	4.4	4.8	3.3	3.6	1774	67.9	2.0	7.2	57	机组停运
28	22.9	25.8	4.7	5.1	3.7	4.1	1868	67.2	2.0	7.5	58	机组停运
29	24.8	28.9	4.3	5.0	4.2	4.9	1761	66.1	1.9	8.1	52	机组停运
30	22.4	26.1	3.9	4.6	5.1	5.9	1695	65.5	1.8	8.1	50	机组停运
31	25.8	28.9	4.3	4.8	4.8	5.4	1722	65.9	2.0	7.6	53	机组停运
最大值	25.8	28.9	20.8	20.2	5.1	5.9	4328	72.4	3.0	8.1	86	72
最小值	19.7	21.2	3.8	4.3	2.1	2.1	1616	64.1	1.8	5.7	48	51
平均	23.6	24.8	9.0	9.2	3.0	3.2	3127	68.3	2.5	6.7	68	59