

深圳妈湾电力有限公司2025年2月#2烟囱烟气数据

浓度单位 (mg/Nm³)

烟气量单位 万立方米/天

日期	#2烟囱排放口										机组负荷率 (%)	
	氮氧化物		二氧化硫		颗粒物		烟气量	温度℃	湿度%	氧量%	#3机组	#4机组
	干基	折算	干基	折算	干基	折算						
1	19.1	21.2	7.3	8.0	1.3	1.4	1933	68.0	3.4	7.5	机组停运	62
2	18.0	20.2	6.5	7.3	1.2	1.4	1878	67.4	3.3	7.7	机组停运	60
3	16.5	20.0	6.1	7.4	1.1	1.3	1697	63.4	3.0	8.6	机组停运	52
4	15.1	18.6	6.2	7.7	1.1	1.3	1722	63.1	2.9	8.8	机组停运	52
5	17.3	21.0	5.5	6.7	1.1	1.4	1598	63.6	2.9	8.6	机组停运	49
6	17.6	20.2	6.7	7.7	1.2	1.4	1572	66.6	3.1	8.0	机组停运	52
7	18.6	20.0	7.8	8.3	1.4	1.5	1789	67.5	3.3	7.1	机组停运	62
8	14.6	16.4	6.2	6.9	1.4	1.5	1623	65.8	3.1	7.6	机组停运	55
9	14.0	15.7	6.6	7.4	1.4	1.6	1668	65.8	3.1	7.7	机组停运	55
10	20.3	21.8	7.8	8.3	1.6	1.7	2025	64.5	3.2	7.1	机组停运	67
11	20.8	23.5	7.8	8.8	1.6	1.8	2188	64.9	3.0	7.7	机组停运	68
12	25.7	27.8	12.9	13.7	1.5	1.6	2203	66.3	3.1	7.2	机组停运	70
13	24.9	27.6	9.4	10.2	1.4	1.5	2092	65.7	3.0	7.5	机组停运	66
14	22.9	26.0	8.5	9.6	1.3	1.5	2012	64.8	3.2	7.8	机组停运	62
15	27.7	29.4	15.6	16.4	1.4	1.5	2153	68.0	3.7	6.9	机组停运	71
16	26.6	27.7	10.0	10.3	1.4	1.5	1987	71.3	3.8	6.6	机组停运	68
17	21.9	23.9	7.3	8.0	1.4	1.5	1780	69.7	3.5	7.2	机组停运	58
18	25.8	27.8	8.2	8.8	1.6	1.7	1962	70.2	3.6	7.1	机组停运	64
19	21.6	23.0	8.5	8.9	1.7	1.8	1911	70.8	3.7	6.9	机组停运	64
20	23.2	23.6	9.4	9.6	1.5	1.6	2096	71.6	3.9	6.5	机组停运	71
21	25.4	26.9	7.8	8.2	2.0	2.2	2266	69.4	3.6	6.9	机组停运	79
22	29.7	29.6	8.6	8.5	1.4	1.4	2010	71.1	3.3	6.1	机组停运	68
23	29.1	28.3	8.9	8.6	1.5	1.5	2265	72.6	3.6	5.6	机组停运	84
24	24.7	24.3	8.0	7.8	1.4	1.4	2077	71.3	3.7	5.8	机组停运	79
25	25.0	24.6	7.2	7.1	1.4	1.4	2019	71.5	3.5	5.9	机组停运	78
26	23.1	23.3	5.7	5.8	1.7	1.8	2452	69.7	3.5	6.2	机组停运	87
27	25.9	31.8	3.6	4.4	2.0	2.5	3501	65.0	3.1	9.0	22: 26并网发电	88
28	25.1	26.1	6.8	7.1	2.2	2.2	4514	71.2	3.5	6.6	67	80
最大值	29.7	31.8	15.6	16.4	2.2	2.5	4514	72.6	3.9	9.0	67	88
最小值	14.0	15.7	3.6	4.4	1.1	1.3	1572	63.1	2.9	5.6	67	49
平均	22.2	23.9	7.9	8.5	1.5	1.6	2107	67.9	3.3	7.2	67	67

深圳妈湾电力有限公司2025年2月#3烟囱烟气数据

浓度单位 (mg/Nm³) 烟气量单位 万立方米/天

日期	#3烟囱排放口										机组负荷率 (%)	
	氮氧化物		二氧化硫		颗粒物		烟气量	温度℃	湿度%	氧量%	#5机组	#6机组
	干基	折算	干基	折算	干基	折算						
1	25.7	26.5	5.7	5.8	2.5	2.6	1937	67.4	2.3	6.4	66	机组停运
2	24.0	25.9	5.1	5.4	2.0	2.1	1899	66.3	2.3	7.0	62	机组停运
3	23.6	27.2	4.1	4.7	1.6	1.8	1695	67.0	2.0	8.0	51	机组停运
4	23.2	26.6	4.4	5.0	2.1	2.4	1724	67.1	1.9	7.9	52	机组停运
5	21.7	24.7	3.8	4.4	1.4	1.6	1637	66.3	1.9	7.8	49	机组停运
6	22.1	24.4	4.3	4.7	1.3	1.5	1665	66.1	2.0	7.4	52	机组停运
7	27.2	31.9	4.4	5.2	1.8	2.1	2869	68.0	2.0	8.1	63	13: 23并网发电
8	15.8	17.2	4.1	4.5	1.7	1.9	3256	70.4	2.0	7.2	53	49
9	19.8	21.9	4.4	4.9	1.7	1.9	3272	69.8	1.9	7.4	52	48
10	23.7	24.9	6.1	6.3	2.0	2.1	3583	70.9	2.1	6.7	57	63
11	21.4	22.3	5.1	5.3	1.8	1.8	3459	69.8	2.2	6.7	61	56
12	25.3	26.6	7.7	8.0	1.7	1.8	3497	68.5	2.3	6.7	62	54
13	32.9	34.6	5.2	5.4	1.7	1.8	3375	69.1	2.2	6.7	59	53
14	33.7	35.1	5.5	5.7	3.0	3.1	3218	68.5	2.2	6.6	57	50
15	33.4	34.3	7.9	8.0	2.4	2.4	3387	68.2	2.3	6.4	62	52
16	32.5	33.9	5.2	5.4	1.8	1.8	3292	69.1	2.4	6.6	60	49
17	33.2	35.0	5.4	5.7	1.6	1.7	3482	70.6	2.5	6.8	53	58
18	33.2	34.6	4.6	4.8	1.5	1.6	3268	70.0	2.4	6.6	58	50
19	32.9	34.5	4.5	4.8	1.5	1.6	3276	70.2	2.4	6.7	56	52
20	33.2	33.5	6.1	6.1	1.8	1.9	3926	71.5	2.8	6.1	79	59
21	32.4	32.2	5.9	5.8	1.7	1.7	3923	71.9	2.8	5.9	82	60
22	34.9	35.3	6.2	6.3	1.7	1.7	3910	72.1	2.8	6.2	81	56
23	34.8	34.7	5.9	5.9	1.5	1.5	3884	73.9	2.7	6.0	84	54
24	36.1	36.4	6.0	6.1	1.7	1.7	3862	73.2	2.6	6.2	79	56
25	34.8	34.8	5.8	5.8	2.3	2.3	3990	73.8	2.6	6.0	78	65
26	34.2	33.4	4.9	4.7	2.8	2.7	4390	74.5	2.9	5.7	86	76
27	33.5	32.7	3.9	3.8	2.7	2.7	4494	73.3	2.9	5.6	88	78
28	32.7	32.9	3.5	3.5	2.0	2.0	3753	70.6	2.8	6.1	79	52
最大值	36.1	36.4	7.9	8.0	3.0	3.1	4494	74.5	2.9	8.1	88	78
最小值	15.8	17.2	3.5	3.5	1.3	1.5	1637	66.1	1.9	5.6	49	48
平均	29.0	30.3	5.2	5.4	1.9	2.0	3212	69.9	2.4	6.7	65	57