

深圳妈湾电力有限公司2025年3月#2烟囱烟气数据

浓度单位 (mg/Nm³)

烟气量单位 万立方米/天

日期	#2烟囱排放口										机组负荷率 (%)	
	氮氧化物		二氧化硫		颗粒物		烟气量	温度℃	湿度%	氧量%	#3机组	#4机组
	干基	折算	干基	折算	干基	折算						
1	27.2	27.2	9.6	9.5	2.4	2.4	4745	73.3	3.7	6.1	79	81
2	24.6	25.2	11.9	12.1	2.3	2.4	4336	73.6	3.7	6.5	71	72
3	31.1	29.9	18.7	17.8	2.9	2.8	5027	75.8	4.1	5.4	89	90
4	31.9	30.1	21.6	20.3	3.3	3.1	5158	77.7	4.3	5.1	94	94
5	32.9	32.3	16.9	16.5	3.4	3.4	5061	74.9	4.1	5.7	87	89
6	26.8	27.8	10.9	11.0	2.5	2.6	4700	70.9	3.7	6.5	76	78
7	26.8	26.8	11.9	11.7	2.4	2.3	5003	71.4	3.7	5.9	85	86
8	27.4	30.9	12.4	13.9	3.0	3.4	2628	69.5	3.4	7.7	79	3: 12机组停运
9	23.4	32.6	11.6	14.9	2.6	3.6	2978	62.2	3.0	10.1	72	机组停运
10	24.2	32.4	11.4	14.0	2.5	3.4	2872	63.4	3.1	9.7	72	机组停运
11	27.8	31.6	21.4	24.0	3.4	3.8	2553	70.2	3.7	7.7	80	机组停运
12	26.7	29.9	21.9	24.2	3.4	3.8	2711	70.1	3.8	7.6	85	机组停运
13	25.5	28.4	17.1	19.1	3.4	3.8	2928	69.8	3.8	7.5	91	机组停运
14	26.9	29.7	15.3	16.8	3.6	3.9	2842	71.0	3.9	7.4	91	机组停运
15	26.6	29.6	12.5	13.8	3.3	3.7	2774	70.5	4.1	7.5	87	机组停运
16	25.7	30.5	10.2	11.7	2.6	2.9	2552	65.8	3.5	8.3	76	机组停运
17	22.4	26.6	8.5	9.7	3.4	3.8	2593	63.7	3.3	8.2	77	机组停运
18	24.0	26.8	14.3	15.9	4.5	5.0	2876	68.0	3.6	7.5	91	机组停运
19	24.0	27.1	15.0	16.7	4.0	4.5	2802	68.1	3.5	7.7	87	机组停运
20	24.2	28.3	14.1	15.9	3.5	3.9	2605	66.8	3.3	8.0	79	机组停运
21	24.4	28.3	13.5	15.3	3.8	4.3	2556	67.1	3.5	8.0	78	机组停运
22	24.7	28.9	10.0	11.0	3.8	4.3	2378	65.8	3.5	8.1	71	机组停运
23	27.5	30.0	14.5	15.4	4.1	4.4	2429	67.9	3.9	7.2	75	机组停运
24	27.4	29.7	15.9	16.9	3.9	4.2	2425	68.7	3.8	7.1	75	机组停运
25	26.6	29.1	13.5	14.4	3.5	3.7	2319	68.2	3.7	7.2	71	机组停运
26	23.6	25.6	16.0	16.9	3.1	3.2	2309	69.3	3.8	7.1	75	机组停运
27	23.1	24.8	16.4	17.3	2.8	3.0	2347	70.1	3.9	7.1	75	机组停运
28	27.1	28.1	17.1	17.4	2.8	2.8	2395	73.2	4.2	6.5	82	机组停运
29	24.1	27.7	8.1	8.9	2.3	2.8	1981	65.9	3.7	7.9	62	机组停运
30	22.3	25.4	7.3	8.1	2.1	2.4	2039	64.9	3.6	7.7	62	机组停运
31	21.1	26.6	3.7	4.6	2.3	2.9	2875	60.2	3.1	9.1	62	机组停运
最大值	32.9	32.6	21.9	24.2	4.5	5.0	5158	77.7	4.3	10.1	94	94
最小值	21.1	24.8	3.7	4.6	2.1	2.3	1981	60.2	3.0	5.1	62	72
平均	25.9	28.6	13.6	14.7	3.1	3.4	3090	69.0	3.7	7.4	79	84

深圳妈湾电力有限公司2025年3月#3烟囱烟气数据

浓度单位 (mg/Nm³)

烟气量单位 万立方米/天

日期	#3烟囱排放口										机组负荷率 (%)	
	氮氧化物		二氧化硫		颗粒物		烟气量	温度℃	湿度%	氧量%	#5机组	#6机组
	干基	折算	干基	折算	干基	折算						
1	33.0	32.9	4.4	4.4	2.1	2.1	4024	70.2	3.0	5.9	80	64
2	32.9	33.5	5.4	5.5	2.1	2.1	3687	69.3	3.0	6.3	72	57
3	34.2	33.1	11.8	11.3	2.3	2.2	4508	70.9	3.4	5.5	91	78
4	35.3	33.7	13.6	12.9	2.7	2.6	4900	70.8	3.7	5.3	94	92
5	35.3	34.6	8.7	8.5	2.1	2.1	4339	71.6	3.3	5.7	88	72
6	32.8	32.9	6.1	6.0	2.1	2.1	4153	74.8	3.1	6.0	77	72
7	34.8	33.9	6.5	6.3	2.4	2.3	4562	76.0	3.1	5.6	86	83
8	33.6	33.4	5.1	5.0	2.1	2.1	4188	75.2	2.9	5.9	80	72
9	32.4	33.0	5.0	5.0	1.9	1.9	3931	72.8	2.8	6.2	72	66
10	33.7	34.2	7.3	7.2	1.6	1.7	3835	70.5	2.9	6.2	71	62
11	34.3	34.1	16.1	15.8	1.9	1.9	4075	69.8	3.1	5.9	77	68
12	32.9	32.5	19.6	19.2	2.0	2.0	4360	70.1	3.3	5.8	84	74
13	33.8	32.7	15.4	14.8	2.4	2.4	4665	70.3	3.5	5.5	92	82
14	34.3	33.3	11.3	10.9	2.2	2.2	4578	70.4	3.6	5.5	91	78
15	33.2	32.4	9.0	8.7	1.9	1.9	4418	70.4	3.6	5.6	88	74
16	31.8	31.9	7.8	7.7	1.9	1.9	4031	75.0	3.4	6.0	76	69
17	31.0	31.0	8.0	7.9	2.2	2.2	4093	75.0	3.2	6.0	78	69
18	34.9	33.9	9.6	9.3	2.4	2.3	4508	75.5	3.3	5.5	89	80
19	32.3	31.7	9.8	9.5	2.2	2.1	4280	73.6	3.2	5.7	84	73
20	31.5	31.1	9.6	9.4	2.2	2.1	4072	71.8	3.1	5.8	80	67
21	29.6	29.4	10.6	10.4	1.7	1.7	4025	71.0	3.1	5.9	78	67
22	31.2	31.4	6.7	6.6	1.6	1.6	3780	69.0	3.0	6.1	72	61
23	30.0	30.1	7.2	7.2	1.6	1.6	3744	68.8	3.1	6.0	76	57
24	33.6	33.9	7.3	7.3	1.5	1.6	3804	68.8	3.2	6.1	75	58
25	31.5	31.7	7.0	7.0	1.5	1.5	3756	68.9	3.3	6.1	75	56
26	32.4	32.8	7.9	7.9	1.4	1.5	3840	69.3	3.4	6.2	73	61
27	31.9	31.9	10.1	10.0	1.6	1.6	4029	70.1	3.6	6.0	76	67
28	34.6	34.2	12.6	12.3	1.7	1.6	4308	71.2	3.9	5.8	84	73
29	32.1	33.4	6.0	6.2	1.3	1.4	3417	73.7	3.2	6.6	62	53
30	30.1	31.6	5.5	5.7	1.3	1.3	3473	75.9	3.1	6.7	62	54
31	29.7	30.4	7.4	7.4	1.5	1.5	3735	77.2	3.0	6.3	70	61
最大值	35.3	34.6	19.6	19.2	2.7	2.6	4900	77.2	3.9	6.7	94	92
最小值	29.6	29.4	4.4	4.4	1.3	1.3	3417	68.8	2.8	5.3	62	53
平均	32.8	32.6	9.0	8.8	1.9	1.9	4101	71.9	3.2	5.9	79	68