

深圳妈湾电力有限公司2025年4月#2烟囱烟气数据

浓度单位 mg/Nm³ 烟气量单位 万立方米/天

日期	#2烟囱排放口										机组负荷率(%)	
	氮氧化物		二氧化硫		颗粒物		烟气量	温度℃	湿度%	氧量%	#3机组	#4机组
	干基	折算	干基	折算	干基	折算						
1	24.6	30.9	2.6	3.1	2.7	3.5	2191	63.1	3.0	8.7	50	23: 21机组并网
2	34.1	36.3	5.1	5.5	2.6	2.8	3503	67.7	3.3	6.9	47	53
3	27.5	30.3	7.3	7.9	1.8	1.9	1877	66.2	3.2	7.4	1: 47机组停运	57
4	22.9	27.6	5.9	7.1	2.0	2.5	1816	60.7	2.8	8.6	机组停运	50
5	28.0	29.7	8.2	8.4	2.5	2.8	2740	67.6	3.5	6.9	14: 52机组并网	65
6	25.5	26.9	6.2	6.5	1.7	1.8	3445	69.6	3.3	6.8	51	53
7	26.4	27.7	6.5	6.8	2.1	2.2	3534	70.6	3.4	6.7	53	53
8	29.6	29.0	7.5	7.3	2.2	2.1	4664	73.3	3.9	5.7	78	78
9	33.6	32.6	8.7	8.3	2.3	2.2	4836	74.5	4.1	5.5	80	84
10	28.1	28.1	9.1	9.0	2.2	2.1	4069	73.9	4.0	6.0	82	49
11	31.9	30.3	12.0	11.3	2.3	2.2	5020	76.7	4.6	5.2	88	87
12	28.2	27.5	6.7	6.5	2.2	2.2	4625	75.6	4.5	5.6	79	79
13	27.3	27.6	5.8	5.8	2.1	2.2	4199	72.5	4.5	6.2	68	68
14	30.3	30.1	7.9	7.7	2.2	2.2	4348	73.3	4.5	5.9	71	72
15	31.2	30.4	11.5	11.0	2.0	2.0	4697	75.5	4.8	5.6	78	79
16	25.8	26.4	7.7	7.7	1.9	1.9	3928	73.5	4.7	6.4	62	62
17	25.5	26.8	6.9	7.2	1.7	1.8	3621	72.1	4.6	6.8	54	54
18	25.8	26.1	8.3	8.2	1.7	1.8	4055	74.4	4.9	6.2	64	65
19	35.2	33.2	11.3	10.6	2.2	2.1	4940	77.7	5.5	5.2	86	87
20	36.7	35.1	10.7	10.1	1.9	1.8	4735	77.6	5.7	5.3	83	83
21	32.8	31.6	10.9	10.4	1.8	1.7	4662	76.8	5.7	5.4	81	81
22	32.6	30.6	12.5	11.5	2.2	2.1	4847	77.5	6.0	5.1	88	88
23	38.9	35.5	18.4	16.7	3.2	2.9	5182	79.0	6.2	4.5	95	95
24	34.0	32.3	9.6	9.1	2.9	2.8	5036	78.4	6.3	5.2	88	95
25	28.3	29.1	6.3	6.4	2.4	2.5	4468	75.8	6.1	6.4	67	85
26	25.7	27.6	5.0	5.3	2.1	2.3	4087	73.8	5.8	7.0	65	66
27	26.7	27.6	6.1	6.2	2.0	2.1	4474	75.6	6.0	6.5	74	75
28	26.6	28.2	7.3	7.5	1.9	2.0	4307	75.6	5.9	6.8	69	71
29	28.9	29.6	11.3	11.4	1.9	2.0	4623	77.0	5.9	6.4	77	78
30	32.0	30.6	15.5	14.8	2.0	1.9	5094	78.9	6.3	5.4	92	92
最大值	38.9	36.3	18.4	16.7	3.2	3.5	5182	79.0	6.3	8.7	95	95
最小值	22.9	26.1	2.6	3.1	1.7	1.7	1816	60.7	2.8	4.5	47	49
平均	29.5	29.8	8.6	8.5	2.2	2.2	4121	73.5	4.8	6.2	73	73

单位负责人: 李辉

审核人: 李中坚

报告人: 李晓寒

报告日期: 2025 年 5 月 6 日

深圳妈湾电力有限公司2025年4月#3烟囱烟气数据

浓度单位 (mg/Nm³) 烟气量单位 万立方米/天

日期	#3烟囱排放口										机组负荷率(%)	
	氮氧化物		二氧化硫		颗粒物		烟气量	温度℃	湿度%	氧量%	#5机组	#6机组
	干基	折算	干基	折算	干基	折算						
1	28.5	30.6	4.8	5.1	1.7	1.8	3266	75.5	2.7	7.0	56	51
2	30.8	33.5	4.7	5.1	1.4	1.6	3232	73.2	2.7	7.2	52	50
3	31.4	33.4	5.8	6.1	2.0	2.1	3359	71.9	2.9	6.9	56	52
4	26.2	33.7	3.8	4.9	2.0	2.6	2004	65.9	2.5	9.3	48	2: 16机组停运
5	24.7	30.2	5.1	6.1	1.9	2.3	2235	67.5	2.7	8.7	64	机组停运
6	26.8	32.1	3.8	4.6	1.9	2.4	2826	65.9	2.7	8.6	52	10: 20机组并网
7	29.6	31.5	5.0	5.3	1.8	1.9	3181	69.5	2.8	6.9	52	51
8	32.1	32.3	5.2	5.2	2.2	2.2	3796	69.8	3.2	6.1	76	58
9	34.1	34.1	5.5	5.5	2.2	2.2	3946	69.7	3.4	6.0	82	59
10	34.9	34.8	7.4	7.3	1.5	1.5	4005	69.9	3.5	6.0	81	61
11	33.6	33.6	8.1	8.1	1.6	1.6	3874	69.9	3.8	6.0	88	48
12	34.1	34.3	4.4	4.4	1.4	1.4	3858	71.1	3.8	6.1	78	58
13	32.5	33.5	3.9	4.0	2.0	2.0	3491	72.4	3.4	6.4	66	52
14	35.0	35.3	5.2	5.1	3.3	3.3	3630	70.5	3.6	6.1	72	55
15	33.6	33.7	7.2	7.1	2.0	2.0	3798	69.8	3.8	6.0	78	55
16	32.4	33.5	5.0	5.2	1.8	1.8	3436	69.5	3.6	6.4	62	53
17	31.7	33.5	4.7	4.9	1.8	1.9	3193	69.4	3.5	6.8	54	48
18	30.0	30.9	5.3	5.4	2.3	2.3	3502	70.7	3.7	6.4	65	52
19	35.1	35.3	5.8	5.8	5.5	5.5	3868	71.8	4.0	6.1	87	48
20	31.3	35.9	5.5	6.3	3.3	3.8	2898	68.7	3.9	7.9	81	4: 46机组停运
21	31.3	35.6	6.5	7.1	2.6	3.1	2631	66.6	4.1	7.8	81	机组停运
22	31.0	30.1	7.9	7.6	1.9	1.9	2488	69.8	4.6	5.5	89	机组停运
23	31.8	32.1	8.0	8.1	1.8	1.9	3765	70.6	4.8	6.1	95	10: 22机组并网
24	31.5	31.1	4.8	4.7	1.6	1.6	4088	72.2	4.6	5.8	94	54
25	33.5	33.1	3.7	3.6	1.5	1.5	3942	71.6	4.6	5.8	85	57
26	32.3	33.0	2.3	2.3	1.5	1.5	3439	71.0	4.2	6.3	64	52
27	29.3	29.5	2.5	2.6	1.5	1.5	3589	71.3	4.4	6.1	74	51
28	32.7	33.2	3.1	3.1	1.6	1.6	3541	71.3	4.5	6.2	68	52
29	31.7	32.4	5.2	5.2	1.8	1.8	3622	71.4	4.6	6.4	58	64
30	33.4	33.8	7.1	7.1	1.6	1.6	3874	72.0	4.8	6.2	53	80
最大值	35.1	35.9	8.1	8.1	5.5	5.5	4088	75.5	4.8	9.3	95	80
最小值	24.7	29.5	2.3	2.3	1.4	1.4	2004	65.9	2.5	5.5	48	48
平均	31.6	33.0	5.2	5.4	2.0	2.1	3413	70.3	3.7	6.6	70	55

单位负责人: 李辉

审核人: 李中坚

报告人: 李晓寒

报告日期: 2025 年 5 月 6 日