

深圳妈湾电力有限公司2025年5月#2烟囱烟气数据

浓度单位 (mg/Nm³) 烟气量单位 万立方米/天

日期	#2烟囱排放口										机组负荷率 (%)	
	氮氧化物		二氧化硫		颗粒物		烟气量	温度℃	湿度%	氧量%	#3机组	#4机组
	干基	折算	干基	折算	干基	折算						
1	29.1	29.8	12.7	12.6	1.9	1.9	4579	77.1	5.9	6.4	76	77
2	27.8	28.2	13.9	13.7	1.8	1.9	4613	78.0	5.9	6.2	77	78
3	28.7	27.9	14.3	13.7	2.0	2.0	5038	78.7	6.1	5.6	88	90
4	30.8	29.0	22.7	21.4	2.2	2.1	5178	80.1	6.5	5.1	93	94
5	29.6	27.6	27.3	25.4	2.4	2.2	5203	81.1	6.5	4.9	95	95
6	28.8	26.9	19.6	18.3	2.3	2.2	5185	80.2	6.4	4.9	95	96
7	25.8	25.2	12.4	11.9	2.3	2.2	4964	78.3	6.2	5.6	87	88
8	22.6	22.8	8.6	8.6	3.7	3.7	4552	77.3	6.1	6.2	94	60
9	29.8	28.7	13.6	13.1	4.0	3.8	5196	79.4	6.5	5.4	94	93
10	24.3	23.7	11.8	11.4	3.3	3.2	4981	78.6	6.5	5.6	88	88
11	25.2	27.8	8.1	8.6	2.7	2.9	3880	73.7	6.0	7.4	59	60
12	26.7	29.0	9.4	9.9	2.1	2.2	4107	75.1	5.7	7.2	63	64
13	26.9	29.0	10.3	10.6	2.1	2.3	4079	75.0	5.6	7.0	63	65
14	25.5	25.0	16.5	16.0	2.3	2.3	5043	79.2	6.3	5.7	87	88
15	30.4	29.5	17.9	17.2	2.5	2.5	5026	79.2	6.4	5.6	88	88
16	32.5	31.1	20.1	19.2	2.5	2.4	5172	79.2	6.5	5.3	92	93
17	29.3	27.9	22.3	21.3	2.8	2.7	5233	79.7	6.6	5.3	95	95
18	32.8	31.3	22.1	21.1	2.7	2.6	5200	80.0	6.7	5.3	93	95
19	30.8	28.9	20.7	19.5	1.9	1.8	5156	80.6	6.7	5.0	94	95
20	30.4	28.6	25.1	23.6	2.0	1.9	5174	81.0	6.6	5.1	94	94
21	29.1	27.8	23.9	22.7	1.9	1.8	5051	80.8	6.6	5.3	91	91
22	28.0	26.3	22.4	21.0	2.1	2.0	5127	81.4	6.7	5.0	95	95
23	27.8	25.9	27.3	25.4	1.9	1.8	5072	81.3	7.0	4.9	93	95
24	27.1	26.3	21.2	20.4	1.8	1.8	4898	80.3	6.9	5.5	88	88
25	24.7	26.9	10.9	11.7	1.4	1.6	4018	75.6	6.0	7.2	60	62
26	25.6	27.9	11.9	12.7	1.4	1.5	3962	75.6	5.9	7.2	60	59
27	25.6	27.3	13.1	13.6	2.0	2.1	4145	75.9	6.1	6.9	65	65
28	25.4	25.7	11.3	11.3	2.6	2.6	4787	78.5	6.5	6.1	80	81
29	23.4	25.5	6.5	7.0	2.0	2.3	3003	76.3	6.6	7.3	3: 49机组停运	85
30	15.0	21.9	3.0	4.3	2.6	3.8	2698	64.2	5.5	10.7	机组停运	60
31	#2烟囱停运										机组停运	7:07机组停运
最大值	32.8	31.3	27.3	25.4	4.0	3.8	5233	81.4	7.0	10.7	95	96
最小值	15.0	21.9	3.0	4.3	1.4	1.5	2698	64.2	5.5	4.9	59	59
平均	27.3	27.3	16.0	15.6	2.3	2.3	4677	78.0	6.3	6.0	84	83

单位负责人: 李辉

审核人: 李中坚

报告人: 李晓寒

报告日期: 2025 年6 月 5 日

深圳妈湾电力有限公司2025年5月#3烟囱烟气数据

浓度单位 (mg/Nm³) 烟气量单位 万立方米/天

日期	#3烟囱排放口										机组负荷率 (%)	
	氮氧化物		二氧化硫		颗粒物		烟气量	温度℃	湿度%	氧量%	#5机组	#6机组
	干基	折算	干基	折算	干基	折算						
1	#3烟囱停运										2: 56机组停运	0:05机组停运
2											机组停运	机组停运
3											机组停运	机组停运
4											8: 37并网发电	机组停运
5	34.6	35.4	10.0	10.1	3.2	3.4	3833	71.9	5.1	6.2	95	12: 22并网发电
6	34.5	32.6	8.7	8.2	2.5	2.4	4779	75.2	5.5	5.1	96	88
7	32.4	31.8	3.6	3.5	2.9	2.8	4033	72.4	4.9	5.7	87	60
8	31.7	30.6	4.0	3.9	2.4	2.4	4329	74.0	5.3	5.4	95	65
9	33.5	32.3	3.5	3.4	1.6	1.6	4334	74.0	5.2	5.5	95	66
10	28.9	28.3	3.0	2.9	1.8	1.8	3991	72.8	5.0	5.7	88	55
11	30.1	31.2	2.5	2.6	1.5	1.6	3319	71.7	4.4	6.5	60	50
12	29.5	30.3	3.6	3.6	1.5	1.6	3411	72.0	4.5	6.3	63	52
13	30.9	31.6	4.0	4.0	1.6	1.6	3548	72.3	4.6	6.3	64	57
14	29.6	28.8	6.5	6.3	1.8	1.8	4288	74.6	5.1	5.6	88	70
15	29.4	28.4	9.9	9.4	2.4	2.3	4422	75.8	5.4	5.5	88	78
16	27.3	25.9	10.7	10.1	1.6	1.6	4643	77.8	5.7	5.2	93	85
17	28.3	26.9	13.9	13.2	1.7	1.6	4741	77.7	5.7	5.2	92	90
18	28.1	26.7	10.5	10.0	1.9	1.9	4618	78.0	5.7	5.2	94	83
19	26.0	24.8	11.0	10.5	2.7	2.5	4676	79.5	5.8	5.3	95	85
20	26.5	25.4	11.9	11.4	2.7	2.6	4525	80.0	5.7	5.4	95	77
21	27.0	26.0	12.1	11.6	2.6	2.5	4526	83.0	5.7	5.4	91	80
22	27.2	25.6	11.7	11.0	1.9	1.8	4753	85.0	5.9	5.1	95	91
23	27.2	25.7	15.8	14.9	2.1	2.0	4749	85.2	6.0	5.1	95	90
24	28.0	27.2	11.3	10.9	2.2	2.2	4166	87.8	5.6	5.5	88	71
25	30.1	30.8	4.0	4.1	1.7	1.7	3265	85.4	4.9	6.3	61	51
26	30.0	31.1	4.2	4.3	1.6	1.7	3157	84.3	4.7	6.5	57	49
27	28.9	29.7	5.3	5.2	1.6	1.7	3384	79.4	4.7	6.2	65	58
28	28.6	28.1	7.9	7.6	1.5	1.5	4671	68.3	5.5	5.7	81	72
29	28.6	28.0	3.1	3.1	1.5	1.5	4885	69.0	5.5	5.7	85	69
30	28.6	29.7	1.8	1.9	1.4	1.5	4075	67.3	4.9	6.5	58	55
31	26.4	30.6	1.4	1.6	1.0	1.1	2316	63.4	4.4	8.0	52	1: 06机组停运
最大值	34.6	35.4	15.8	14.9	3.2	3.4	4885	87.8	6.0	8.0	96	91
最小值	26.0	24.8	1.4	1.6	1.0	1.1	2316	63.4	4.4	5.1	52	49
平均	29.3	29.0	7.3	7.0	2.0	1.9	4127	76.2	5.2	5.8	82	70