



深圳妈湾电力有限公司2025年6月#2烟囱烟气数据

浓度单位 (mg/Nm³) 烟气量单位 万立方米/天

日期	#2烟囱排放口										机组负荷率(%)	
	氮氧化物		二氧化硫		颗粒物		烟气量	温度℃	湿度%	氧量%	#3机组	#4机组
	干基	折算	干基	折算	干基	折算						
1	烟囱停运										13: 29并网发电	机组停运
2	30.7	30.8	16.0	16.1	3.0	3.0	4223	80.0	6.6	6.0	92	8: 42并网发电
3	26.9	26.3	10.8	10.4	2.6	2.5	4530	80.0	6.3	5.7	79	78
4	25.3	25.8	5.0	5.0	2.2	2.3	4283	78.7	6.2	6.3	69	70
5	27.3	28.2	3.9	3.9	1.8	1.9	3882	77.8	5.9	6.5	60	64
6	30.3	30.4	8.0	7.7	2.0	2.0	4352	79.3	6.2	6.0	73	72
7	30.1	29.5	15.1	14.5	2.4	2.4	4486	80.7	6.3	5.7	78	78
8	29.4	28.2	11.8	11.1	2.2	2.1	4739	81.8	6.6	5.4	85	84
9	33.2	31.3	23.3	22.0	2.4	2.3	4981	82.4	6.7	5.1	90	89
10	31.5	29.9	22.3	21.1	3.1	3.0	4912	82.8	6.6	5.2	89	88
11	30.4	28.9	21.1	19.8	2.1	2.0	4641	82.1	6.6	5.3	84	84
12	26.8	27.6	11.8	11.9	1.8	1.9	3782	78.5	6.2	6.5	60	62
13	28.7	28.6	17.8	17.4	2.0	2.0	4300	79.6	6.6	5.9	73	73
14	31.6	31.4	14.0	13.6	1.7	1.7	4286	80.6	6.6	5.9	72	73
15	28.4	30.0	10.1	10.5	1.3	1.4	3754	79.2	6.7	6.8	58	58
16	27.8	28.0	15.4	15.2	1.4	1.4	4323	81.2	6.9	6.1	72	73
17	25.9	27.6	8.2	8.7	1.2	1.2	3677	77.9	6.5	6.9	56	56
18	29.4	29.4	12.1	11.8	1.6	1.6	4290	81.0	6.8	6.0	72	72
19	28.3	29.0	9.5	9.5	1.8	1.8	4063	80.9	6.5	6.4	67	66
20	26.8	28.1	7.8	8.0	1.6	1.7	3789	79.5	6.5	6.7	59	58
21	26.7	27.8	12.1	12.2	1.8	1.8	3871	79.5	6.5	6.6	61	62
22	27.6	29.8	7.4	7.9	1.6	1.7	3409	78.4	6.3	7.1	51	52
23	28.7	29.8	10.7	10.7	2.1	2.1	3872	79.3	6.5	6.5	62	62
24	29.0	29.1	11.2	11.0	2.1	2.1	4273	80.2	6.5	6.0	71	72
25	30.5	29.6	17.4	16.6	2.5	2.4	4735	81.5	6.8	5.6	82	84
26	33.0	32.6	12.6	12.2	2.3	2.2	4451	80.0	6.6	5.9	76	77
27	34.0	33.4	17.7	17.1	2.2	2.1	4495	79.9	6.6	5.8	77	79
28	34.6	34.4	17.5	17.0	2.5	2.4	4493	80.1	6.7	5.9	75	78
29	32.1	34.7	8.1	8.7	2.0	2.1	3352	77.6	6.0	7.1	50	52
30	30.9	32.1	11.3	11.5	2.6	2.7	3753	78.5	6.1	6.5	59	61
最大值	34.6	34.7	23.3	22.0	3.1	3.0	4981	82.8	6.9	7.1	92	89
最小值	25.3	25.8	3.9	3.9	1.2	1.2	3352	77.6	5.9	5.1	50	52
平均	29.5	29.7	12.8	12.5	2.1	2.1	4207	80.0	6.5	6.1	71	71

单位负责人: 李辉

审核人: 李中坚

报告人: 李晓寒

报告日期: 2025 年 7 月 2 日



深圳妈湾电力有限公司2025年6月#3烟囱烟气数据

浓度单位 (mg/Nm³) 烟气量单位 万立方米/天

日期	#3烟囱排放口										机组负荷率 (%)	
	氮氧化物		二氧化硫		颗粒物		烟气量	温度℃	湿度%	氧量%	#5机组	#6机组
	干基	折算	干基	折算	干基	折算						
1	27.8	30.8	4.5	4.7	1.0	1.1	2863	64.1	4.8	7.4	65	机组停运
2	26.9	27.0	10.8	10.9	1.5	1.5	3246	66.9	5.6	6.1	90	机组停运
3	29.4	32.2	4.2	4.5	1.7	1.9	4324	64.6	5.0	6.9	76	6: 21并网发电
4	27.2	27.8	1.6	1.6	1.6	1.6	4199	66.8	5.0	6.3	68	50
5	28.0	29.1	1.9	1.9	1.6	1.6	3976	67.9	4.9	6.6	61	51
6	27.9	28.3	5.6	5.4	1.7	1.8	4436	67.7	5.2	6.1	71	62
7	26.2	26.0	16.0	15.4	2.2	2.1	4608	68.8	5.4	5.9	78	68
8	26.6	26.0	8.1	7.7	2.4	2.4	5033	69.2	5.7	5.7	82	79
9	26.2	25.1	17.2	16.5	2.0	1.9	5027	69.7	5.9	5.4	88	82
10	25.4	24.3	16.1	15.3	1.9	1.8	4960	70.2	6.0	5.4	89	78
11	25.8	25.2	13.6	13.0	2.3	2.2	4755	69.6	6.0	5.6	84	77
12	26.8	27.5	5.8	5.8	2.0	2.1	3749	68.0	5.5	6.3	63	59
13	28.3	28.4	9.3	9.1	1.7	1.7	3988	67.5	5.7	6.1	72	61
14	27.5	27.5	8.9	8.5	1.4	1.4	4177	69.3	6.0	5.9	72	70
15	28.3	29.5	3.1	3.2	1.0	1.1	3372	68.0	5.5	6.6	58	48
16	27.4	27.6	8.2	8.1	1.1	1.1	4036	69.5	5.9	6.1	72	64
17	27.8	29.2	1.8	1.9	1.1	1.1	3436	67.6	5.4	6.7	55	48
18	28.6	28.7	8.6	8.3	1.2	1.2	4226	70.1	5.9	6.1	70	70
19	26.7	27.4	4.1	4.1	1.2	1.2	3894	69.8	5.6	6.4	64	60
20	28.6	29.6	3.2	3.3	1.2	1.3	3638	68.6	5.4	6.5	59	54
21	28.7	29.9	3.6	3.7	1.1	1.2	3667	68.9	5.5	6.6	61	53
22	28.8	30.9	1.9	2.1	1.1	1.2	3366	68.6	5.3	7.0	51	47
23	29.5	30.5	3.4	3.4	1.1	1.1	3939	70.0	5.6	6.4	61	58
24	29.2	29.3	5.0	4.9	1.1	1.1	4215	69.9	5.8	6.0	70	64
25	29.0	28.3	13.1	12.5	1.1	1.1	4719	69.7	5.9	5.6	83	80
26	29.1	29.0	6.2	6.0	1.2	1.2	4337	68.2	5.8	5.9	76	69
27	28.9	28.6	10.2	9.8	1.5	1.5	4571	68.9	5.8	5.8	78	75
28	29.2	28.9	11.2	10.7	1.8	1.8	4403	68.9	5.9	5.8	76	71
29	30.4	32.2	3.2	3.4	1.4	1.4	3216	68.0	5.3	6.8	49	48
30	30.9	31.9	4.3	4.4	1.5	1.6	3449	66.8	5.2	6.5	59	48
最大值	30.9	32.2	17.2	16.5	2.4	2.4	5033	70.2	6.0	7.4	90	82
最小值	25.4	24.3	1.6	1.6	1.0	1.1	2863	64.1	4.8	5.4	49	47
平均	28.0	28.6	7.2	7.0	1.5	1.5	4061	68.4	5.6	6.2	70	63

单位负责人：李辉

审核人：李中坚

报告人：李晓寒

报告日期：2025 年 7 月 2 日