

深圳妈湾电力有限公司2025年9月#2烟囱烟气数据

浓度单位 (mg/Nm³) 烟气量单位 万立方米/天

日期	#2烟囱排放口										机组负荷率 (%)	
	氮氧化物		二氧化硫		颗粒物		烟气量	温度℃	湿度%	氧量%	#3机组	#4机组
	干基	折算	干基	折算	干基	折算						
1	31.1	29.7	29.4	28.1	4.4	4.2	5056	80.9	6.7	5.3	90	89
2	31.4	29.9	26.5	25.2	3.9	3.7	5011	80.8	6.7	5.3	91	92
3	30.8	29.2	25.1	23.8	4.4	4.1	4974	80.0	6.9	5.2	92	92
4	30.0	28.8	23.5	22.6	4.6	4.4	4998	81.0	6.9	5.4	91	92
5	30.2	28.8	22.8	21.7	4.2	4.0	4987	81.4	7.1	5.2	92	92
6	29.0	27.6	22.7	21.6	4.6	4.4	4968	81.8	7.1	5.2	92	92
7	26.3	25.7	20.2	19.6	4.0	3.9	4734	80.3	7.1	5.6	84	86
8	28.8	29.4	13.9	13.9	4.3	4.3	4314	76.6	6.8	6.3	73	74
9	30.6	30.6	20.8	20.5	3.8	3.8	4321	79.2	7.0	6.0	75	76
10	31.8	31.1	19.0	18.5	4.2	4.1	4701	81.0	7.1	5.7	83	84
11	29.2	28.9	16.7	16.3	4.0	3.9	4660	81.3	7.2	5.8	82	82
12	29.0	28.0	17.1	16.3	4.0	3.8	4692	81.9	7.2	5.5	84	84
13	26.9	25.9	11.6	11.1	4.0	3.8	4812	81.8	7.3	5.4	88	85
14	26.4	26.3	13.7	13.4	3.6	3.5	4573	80.3	7.2	5.9	84	75
15	27.9	27.0	16.2	15.5	4.0	3.9	4763	80.7	7.2	5.5	85	85
16	27.1	26.6	17.1	16.6	4.2	4.1	4655	81.2	7.3	5.7	83	84
17	27.2	26.2	22.1	21.2	4.3	4.1	4749	81.4	7.3	5.4	87	84
18	24.7	24.5	16.7	16.5	4.8	4.7	4590	80.5	7.2	5.9	83	77
19	23.6	23.4	18.5	18.1	4.5	4.5	4509	79.8	7.1	5.9	81	76
20	21.6	22.0	14.4	14.4	3.4	3.5	4249	78.0	7.1	6.3	74	72
21	21.9	24.3	5.5	6.0	2.8	3.1	3422	77.0	6.8	7.4	51	52
22	21.0	22.8	9.7	10.4	3.3	3.6	3802	79.3	6.8	7.1	59	59
23	20.9	23.3	6.4	7.0	3.0	3.3	3350	78.9	6.3	7.5	50	50
24	21.2	23.5	4.5	4.9	2.7	3.0	3340	75.5	5.9	7.5	48	48
25	22.5	23.7	9.2	9.4	3.1	3.3	3888	78.7	6.3	6.8	62	61
26	23.0	23.6	11.5	11.5	3.7	3.7	4277	79.8	6.6	6.4	70	72
27	23.9	23.5	18.9	18.4	3.1	3.0	4596	80.9	6.8	5.8	81	81
28	26.9	26.0	25.0	24.0	3.2	3.1	4746	80.9	6.7	5.5	85	85
29	27.9	27.0	24.1	23.2	3.3	3.2	4682	80.9	6.7	5.5	85	85
30	25.1	25.0	18.5	18.4	2.6	2.6	4301	81.1	6.7	6.0	90	59
最大值	31.8	31.1	29.4	28.1	4.8	4.7	5056	81.9	7.3	7.5	92	92
最小值	20.9	22.0	4.5	4.9	2.6	2.6	3340	75.5	5.9	5.2	48	48
平均	26.6	26.4	17.4	16.9	3.8	3.8	4491	80.1	6.9	5.9	79	77

单位负责人：李辉

审核人：李中坚

报告人：李晓寒

报告日期：2025 年 10 月 11 日

深圳妈湾电力有限公司2025年9月#3烟囱烟气数据

浓度单位 (mg/Nm³)

烟气量单位 万立方米/天

日期	#3烟囱排放口										机组负荷率 (%)	
	氮氧化物		二氧化硫		颗粒物		烟气量	温度℃	湿度%	氧量%	#5机组	#6机组
	干基	折算	干基	折算	干基	折算						
1	29.4	28.1	22.7	21.6	2.5	2.4	4360	69.3	5.9	5.3	89	64
2	29.4	27.8	23.4	22.1	2.6	2.4	4513	69.4	5.9	5.2	90	70
3	29.3	27.6	24.5	23.0	2.7	2.5	4634	70.0	5.9	5.1	92	77
4	29.4	27.4	23.9	22.2	2.7	2.5	4534	70.5	6.1	4.9	91	76
5	30.7	28.4	24.6	22.8	3.2	3.0	4837	71.2	6.3	4.8	92	89
6	29.9	27.9	22.6	21.0	2.8	2.6	4526	70.5	6.3	4.9	91	78
7	28.9	27.5	13.1	12.3	2.5	2.4	4024	69.4	6.2	5.2	84	63
8	26.7	26.1	9.9	9.6	2.2	2.2	3569	66.6	6.0	5.6	72	50
9	29.2	28.0	18.5	17.5	2.0	1.9	3866	69.1	6.1	5.4	75	61
10	28.1	27.0	12.4	11.8	2.1	2.0	4005	70.6	6.2	5.4	83	60
11	29.0	28.1	9.8	9.2	2.1	2.1	3951	70.6	6.2	5.5	81	58
12	31.3	29.8	10.1	9.5	2.2	2.1	4131	71.6	6.4	5.3	83	66
13	32.0	30.2	6.4	6.0	2.4	2.2	4318	71.5	6.4	5.1	89	69
14	30.9	29.6	7.7	7.2	2.3	2.2	4094	70.8	6.1	5.4	84	61
15	31.1	29.8	7.1	6.8	2.1	2.0	4088	70.4	6.3	5.4	86	60
16	28.2	27.5	6.5	6.2	2.1	2.1	3935	71.4	6.2	5.6	82	57
17	29.0	27.7	12.5	11.9	2.2	2.1	4174	71.1	6.3	5.3	88	64
18	29.1	28.4	7.7	7.5	2.0	2.0	3792	70.4	6.1	5.7	82	54
19	28.5	28.0	8.0	7.8	2.0	2.0	3748	69.5	6.0	5.8	79	53
20	26.8	27.0	3.1	3.1	2.0	2.0	3530	68.3	5.7	6.1	71	50
21	27.1	28.0	1.1	1.1	1.7	1.8	3038	67.6	5.4	6.5	49	48
22	27.6	28.0	2.2	2.3	1.7	1.7	3448	68.8	5.5	6.2	58	48
23	29.1	30.5	1.9	2.0	1.8	1.9	2918	68.8	5.3	6.7	49	18:32机组停运
24	29.8	30.9	2.0	2.1	2.2	2.3	1912	64.3	4.9	6.6	48	机组停运
25	31.7	31.9	4.0	3.9	2.8	2.7	2270	65.9	5.4	6.1	62	机组停运
26	31.9	31.4	6.6	6.3	3.3	3.2	2312	67.7	5.5	5.7	72	机组停运
27	31.2	30.1	12.3	11.7	4.0	3.8	2406	67.6	5.7	5.4	81	机组停运
28	29.4	31.0	12.7	13.0	2.8	3.0	3644	66.2	5.4	6.6	84	11:16并网发电
29	26.6	26.0	16.0	15.6	2.3	2.3	4032	69.9	5.5	5.7	85	48
30	25.7	24.5	17.2	16.3	2.5	2.4	4418	70.8	5.8	5.2	92	66
最大值	32.0	31.9	24.6	23.0	4.0	3.8	4837	71.6	6.4	6.7	92	89
最小值	25.7	24.5	1.1	1.1	1.7	1.7	1912	64.3	4.9	4.8	48	48
平均	29.2	28.5	11.7	11.1	2.4	2.3	3768	69.3	5.9	5.6	79	62

单位负责人: 李辉

审核人: 李中坚

报告人: 李晓寒

报告日期: 2025 年 10 月 11 日