

深圳妈湾电力有限公司2025年10月#2烟囱烟气数据

浓度单位 (mg/m³) 烟气量单位 万立方米/天

日期	#2烟囱排放口										机组负荷率 (%)	
	氮氧化物		二氧化硫		颗粒物		烟气量	温度℃	湿度%	氧量%	#3机组	#4机组
	干基	折算	干基	折算	干基	折算						
1	22.7	24.5	8.0	8.3	2.4	2.6	3648	78.6	6.4	7.0	64	51
2	25.8	27.4	8.7	8.8	2.3	2.4	3579	78.2	6.4	6.8	58	57
3	24.6	26.4	11.3	11.6	2.2	2.3	3615	78.0	6.4	7.0	56	58
4	24.5	26.1	9.4	9.5	2.1	2.2	3687	79.6	6.6	6.9	59	60
5	23.1	25.4	5.2	5.7	1.5	1.7	3414	77.7	6.5	7.4	50	51
6	21.0	23.4	3.4	3.8	1.6	1.8	3151	75.8	6.5	7.6	46	46
7	29.0	29.5	11.5	11.3	2.6	2.6	4085	78.6	6.9	6.3	68	68
8	29.9	28.7	20.4	19.5	3.6	3.5	4919	81.0	7.1	5.3	88	89
9	29.4	28.2	21.2	20.3	3.3	3.1	4879	81.0	7.2	5.4	88	89
10	27.1	26.2	21.7	20.9	2.4	2.4	4790	80.9	7.2	5.5	86	87
11	28.9	28.6	21.0	20.4	2.2	2.1	4528	80.8	7.0	5.8	79	80
12	29.2	27.7	27.7	26.2	1.6	1.5	4857	81.2	7.2	5.2	89	89
13	33.0	30.7	32.6	30.3	2.2	2.0	4938	81.5	7.2	4.9	93	94
14	30.4	28.5	30.0	28.1	2.1	2.0	4906	81.5	7.1	5.0	93	91
15	32.4	30.1	30.4	28.2	2.2	2.1	4868	81.5	7.1	4.9	92	91
16	31.9	29.9	30.5	28.6	2.5	2.3	4921	81.5	7.2	5.0	92	92
17	31.5	29.3	22.4	20.9	2.1	2.0	4975	81.1	7.2	4.9	94	92
18	32.3	30.0	18.9	17.6	2.0	1.8	5003	81.2	7.3	4.8	94	94
19	26.6	25.0	18.7	17.5	2.2	2.1	4926	80.6	7.3	5.1	91	92
20	21.1	21.9	11.8	12.0	2.0	2.1	4030	77.4	6.7	6.6	68	66
21	21.5	22.6	13.8	14.0	1.2	1.3	3865	75.8	6.7	6.7	64	61
22	23.0	25.8	4.9	5.4	2.3	2.6	3339	72.4	6.1	7.7	49	48
23	25.6	27.6	7.5	7.9	2.4	2.6	3626	73.2	5.9	7.1	57	56
24	24.7	27.3	5.1	5.6	2.5	2.7	3364	73.4	5.7	7.4	49	50
25	25.4	28.0	5.2	5.7	2.5	2.7	3461	74.6	5.6	7.3	52	52
26	25.8	28.5	4.8	5.2	2.7	3.0	3461	75.5	5.5	7.4	51	51
27	26.9	29.7	5.1	5.4	2.6	2.9	3511	75.0	5.5	7.4	52	52
28	27.0	30.5	5.1	5.7	2.5	2.8	3272	73.2	5.4	7.7	48	47
29	27.6	30.6	6.2	6.8	2.4	2.7	3290	73.8	5.4	7.5	47	51
30	28.4	30.7	8.3	8.8	2.7	2.9	3689	75.5	5.6	7.1	57	57
31	29.3	29.8	12.0	12.1	3.1	3.2	4436	77.9	5.9	6.3	74	74
最大值	33.0	30.7	32.6	30.3	3.6	3.5	5003	81.5	7.3	7.7	94	94
最小值	21.0	21.9	3.4	3.8	1.2	1.3	3151	72.4	5.4	4.8	46	46
平均	27.1	27.7	14.3	13.9	2.3	2.4	4098	78.0	6.5	6.4	69	69

单位负责人：李辉

审核人：李中坚

报告人：李晓寒

报告日期： 2025 年 11 月 4 日

深圳妈湾电力有限公司2025年10月#3烟囱烟气数据

浓度单位: (mg/Nm³) 烟气量单位: 万立方米/天

日期	#3烟囱排放口										机组负荷率 (%)	
	氮氧化物		二氧化硫		颗粒物		烟气量	温度℃	湿度%	氧量%	#5机组	#6机组
	干基	折算	干基	折算	干基	折算						
1	27.1	29.1	5.9	6.0	2.4	2.6	2041	67.9	5.4	7.0	64	1:58机组停运
2	26.7	28.9	5.7	5.8	2.5	2.7	1989	66.1	5.2	7.1	58	机组停运
3	27.0	29.0	6.0	5.9	3.5	3.8	1937	66.3	5.3	6.9	58	机组停运
4	28.5	29.4	4.9	4.8	2.3	2.4	1958	67.7	5.4	6.5	59	机组停运
5	28.7	30.6	2.3	2.4	2.0	2.1	1864	66.3	5.2	6.9	51	机组停运
6	25.9	28.2	1.7	1.9	1.9	2.0	1755	66.4	5.1	7.1	48	机组停运
7	24.9	24.8	9.8	9.3	1.8	1.8	2156	66.9	5.6	6.0	66	机组停运
8	25.7	25.5	19.1	18.7	1.8	1.8	3733	67.3	6.1	5.8	87	11:55并网发电
9	24.0	22.5	16.9	15.7	1.9	1.7	4409	69.2	6.1	5.0	86	70
10	25.2	23.4	17.1	15.8	2.1	1.9	4664	69.6	6.1	4.9	85	83
11	27.3	25.8	16.5	15.3	1.8	1.7	4258	70.0	6.1	5.1	77	75
12	29.3	27.2	21.5	19.9	2.0	1.9	4650	70.1	6.2	4.8	88	83
13	29.7	27.5	18.6	17.1	2.1	2.0	4843	70.4	6.2	4.7	85	92
14	29.1	28.2	17.9	17.2	2.6	2.5	2755	71.2	6.4	5.5	2:28机组停运	90
15	24.2	26.9	16.0	17.4	3.7	4.4	3137	67.0	5.8	7.6	机组停运	91
16	26.7	28.0	15.2	15.8	2.9	3.1	2893	67.8	5.8	6.7	机组停运	93
17	32.7	30.9	21.0	19.8	2.8	2.6	2525	70.5	6.3	5.1	机组停运	92
18	31.6	30.0	20.2	19.2	2.8	2.7	2603	70.5	6.4	5.2	机组停运	95
19	29.3	28.4	17.0	16.3	2.4	2.3	2581	69.6	6.2	5.5	机组停运	88
20	25.6	26.5	7.2	7.3	2.2	2.2	1993	66.1	5.5	6.6	机组停运	63
21	25.6	27.1	6.8	7.0	2.0	2.1	2032	64.1	5.2	6.8	机组停运	58
22	26.5	29.5	4.2	4.6	2.0	2.2	2074	61.1	4.7	7.5	机组停运	49
23	25.8	28.2	4.5	4.9	1.9	2.1	2069	61.7	4.6	7.3	机组停运	54
24	24.6	27.8	3.6	4.0	2.1	2.4	1899	62.5	4.4	7.7	机组停运	50
25	29.2	32.3	4.3	4.7	2.0	2.2	1890	63.6	4.4	7.4	机组停运	52
26	21.8	24.2	4.3	4.8	2.2	2.4	1992	64.4	4.4	7.5	机组停运	52
27	25.1	27.6	4.2	4.6	2.1	2.3	1988	63.7	4.4	7.4	机组停运	52
28	25.9	28.5	4.0	4.4	2.0	2.2	1924	62.8	4.2	7.4	机组停运	49
29	25.2	28.1	4.4	4.9	2.1	2.4	2012	63.3	4.2	7.5	机组停运	49
30	27.2	29.3	6.2	6.6	2.3	2.5	2126	65.0	4.5	7.1	机组停运	58
31	26.3	28.9	4.8	5.2	2.3	2.5	2061	65.1	4.5	7.3	机组停运	54
最大值	32.7	32.3	21.5	19.9	3.7	4.4	4843	71.2	6.4	7.7	88	95
最小值	21.8	22.5	1.7	1.9	1.8	1.7	1755	61.1	4.2	4.7	48	49
平均	26.9	27.8	10.1	9.9	2.3	2.4	2607	66.6	5.3	6.5	70	69

单位负责人: 李辉

审核人: 李中坚

报告人: 李晓寒

报告日期: 2025 年 11 月 4 日

深圳妈湾电力有限公司2025年10月#4烟囱烟气数据

日期	#4烟囱排放口										机组负荷率
	氮氧化物		二氧化硫		颗粒物		烟气量	温度℃	湿度%	氧量%	#7机组
	干基	折算	干基	折算	干基	折算					
1	机组停运										
2											
3											
4											
5											
6											
7											
8											
9	5.87	6.02	0.17	0.16	0.019	0.017	1601.27	54.53	4.97	17.87	28
10	5.14	4.61	0.20	0.18	0.017	0.014	1872.20	73.11	5.76	17.47	34
11	5.42	4.98	0.16	0.14	0.015	0.013	1783.10	71.86	5.55	17.63	34
12	0.78	0.68	0.02	0.02	0.002	0.002	188.39	60.17	2.63	20.20	45
13	5.42	4.50	0.26	0.21	0.037	0.029	3475.16	81.37	8.78	15.39	43
14	3.82	3.37	0.22	0.18	0.020	0.016	2342.18	75.33	6.92	16.78	38
15	5.77	4.95	0.28	0.23	0.024	0.019	2583.80	75.38	7.12	16.54	41
16	5.97	4.94	0.31	0.24	0.022	0.018	2746.61	76.61	7.20	16.36	44
17	7.59	6.39	0.19	0.16	0.024	0.019	2849.66	75.13	7.42	16.13	42
18	8.10	6.55	0.12	0.10	0.026	0.020	3148.80	78.26	7.71	16.18	51
19	1.70	1.50	0.02	0.02	0.003	0.003	338.74	62.54	2.59	19.90	42
20	4.74	4.09	0.07	0.06	0.026	0.021	3313.31	80.65	7.04	15.41	41
21	1.07	0.94	0.01	0.01	0.002	0.002	202.01	53.11	1.23	19.91	45
22	机组停运										
23											
24											
25											
26											
27	7.96	7.28	0.08	0.08	0.016	0.014	1629.80	57.49	3.80	17.70	30
28	4.08	3.50	0.04	0.04	0.010	0.008	1106.53	61.90	2.92	18.52	34
29	3.76	3.24	0.07	0.06	0.009	0.008	1154.38	61.14	3.16	18.45	34
30	机组停运										
31											
最大值	8.1	7.3	0.3	0.2	0.037	0.029	3475	81.4	8.8	20.2	51
最小值	0.8	0.7	0.0	0.0	0.002	0.002	188	53.1	1.2	15.4	28
平均	4.8	4.2	0.1	0.1	0.017	0.014	1896	68.7	5.3	17.5	39

单位负责人：李辉

审核人：李中坚

报告人：李晓寒

报告日期：2025 年 11 月 4 日