

深圳妈湾电力有限公司2025年11月#2烟囱烟气数据

浓度单位 (mg/Nm³) 烟气量单位 万立方米/天

日期	#2烟囱排放口						机组负荷率 (%)					
	氮氧化物		二氧化硫		颗粒物		烟气量	温度℃	湿度%	氧量%	#3机组	#4机组
	干基	折算	干基	折算	干基	折算						
1	27.1	28.4	11.3	11.7	2.7	2.8	4162	76.5	5.8	6.7	66	66
2	27.1	29.3	10.3	10.9	2.4	2.6	3809	76.1	5.6	7.1	59	58
3	27.4	28.2	13.3	13.4	2.6	2.7	4460	77.0	5.8	6.4	73	73
4	26.7	26.8	14.4	14.1	2.8	2.8	4563	76.6	5.8	6.0	78	79
5	23.5	24.6	8.6	8.6	3.0	3.1	4030	74.6	5.3	6.7	67	65
6	25.4	26.8	8.2	8.3	2.9	3.0	3873	75.3	5.2	6.8	63	62
7	24.0	25.0	7.4	7.4	3.3	3.4	4043	76.9	5.5	6.6	66	65
8	25.9	24.6	15.2	14.3	3.9	3.7	4842	80.4	6.0	5.2	87	88
9	24.7	23.9	13.1	12.5	4.0	3.9	4692	79.2	6.1	5.5	85	85
10	17.7	19.1	3.9	4.1	3.2	3.5	3810	75.4	5.4	7.1	59	59
11	20.9	22.2	3.5	3.7	3.3	3.5	3919	76.0	5.4	6.8	56	66
12	19.9	21.2	3.5	3.7	3.2	3.4	3941	76.0	5.3	6.9	61	60
13	20.1	21.1	3.5	3.6	3.3	3.4	4161	75.9	5.3	6.7	67	64
14	23.3	25.0	3.4	3.6	3.0	3.2	3981	75.6	5.2	7.0	62	58
15	23.1	24.4	4.6	4.8	3.5	3.7	4157	76.9	5.3	6.8	60	68
16	25.8	28.1	4.2	4.5	3.0	3.2	3836	75.8	5.0	7.2	54	59
17	25.9	26.8	5.5	5.7	3.5	3.7	4317	77.7	5.4	6.5	63	74
18	24.6	25.5	5.2	5.3	3.2	3.3	4357	76.2	5.3	6.5	63	74
19	22.0	23.1	5.3	5.5	3.2	3.3	4140	71.8	4.9	6.7	60	67
20	22.8	23.8	9.5	9.8	3.0	3.2	4223	72.8	4.7	6.6	61	72
21	20.1	21.3	9.5	10.0	2.9	3.1	4085	72.9	4.4	6.9	58	65
22	21.7	23.0	10.6	11.0	2.6	2.7	4108	73.3	4.3	6.9	60	67
23	23.7	24.8	11.2	11.6	2.7	2.9	4194	74.2	4.4	6.7	60	72
24	20.4	21.0	10.1	10.1	3.0	3.0	4211	75.7	4.4	6.4	68	67
25	20.7	22.4	7.7	8.2	2.5	2.7	3920	73.8	4.3	7.1	55	61
26	22.7	24.3	8.0	8.4	2.1	2.2	4049	73.4	4.2	7.0	57	64
27	22.3	24.0	9.2	9.7	2.3	2.4	4015	72.9	4.2	7.0	55	64
28	23.9	24.7	10.3	10.5	2.2	2.3	4106	73.5	4.1	6.5	60	69
29	23.6	24.5	11.7	12.0	2.2	2.3	4125	73.6	4.1	6.5	60	68
30	26.1	26.4	11.7	11.8	2.1	2.1	4224	75.2	4.3	6.2	63	73
最大值	27.4	29.3	15.2	14.3	4.0	3.9	4842	80.4	6.1	7.2	87	88
最小值	17.7	19.1	3.4	3.6	2.1	2.1	3809	71.8	4.1	5.2	54	58
平均	23.4	24.5	8.5	8.6	2.9	3.0	4145	75.4	5.0	6.6	64	68

单位负责人：李辉

审核人：李中坚

报告人：李晓寒

报告日期：2025年12月3日

深圳妈湾电力有限公司2025年11月#3烟囱烟气数据

浓度单位 (mg/Nm³) 烟气量单位 万立方米/天

日期	#3烟囱排放口							机组负荷率 (%)				
	氮氧化物		二氧化硫		颗粒物		烟气量	温度℃	湿度%	氧量%	#5机组	#6机组
	干基	折算	干基	折算	干基	折算						
1	26.2	29.2	4.9	5.5	2.3	2.5	2182	64.9	4.4	7.6	机组停运	52
2	25.7	28.9	5.1	5.7	2.1	2.4	2016	64.5	4.2	7.6	机组停运	49
3	27.9	29.6	6.9	7.2	2.2	2.3	2536	64.0	4.3	6.9	机组停运	69
4	25.8	29.3	4.2	4.7	2.5	2.8	2308	61.4	3.9	7.8	机组停运	58
5	26.6	28.3	4.8	5.0	3.3	3.6	2162	65.1	4.5	6.9	机组停运	63
6	24.1	28.8	5.4	6.3	3.2	3.9	2741	62.3	4.3	8.4	机组停运	64
7	25.2	30.6	5.0	5.6	2.7	3.4	2829	65.5	4.5	8.3	机组停运	69
8	25.0	25.2	9.0	9.0	2.1	2.1	2474	69.0	5.0	6.1	机组停运	81
9	18.3	20.6	3.6	4.0	2.4	2.7	2201	66.5	4.4	7.7	机组停运	59
10	20.1	23.0	2.5	2.8	2.4	2.7	2012	64.9	4.2	7.8	机组停运	53
11	22.9	24.9	2.9	3.2	2.0	2.2	2492	65.2	4.4	7.2	机组停运	67
12	16.8	20.4	2.3	2.8	2.2	2.6	2268	61.2	3.8	8.6	机组停运	50
13	17.2	19.1	2.3	2.6	2.3	2.6	1830	63.0	3.9	7.5	机组停运	50
14	21.6	23.2	1.6	1.7	3.0	3.2	1584	63.8	4.1	7.0	机组停运	50
15	#5、#6机停运										机组停运	1:29机组停运
16											机组停运	机组停运
17											机组停运	机组停运
18											机组停运	机组停运
19											12:31并网发电	机组停运
20	18.7	21.6	3.2	3.6	2.4	2.8	1638	68.3	3.4	7.9	56	机组停运
21	18.0	21.3	4.1	4.7	2.3	2.7	1632	69.3	3.2	8.2	54	机组停运
22	24.3	26.6	6.5	7.0	2.1	2.3	1933	71.6	3.4	7.1	68	机组停运
23	25.5	27.3	6.8	7.2	1.9	2.1	2007	73.1	3.4	6.9	72	机组停运
24	22.6	24.4	6.5	6.9	2.1	2.2	1933	73.7	3.5	7.0	70	机组停运
25	23.2	26.8	5.4	6.2	2.1	2.4	1800	72.3	3.2	8.0	59	机组停运
26	23.7	27.3	5.1	5.8	2.0	2.3	1757	71.6	3.4	7.9	58	机组停运
27	23.7	26.7	6.4	7.0	2.0	2.2	1740	70.9	3.3	7.6	60	机组停运
28	23.4	26.2	7.5	8.3	2.2	2.5	1911	71.7	3.3	7.6	65	机组停运
29	22.5	25.3	7.8	8.7	2.2	2.5	1959	72.1	3.4	7.6	66	机组停运
30	23.2	25.6	7.2	8.0	2.2	2.4	1937	73.1	3.5	7.3	67	机组停运
最大值	27.9	30.6	9.0	9.0	3.3	3.9	2829	73.7	5.0	8.6	72	81
最小值	16.8	19.1	1.6	1.7	1.9	2.1	1584	61.2	3.2	6.1	54	49
平均	22.9	25.6	5.1	5.6	2.3	2.6	2075	67.6	3.9	7.6	63	59

单位负责人：李辉

审核人：李中坚

报告人：李晓寒

报告日期：2025年12月3日

深圳妈湾电力有限公司2025年11月#4烟囱烟气数据

浓度单位 (mg/Nm³) 烟气量单位 万立方米/天

日期	#4烟囱排放口						机组负荷率 (%)				
	氮氧化物		二氧化硫		颗粒物		烟气量	温度℃	湿度%	氧量%	#7机组
	干基	折算	干基	折算	干基	折算					
1											0
2											0
3											0
4											0
5											0
6											0
7											0
8											0
9											0
10											0
11											0
12											0
13											0
14											0
15											0
16											0
17											0
18											0
19											0
20											0
21											0
22											0
23											0
24											0
25											0
26											0
27											0
28											0
29											0
30											0
最大值	0.0	0.0	0.0	0.0	0.0	0.0	0	0.0	0.0	0.0	0
最小值	0.0	0.0	0.0	0.0	0.0	0.0	0	0.0	0.0	0.0	0
平均	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	#DIV/0!	0

全月停机

单位负责人: 李辉

审核人: 李中坚

报告人: 李晓寒

报告日期: 2025年12月3日