

深圳妈湾电力有限公司2026年5月#2烟囱烟气数据



浓度单位 (mg/Nm³)

烟气量单位 万立方米/天

日期	#2烟囱排放口							机组负荷率 (%)				
	氮氧化物		二氧化硫		颗粒物		烟气量	温度℃	湿度%	氧量%	#3机组	#4机组
	干基	折算	干基	折算	干基	折算						
1	25.6	25.7	10.9	10.7	2.8	2.8	4162	75.3	5.4	6.0	65	64
2	24.9	24.0	15.7	14.7	2.9	2.8	4560	77.2	5.6	5.5	75	74
3	25.3	23.7	18.2	16.8	2.9	2.7	4828	77.5	5.8	4.9	83	82
4	25.4	23.0	20.2	18.3	3.9	3.5	5197	78.1	6.2	4.5	93	91
5	27.0	24.8	20.4	18.6	4.3	4.0	5081	75.7	6.0	4.7	90	88
6	25.8	24.0	20.7	19.1	4.2	3.9	5069	77.0	5.9	4.9	87	88
7	26.3	23.8	20.9	18.8	3.4	3.1	5144	78.6	6.1	4.4	91	92
8	28.7	25.2	29.1	25.5	3.1	2.7	5200	79.7	6.2	3.9	95	95
9	27.7	25.2	24.5	22.2	3.0	2.8	5064	77.9	6.0	4.5	89	90
10	26.3	24.1	19.6	17.9	3.3	3.1	5111	78.2	5.9	4.6	90	90
11	28.8	25.8	22.7	20.4	3.4	3.0	5239	78.9	6.2	4.3	95	95
12	28.7	25.8	19.3	17.3	3.3	3.0	5162	79.0	6.2	4.3	93	94
13	28.5	25.3	22.5	19.9	3.6	3.2	5172	79.9	6.3	4.1	93	95
14	30.2	26.6	29.1	25.7	2.9	2.6	5171	80.0	6.5	4.0	94	96
15	29.9	26.4	30.8	27.2	2.4	2.2	5139	79.8	6.5	4.0	94	95
16	28.6	25.9	26.2	23.6	3.0	2.7	5010	78.9	6.4	4.5	89	89
17	26.9	26.2	19.0	17.9	3.1	3.0	4429	77.3	5.9	5.6	72	73
18	29.0	25.8	29.2	25.9	2.8	2.5	5157	80.1	6.5	4.1	94	94
19	28.7	25.4	31.3	27.7	2.6	2.3	5192	79.5	6.5	4.1	95	95
20	29.1	25.8	28.1	24.9	2.5	2.2	5242	80.0	6.3	4.0	95	96
21	31.3	28.5	26.3	23.9	2.9	2.7	5247	76.5	6.3	4.5	93	94
22	29.8	26.6	27.6	24.6	3.0	2.7	5237	78.8	6.3	4.2	94	95
23	26.3	24.6	23.6	21.9	2.6	2.4	4885	78.0	6.1	5.0	84	83
24	27.2	26.0	18.5	17.4	2.5	2.4	4589	77.6	6.2	5.4	78	74
25	29.3	26.7	26.0	23.6	2.4	2.2	5057	79.1	6.2	4.5	88	89
26	29.9	26.6	30.6	27.2	2.7	2.4	5212	80.4	6.4	4.1	94	96
27	29.3	25.9	29.3	25.9	2.4	2.2	5217	80.1	6.5	4.1	94	96
28	28.7	25.9	18.1	16.3	2.5	2.3	5203	79.5	6.5	4.4	93	94
29	28.7	26.0	19.1	17.3	2.8	2.5	5117	79.5	6.5	4.5	91	92
30	27.0	26.2	13.4	12.8	2.7	2.6	4649	77.5	6.3	5.5	76	77
31	26.0	24.8	16.1	15.2	2.7	2.6	4747	78.0	6.4	5.3	80	80
最大值	31.3	28.5	31.3	27.7	4.3	4.0	5247	80.4	6.5	6.0	95	96
最小值	24.9	23.0	10.9	10.7	2.4	2.2	4162	75.3	5.4	3.9	65	64
平均	27.9	25.5	22.8	20.6	3.0	2.7	5016	78.5	6.2	4.6	88	89

单位负责人：李辉

审核人：李中坚

报告人：李晓寒

报告日期：2026 年 6 月 3 日

深圳妈湾电力有限公司2026年5月#3烟囱烟气数据

浓度单位 (mg/Nm³) 烟气量单位 万立方米/天

日期	#3烟囱排放口										机组负荷率 (%)	
	氮氧化物		二氧化硫		颗粒物		烟气量	温度℃	湿度%	氧量%	#5机组	#6机组
	干基	折算	干基	折算	干基	折算						
1	23.6	27.3	7.2	7.9	3.5	4.2	2617	68.8	3.9	8.0	7:07机组停运	48
2	25.8	30.1	7.2	7.9	2.4	2.8	2471	68.2	4.1	8.1	机组停运	54
3	28.9	31.0	10.5	10.9	3.3	3.5	2527	71.8	4.6	7.0	机组停运	69
4	27.2	30.4	8.2	8.5	2.6	2.9	3760	70.8	4.6	7.2	7:51并网发电	53
5	27.0	25.9	15.2	14.5	1.9	1.8	4696	75.4	5.0	5.4	89	71
6	28.2	27.3	12.4	11.8	1.7	1.7	4369	75.2	4.8	5.5	88	60
7	29.6	28.4	18.5	17.6	1.8	1.7	4565	77.0	4.9	5.4	91	64
8	31.0	29.2	20.5	19.3	2.4	2.2	4990	76.8	5.2	5.0	97	80
9	29.4	28.2	16.2	15.4	2.5	2.4	4504	75.7	4.8	5.3	90	62
10	28.1	27.0	14.1	13.5	2.4	2.3	4473	76.3	5.0	5.4	90	58
11	28.6	27.0	16.5	15.6	2.5	2.4	4709	77.4	5.2	5.1	94	67
12	28.4	26.8	13.4	12.5	2.6	2.5	4701	77.8	5.2	5.1	93	71
13	29.8	27.8	19.6	18.2	2.6	2.5	4951	78.9	5.5	4.9	95	81
14	30.3	28.1	28.4	26.4	2.4	2.2	5210	79.2	5.7	4.8	96	91
15	30.2	28.2	28.7	26.7	2.1	1.9	4810	78.6	5.6	4.9	96	76
16	28.9	27.6	19.1	18.1	1.9	1.8	4240	76.8	5.2	5.3	91	53
17	28.6	28.3	14.6	14.2	1.8	1.8	3960	75.0	4.9	5.8	73	47
18	29.9	28.0	27.0	25.1	2.0	1.9	5253	79.4	5.7	5.0	96	84
19	32.0	29.7	30.6	28.3	2.0	1.9	5359	78.7	5.7	4.8	97	93
20	30.8	28.7	28.6	26.7	2.1	1.9	5449	78.7	5.4	4.9	97	95
21	28.3	27.1	21.0	20.1	2.2	2.1	4670	76.2	5.3	5.3	96	66
22	28.6	26.6	25.2	23.4	2.4	2.2	5267	78.8	5.4	4.9	97	94
23	27.7	26.5	22.7	21.6	1.8	1.8	4532	78.4	5.4	5.3	91	68
24	25.0	24.6	13.1	12.7	1.7	1.7	3967	76.1	5.1	5.7	77	57
25	26.9	25.8	23.4	22.3	1.8	1.7	4642	78.3	5.3	5.4	88	74
26	30.1	28.1	30.4	28.4	2.0	1.8	5177	80.1	5.5	4.9	95	94
27	30.5	28.5	27.1	25.3	1.9	1.8	5197	80.1	5.5	4.9	96	95
28	31.0	29.3	21.2	19.9	2.2	2.1	5056	78.6	5.5	5.1	93	90
29	29.2	27.5	19.4	18.3	2.2	2.1	4802	79.5	5.6	5.1	90	83
30	27.3	26.8	15.3	14.9	2.1	2.1	3967	77.6	5.3	5.7	75	56
31	28.0	27.2	17.4	16.7	2.0	1.9	4171	77.7	5.4	5.6	78	62
最大值	32.0	31.0	30.6	28.4	3.5	4.2	5449	80.1	5.7	8.1	97	95
最小值	23.6	24.6	4.8	5.5	1.7	1.7	2471	68.2	3.9	4.8	73	47
平均	28.7	27.8	19.0	18.1	2.2	2.2	4486	76.7	5.2	5.5	91	71

单位负责人: 李辉

审核人: 李中坚

报告人: 李晓寒

报告日期: 2026 年 6 月 3 日

深圳妈湾电力有限公司2026年5月#4烟囱烟气数据



浓度单位 (mg/Nm³) 烟气量单位 万立方米/天

日期	#4烟囱排放口					
	氮氧化物		烟气量	温度℃	湿度%	氧量%
	干基	折算				
1	机组停运					
2						
3						
4						
5						
6						
7						
8						
9						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
21						
22						
23						
24						
25						
26	4.6	5.9	3089.8	75.8	8.2	16.2
27	3.3	2.8	4163.7	83.6	11.2	13.7
28	3.4	3.1	2319.7	79.6	7.4	16.8
29	3.8	3.4	2876.7	78.9	8.3	15.9
30	2.9	2.3	4163.4	82.8	10.6	13.6
31	机组停运					
最大值	4.6	5.9	4164	83.6	11.2	16.8
最小值	2.9	2.3	2320	75.8	7.4	13.6
平均	3.6	3.5	3323	80.1	9.1	15.2

单位负责人: 李辉

审核人: 李中坚

报告人: 李晓寒

报告日期: 2026 年6月3日